

Tools for Schools - Indoor Air Quality

Follow-up Action Plan for Site



Millennium Middle

81 62%

Principal: Dr. Cheryl Cendan

Walkthrough Date: 5/26/2004

Temp RH Co2
Outside Measurements

Assignment Member: Bob Krickovich

Room	Priority	Responsible	Assessment Comments	Recommended Corrective Action
125	3	Site	Dust accumulation was observed on environmental surfaces.	Custodial staff should thoroughly clean all environmental surfaces within classroom.
136	3	Site		Site based administration will provide information to site based staff.
136	3	Site		Site based administration will provide information to site based staff.
136	3	Site		Site based administration will provide information to site based staff.
136	3	Site		Contact EPA website www.epa.gov/iaq
224	3	Site	Traps dry.	Site to run water at least once per month to keep trap wet.
241	3	Site	Dust accumulation was observed on environmental surfaces and flooring has minor stains.	Custodial staff should thoroughly clean all environmental surfaces within classroom and clean and wax flooring.
245	3	Site		Site based administration will provide information to site based staff.
245	3	Site		Site based administration will provide information to site based staff.
245	3	Site		Site based administration will provide information to site based staff.
245	3	Site		Site based administration will provide information to site based staff.
245	3	Site		Contact EPA website www.epa.gov/iaq
245	3	Site		Site based administration will provide information to site based staff.
245	3	Site		Site based administration will provide information to site based staff.
319	3	Site	Carpeting is stained.	Clean and sanitize carpeting.
320	3	Site	Dust accumulation was observed on environmental surfaces. Floor tile stained and dirty.	custodial staff should thoroughly clean all environmental surfaces within classroom and clean and wax flooring.