

Millennium Middle

Outdoor Parameter Measurements:

WalkthroughDate: 5/26/2004

Temp

RH

Co2

81

62%

	Category	Detail	Assessment Comments	Recommended Corrective Action
125	Temp	74		
	RH	47%		
	Co2			
	Excess Moisture	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Clean spills promptly.	Minor carpet staining.	No corrective action recommended at this time.
General Cleanliness	confirm that the office area is cleaned properly	Dust accumulation was observed on environmental surfaces.	Custodial staff should thoroughly clean all environmental surfaces within classroom.	
Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.	
I am not sure of the buttons to push. If "I" needed help completing the requirements in my media center because I couldn't do it alone, I clicked need help.				
136	Temp	73		
	RH	49%		
	Co2			
	Animals in the Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.
	Health and Hygiene Education	Inform students and staff about the importance of good hygiene in preventing the spread of airborne contagious diseases.		Site based administration will provide information to site based staff.
	Health and Hygiene Education	Obtain Indoor Air Quality: An introduction for health professionals.		Site based administration will provide information to site based staff.
Health and Hygiene Education	Provide information about IAQ and health.		Contact EPA website www.epa.gov/iaq	
Maintain Student Health Records	Track health-related complaints by students and staff.		Site based administration will provide information to site based staff.	
I took the survey on 11/18 but my name did not appear on the list. Please email to confirm.				

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
139	74 <i>Temp</i>	49% <i>RH</i>		
	Animals in the Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.
212	73 <i>Temp</i>	52% <i>RH</i>		
	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment. Teacher advised old roof leak has been repaired.	No corrective action recommended at this time.
224	73 <i>Temp</i>	53% <i>RH</i>		
	Drain Traps in the Classroom	Drain traps, if present, can become a problem when the water in the drain trap evaporates due to infrequent use, allowing sewer gases to enter the room.	Traps dry.	Site to run water at least once per month to keep trap wet.
228	73 <i>Temp</i>	52% <i>RH</i>		
	Animals in the Classroom	General items to watch for.	No animals in the classroom.	No corrective action recommended at this time.
	Animals in the Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.
	Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
	Local Exhaust Fans	Confirm that fume hoods and local exhaust fans are used whenever activities that generate pollutants take place.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Local Exhaust Fans	General items.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Local Exhaust Fans	Confirm that fume hoods and local exhaust fans function properly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.
	Ventilation	If you have mechanical ventilation, confirm that air is flowing from the room into the air return grille(s).	Return air grill is functioning properly.	No corrective action recommended at this time.
	Ventilation	Determine how your classroom is ventilated.	4 supply grills and 2 return air grills.	No corrective action recommended at this time.
240				
		72	53%	
		<i>Temp</i>	<i>RH</i>	<i>Co2</i>
	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment. Leak under sink in back room has been repaired.	No corrective action recommended at this time.
241				
		71	54%	
		<i>Temp</i>	<i>RH</i>	<i>Co2</i>
	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment. Leak under sink in back room has been repaired.	No corrective action recommended at this time.
	General Cleanliness	Confirm that the classroom is cleaned properly	Dust accumulation was observed on environmental surfaces and flooring has minor stains.	Custodial staff should thoroughly clean all environmental surfaces within classroom and clean and wax flooring.
	<p>My room is an interior room. The vent in the ceiling needs a bit of repair. My fume hood works and is totally functional. We are not in the building for pest controls days so it does not effect my students. We have controlled air conditionnig and it stays at a comfortable level at all times. There is no evidence of mold in my room and no water leaks as of yet.</p>			

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
245	73 <i>Temp</i>	55% <i>RH</i>		
	Health and Hygiene Education	Obtain Indoor Air Quality: An introduction for health professionals.		Site based administration will provide information to site based staff.
	Health and Hygiene Education	Provide information about IAQ and health.		Contact EPA website www.epa.gov/iaq
	Health and Hygiene Education	Establish an information and counseling program regarding smoking.		Site based administration will provide information to site based staff.
	Health and Hygiene Education	Inform students and staff about the importance of good hygiene in preventing the spread of airborne contagious diseases.		Site based administration will provide information to site based staff.
	Health Officer's Office	Ensure that the ventilation system is properly operating.	Ventilation is working properly.	No corrective action recommended at this time.
	Maintain Student Health Records	Recognize indicators that health problems may be IAQ-related.		Site based administration will provide information to site based staff.
	Maintain Student Health Records	Track health-related complaints by students and staff.		Site based administration will provide information to site based staff.
	Maintain Student Health Records	Include information about sensitivities to IAQ problems in student health records.		Site based administration will provide information to site based staff.
270	75 <i>Temp</i>	52% <i>RH</i>		
	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment. Roof leak has been fixed and ceiling tile replaced.	No corrective action recommended at this time.
		There was a leak coming through the ceiling but custodians took care of it immediately but the stain is there.		
319	75 <i>Temp</i>	53% <i>RH</i>		
	Animals in the Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
320	General Classroom Information		Carpeting is stained.	Clean and sanitize carpeting.
		Our room is swept, but the carpeting is not vacuumed. I believe this may lead to too much dust in the carpet, leading to problems with students with allergies. When I asked the maintenance man about vacuuming, the statement was that the vacuums threw out too much dust into the room and thus were inefficient.		
	75	52%		
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	General Classroom Information		Dust accumulation was observed on environmental surfaces. Floor tile stained and dirty.	custodial staff should thoroughly clean all environmental surfaces within classroom and clean and wax flooring.
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Local Exhaust Fans	Confirm that fume hoods and local exhaust fans function properly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.