

# Nova Middle

## IAQ Walkthrough 5/6/2005

Outside Temp  RH%  CO2

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority	
<b>116</b>	Temp <input type="text" value="68.6"/> RH% <input type="text" value="54.9"/> CO2 <input type="text" value="661"/>	Occupants: <input type="text" value="2"/>				
<b>THERMAL COMFORT</b>						
	Room is usually comfortable? (If no, please explain in the notes below.)	Classroom is VERY cold--very difficult to function properly.	Environmental parameters were not within acceptable range at the time of assessment..	Physical Plant Operations to evaluate need for test and balance.	Physical Plant Operations	2
	Temperature in my classroom is generally comfortable (72F-76F)?	Classroom is VERY cold--very difficult to function properly.	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
<b>Walkthrough</b>						
		Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2	
		Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2	
<b>128</b>	Temp <input type="text" value="68.1"/> RH% <input type="text" value="58.9"/> CO2 <input type="text" value="870"/>	Occupants: <input type="text" value="17"/>				
<b>ANIMALS IN THE CLASSROOM</b>						
	Activities and/or room conditions are modified to address student allergies?	No animals identified at the time of assessment.	None	None		
<b>EXCESS MOISTURE IN CLASSROOMS</b>						
	Windows, windowsills and window frames free of continuous condensation?	No condensation on windows at the time of assessment.	None	None		
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for roof leaks and repair as appropriate.	Physical Plant Operations	2	
<b>GENERAL CLEANLINESS</b>						
	Room is free of pests?	No pests observed at the time of assessment.	None	None		
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	No dust observed on supply/return registers at the time of assessment.	None	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

128

Temp  RH%  CO2

Occupants:

Classroom is dusted/vacuumed thoroughly and regularly?

Slight dust accumulation was observed on environmental surfaces at the time of assessment.

Site based administration should address general cleanliness with facility serviceperson staff.

Site Based

2

Spills and other such issues requiring custodial assistance are addressed in a timely manner?

No issues identified relating to spill clean up practices at the time of assessment..

None

None

**THERMAL COMFORT**

Temperature in my classroom is generally comfortable (72F-76F)?

We have been told this building has a broken thermostat for years. It is either a freezer (when on) or a sauna (when off) in this classroom. It is NEVER comfortable.

Temperature was low at the time of assessment.

Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Site Based

2

Room is usually comfortable? (If no, please explain in the notes below.)

We have been told this building has a broken thermostat for years. It is either a freezer (when on) or a sauna (when off) in this classroom. It is NEVER comfortable.

Temperature was low at the time of assessment.

Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Site Based

2

Room is free of the introduction of outdoor air? (Gaps in window/door frames.)

We have been told this building has a broken thermostat for years. It is either a freezer (when on) or a sauna (when off) in this classroom. It is NEVER comfortable.

No gaps in windows or doors identified at the time of assessment.

None

None

Classroom is free of significant temperature shifts?

We have been told this building has a broken thermostat for years. It is either a freezer (when on) or a sauna (when off) in this classroom. It is NEVER comfortable.

Temperature was low at the time of assessment.

Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Site Based

2

Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)

We have been told this building has a broken thermostat for years. It is either a freezer (when on) or a sauna (when off) in this classroom. It is NEVER comfortable.

Humidity was slightly elevated at the time of assessment - 10% greater than outdoors.

Facilities serviceperson should monitor this room.

Site Based

2

132

Temp  RH%  CO2

Occupants:

**AIR CONDITIONING**

Room is free of smell of mold or mildew?

No odor detected at the time of assessment.

None

None

**ANIMALS IN THE CLASSROOM**

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
132	Temp	74.0	RH% 52.1	CO2 1124	Occupants: 18			
	Activities and/or room conditions are modified to address student allergies?	I suffer from asthma, so do many of my students. Custodian RARELY dusts. One of my students that does not have allergies usually volunteers to dust the room.			None	None		
<b>GENERAL CLEANLINESS</b>								
	Classrooms general appearance is clean and acceptable?	custodians never use detergent and water. I supply my own cleaner and clean floors myself on a weekly basis			General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Trash is removed daily and trash bags are changed as appropriate?	custodians never use detergent and water. I supply my own cleaner and clean floors myself on a weekly basis			No issues identified regarding trash removal practices.	None	None	
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?	custodians never use detergent and water. I supply my own cleaner and clean floors myself on a weekly basis			No issues identified relating to spill clean up practices at the time of assessment..	None	None	
	Room is free of pests?	custodians never use detergent and water. I supply my own cleaner and clean floors myself on a weekly basis			No pests observed at the time of assessment.	None	None	
	Floor is cleaned on a regular basis?	custodians never use detergent and water. I supply my own cleaner and clean floors myself on a weekly basis			Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?	custodians never use detergent and water. I supply my own cleaner and clean floors myself on a weekly basis			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	custodians never use detergent and water. I supply my own cleaner and clean floors myself on a weekly basis			No dust observed on supply/return registers at the time of assessment.	None	None	
<b>LOCAL EXHAUST FANS</b>								
	Other exhaust fans that may exist in the classroom are functioning properly?				Exhaust fan is functioning properly.	None	None	
	Bathroom exhaust fan is functioning properly?				No bathroom. Identified in error.	None	None	
<b>THERMAL COMFORT</b>								
	Classroom is free of significant temperature shifts?	At times the room is very cold and then when someone complains, the room becomes uncomfortably hot. The students actually get so hot that perspiration runs down their faces. The room also becomes "muggy".			Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
132	Temp	74.0	RH%	52.1	CO2	1124	Occupants:	18			
	Room is usually comfortable? (If no, please explain in the notes below.)	At times the room is very cold and then when someone complains, the room becomes uncomfortably hot. The students actually get so hot that perspiration runs down their faces. The room also becomes "muggy".			Temperature was acceptable at the time of assessment.	None	None				
	Temperature in my classroom is generally comfortable (72F-76F)?	At times the room is very cold and then when someone complains, the room becomes uncomfortably hot. The students actually get so hot that perspiration runs down their faces. The room also becomes "muggy".			Temperature was acceptable at the time of assessment.	None	None				
134	Temp	71.6	RH%	54.2	CO2	1107	Occupants:	25			
	<b>GENERAL CLEANLINESS</b>										
	Floor is cleaned on a regular basis?				Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based				2
	<b>THERMAL COMFORT</b>										
	Classroom is free of significant temperature shifts?				Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based				2
	<b>Walkthrough</b>										
					Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based				2
138	Temp	71.4	RH%	55.2	CO2	1202	Occupants:	19			
	<b>ANIMALS IN THE CLASSROOM</b>										
	You are informed about the potential allergies of your students?						None				None
	<b>EXCESS MOISTURE IN CLASSROOMS</b>										
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				No leaks or signs of water intrusion identified.		None				None
	<b>GENERAL CLEANLINESS</b>										
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				No dust observed on supply/return registers at the time of assessment.		None				None

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
138	Temp	71.4	RH% 55.2	CO2 1202	Occupants: 19		
141	Temp	72.7	RH% 63.1	CO2 1129	Occupants: 25		
<b>AIR CONDITIONING</b>							
	Room is free of smell of chemicals?	Sometimes there is a very strong smell like wet concrete. I use an air freshener to make it go away. Also, in the morning,s I sometimes find desks turned and the smells of chewing tabbaco is very strong.			No odor detected at the time of assessment.	None	None
	Room is free of smell of mold or mildew?	Sometimes there is a very strong smell like wet concrete. I use an air freshener to make it go away. Also, in the morning,s I sometimes find desks turned and the smells of chewing tabbaco is very strong.			No odor detected at the time of assessment.	None	None
<b>GENERAL CLEANLINESS</b>							
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?				No issues identified relating to spill clean up practices at the time of assessment..	None	None
	Room is free of the use of scented cleaners and air fresheners?				No scented cleaners, air fresheners or non-approved chemicals found at the time of assessment.	None	None
	Floor is cleaned on a regular basis?				Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	Room is free of pests?				No pests observed at the time of assessment.	None	None
<b>THERMAL COMFORT</b>							
	Room is usually comfortable? (If no, please explain in the notes below.)	The room feels like a freezer. My students and I are constantly having to wear sweaters.			Temperature was acceptable at the time of assessment.	None	None
	Temperature in my classroom is generally comfortable (72F-76F)?	The room feels like a freezer. My students and I are constantly having to wear sweaters.			Temperature was acceptable at the time of assessment.	None	None
217	Temp	71.3	RH% 52.7	CO2 2836	Occupants: 3		
<b>ANIMALS IN THE CLASSROOM</b>							
	Activities and/or room conditions are modified to address student allergies?					None	None
	You are informed about the potential allergies of your students?					None	None

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
217	Temp	71.3	RH% 52.7	CO2 2836	Occupants: 3		
<b>GENERAL CLEANLINESS</b>							
	Classroom is dusted/vacuumed thoroughly and regularly?	Floor is swept routinely; however, not mopped		Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?	Floor is swept routinely; however, not mopped		Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Room is free of pests?	Floor is swept routinely; however, not mopped		No pests observed at the time of assessment.	None	None	
<b>Walkthrough</b>							
				Signs of microbial growth on west wall.	Physical Plant Operations to evaluate for roof leaks and repair as appropriate.	Physical Plant Operations	1
298	Temp	74.5	RH% 44.9	CO2 3548	Occupants: 17		
<b>GENERAL CLEANLINESS</b>							
	Classroom is dusted/vacuumed thoroughly and regularly?	Floor is occasionally swept. I do not believe it has been mopped due to a sortage of janitorial staff.		Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?	Floor is occasionally swept. I do not believe it has been mopped due to a sortage of janitorial staff.		Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
<b>THERMAL COMFORT</b>							
	Classroom is free of significant temperature shifts?			Temperature was acceptable at the time of assessment.	None	None	
704	Temp	71.2	RH% 62.3	CO2 1298	Occupants: 27		
<b>DRAIN TRAPS IN THE CLASSROOM</b>							
	Water poured down floor drains once per week (approx. 1 quart of water).			It appears as though water is poured down the floor drain at least once a week.	None	None	
<b>GENERAL CLEANLINESS</b>							
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
705	Temp	69.3	RH% 52.5	CO2 938	Occupants: 3			
<b>AIR CONDITIONING</b>								
	Air is flowing without obstruction?	It is not a comfortable temperature sometimes; right now I am wearing a sweater. Other times, I am too warm.			Air flowing without obstruction at the time of assessments.	None	None	
	Air flowing from air supply?	It is not a comfortable temperature sometimes; right now I am wearing a sweater. Other times, I am too warm.			Air flowing without obstruction at the time of assessments.	None	None	
	Room is free of smell of kitchen/food?	It is not a comfortable temperature sometimes; right now I am wearing a sweater. Other times, I am too warm.			No odor detected at the time of assessment.	None	None	
<b>ANIMALS IN THE CLASSROOM</b>								
	You are informed about the potential allergies of your students?	I just recently received a list of students with allergies but it does not clearly state what specific things that they are allergic to. So, I can not really modify things without knowing those details. As a science teacher, this info is important for				None	None	
	Activities and/or room conditions are modified to address student allergies?	I just recently received a list of students with allergies but it does not clearly state what specific things that they are allergic to. So, I can not really modify things without knowing those details. As a science teacher, this info is important for				None	None	
<b>DRAIN TRAPS IN THE CLASSROOM</b>								
	Water run in sinks at least once per week (about 2 cups of water).	I have 10 sinks in my room and use one on a regular basis; the other ones are not used.			It appears as though sink is not utilized regularly. Sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.	Site based administration should address maintenance of sinks with facility serviceperson staff.	Site Based	2
<b>EXCESS MOISTURE IN CLASSROOMS</b>								
	Cold water pipes free of continuous condensation?	I have 10 sinks in my room and use one on a regular basis; the other ones are not used.			No condensation on pipes at the time of assessment.	None	None	
	Windows, windowsills and window frames free of continuous condensation?	I have 10 sinks in my room and use one on a regular basis; the other ones are not used.			No condensation on windows at the time of assessment.	None	None	
<b>Walkthrough</b>								
					Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
					Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
705	Temp	69.3	RH% 52.5	CO2 938	Occupants: 3		
				Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
				Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
706	Temp	72.0	RH% 62.3	CO2 1149	Occupants: 31		
<b>ANIMALS IN THE CLASSROOM</b>							
	Activities and/or room conditions are modified to address student allergies?		Classroom has never been mopped since students first arrived in August. Classroom floor is cleaned using a pushbroom only. This does not remove dust, only debris.		None	None	
	You are informed about the potential allergies of your students?		Classroom has never been mopped since students first arrived in August. Classroom floor is cleaned using a pushbroom only. This does not remove dust, only debris.		None	None	
<b>DRAIN TRAPS IN THE CLASSROOM</b>							
	Water poured down floor drains once per week (approx. 1 quart of water).			It appears as though sink is not utilized regularly. Sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.	Site based administration should address maintenance of sinks with facility serviceperson staff.	Site Based	2
<b>GENERAL CLEANLINESS</b>							
	Floor is cleaned on a regular basis?		Classroom has never been mopped since students first arrived in August. Classroom floor is cleaned using a pushbroom only. This does not remove dust, only debris.	Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Room is free of the use of scented cleaners and air fresheners?		Classroom has never been mopped since students first arrived in August. Classroom floor is cleaned using a pushbroom only. This does not remove dust, only debris.	No scented cleaners, air fresheners or non-approved chemicals found at the time of assessment.	None	None	
	Classrooms general appearance is clean and acceptable?		Classroom has never been mopped since students first arrived in August. Classroom floor is cleaned using a pushbroom only. This does not remove dust, only debris.	General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2



FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
706	Temp	72.0	RH% 62.3	CO2 1149	Occupants: 31			
	Classroom is dusted/vacuumed thoroughly and regularly?	Classroom has never been mopped since students first arrived in August. Classroom floor is cleaned using a pushbroom only. This does not remove dust, only debris.			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	<b>LOCAL EXHAUST FANS</b>							
	Bathroom exhaust fan is functioning properly?				No bathroom. Identified in error.	None	None	
	<b>THERMAL COMFORT</b>							
	Temperature in my classroom is generally comfortable (72F-76F)?	Room is often to cold for comfort or no air is on at all.			Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Classroom is free of significant temperature shifts?	Room is often to cold for comfort or no air is on at all.			Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Room is usually comfortable? (If no, please explain in the notes below.)	Room is often to cold for comfort or no air is on at all.			Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
708	Temp	71.9	RH% 54.8	CO2 992	Occupants: 3			
	<b>GENERAL CLEANLINESS</b>							
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	<b>Walkthrough</b>							
					Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
					Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
709	Temp	<input type="text" value="67.3"/>	RH% <input type="text" value="60.5"/>	CO2 <input type="text" value="1475"/>	Occupants: <input type="text" value="23"/>		
	<b>DRAIN TRAPS IN THE CLASSROOM</b>						
	Water poured down floor drains once per week (approx. 1 quart of water).			It appears as though water is poured down the floor drain at least once a week.	None	None	
	<b>GENERAL CLEANLINESS</b>						
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?			Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	<b>LOCAL EXHAUST FANS</b>						
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?				None	None	
711	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
	<b>DRAIN TRAPS IN THE CLASSROOM</b>						
	Water poured down floor drains once per week (approx. 1 quart of water).			It appears as though water is poured down the floor drain at least once a week.	None	None	
	Water run in sinks at least once per week (about 2 cups of water).			It appears as though sink is utilized regularly. No sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.	None	None	
	<b>EXCESS MOISTURE IN CLASSROOMS</b>						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Signs of water intrusion. Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
	<b>GENERAL CLEANLINESS</b>						
	Floor is cleaned on a regular basis?			Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority	
711	Temp <input type="text"/> RH% <input type="text"/> CO2 <input type="text"/>	Occupants: <input type="text"/>				
	Classrooms general appearance is clean and acceptable?	The custodial care of my room is deplorable. Counters are dusty, sinks are dirty, the floor is rarely mopped, Maintenance issues are not addressed in a timely manner. Only when a "substitute" custodian was assigned to my room was it really cleaned!	General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Room is free of pests?	The custodial care of my room is deplorable. Counters are dusty, sinks are dirty, the floor is rarely mopped, Maintenance issues are not addressed in a timely manner. Only when a "substitute" custodian was assigned to my room was it really cleaned!	No pests observed at the time of assessment.	None	None	
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?	The custodial care of my room is deplorable. Counters are dusty, sinks are dirty, the floor is rarely mopped, Maintenance issues are not addressed in a timely manner. Only when a "substitute" custodian was assigned to my room was it really cleaned!	No issues identified relating to spill clean up practices at the time of assessment..	None	None	
817C	Temp <input type="text"/> RH% <input type="text"/> CO2 <input type="text"/>	Occupants: <input type="text"/>				
	<b>AIR CONDITIONING</b>					
	Room is free of smell of mold or mildew?	Often the electricity or the individual A/C units are tuned off at night or over the weekends. This DOES NOT keep a continous check on the mold and mildew problem in the Portable.	No odor detected at the time of assessment.	None	None	
	<b>ANIMALS IN THE CLASSROOM</b>					
	Activities and/or room conditions are modified to address student allergies?	Evidence STILL of squirrels entering between the roof and interior ceiling tiles		None	None	
	Classroom is free of animals and pets?	Evidence STILL of squirrels entering between the roof and interior ceiling tiles	No pests observed at the time of assessment.	None	None	
	<b>EXCESS MOISTURE IN CLASSROOMS</b>					
	Windows, windowsills and window frames free of continuous condensation?		No condensation on windows at the time of assessment.	None	None	
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?		No leaks or signs of water intrusion identified.	None	None	
	<b>GENERAL CLEANLINESS</b>					
	Floor is cleaned on a regular basis?		Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
817C	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>			
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2	
	<b>THERMAL COMFORT</b>							
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)			We have had frequent bouts with bad A/C units and have suffered through lengthy periods without sufficient cooling. At this time, the room is cool and stable; yet throughout, recent difficulties, district attention to severe problems was VERY SLOW!!!	Gaps in windows or doors identified at the time of assessment.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
R21A	Temp	<input type="text" value="71.1"/>	RH% <input type="text" value="75.7"/>	CO2 <input type="text" value="428"/>	Occupants: <input type="text" value="2"/>			
	<b>AIR CONDITIONING</b>							
	Room is free of smell of mold or mildew?			Odor detected at the time of assessment.	Physical Plant Operations to evaluate cause of odor.	Physical Plant Operations	2	
	<b>ANIMALS IN THE CLASSROOM</b>							
	Activities and/or room conditions are modified to address student allergies?				None	None		
	You are informed about the potential allergies of your students?				None	None		
	<b>ART SUPPLIES</b>							
	Following good handling and storage practices for industrial supplies?			No industrial supplies in room. Room not being used as an industrial room.	None	None		
	Exposure minimized for industrial supplies?			No industrial supplies in room. Room not being used as an industrial room.	None	None		
	<b>DRAIN TRAPS IN THE CLASSROOM</b>							
	Water run in sinks at least once per week (about 2 cups of water).			It appears as though water is poured down the floor drain at least once a week.	None	None		
	<b>EXCESS MOISTURE IN CLASSROOMS</b>							
	Windows, windowsills and window frames free of continuous condensation?			No condensation on windows at the time of assessment.	None	None		
	Indoor surfaces of exterior walls free of continuous condensation?			No condensation on windows at the time of assessment.	None	None		
	Cold water pipes free of continuous condensation?			No condensation on pipes at the time of assessment.	None	None		
	Classroom lavatories/water fountains free of leaks?			Signs of water intrusion. Leak identified.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
<i>R21A</i>	Temp	71.1	RH% 75.7	CO2 428	Occupants: 2		
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for roof leaks and repair as appropriate.	Physical Plant Operations	1
	Area around and under classroom sinks free of leaks?			Signs of water intrusion. Leak identified.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
<b>GENERAL CLEANLINESS</b>							
	Floor is cleaned on a regular basis?			Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Physical Plant Operations	2
	Classrooms general appearance is clean and acceptable?			General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
<b>THERMAL COMFORT</b>							
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)			No gaps in windows or doors identified at the time of assessment.	None	None	
	Walkthrough			Humidity was slightly elevated at the time of assessment - 10% greater than outdoors.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	2