

Parkway Middle

Outdoor Parameter Measurements:

WalkthroughDate: 5/18/2004

Temp

RH

Co2

86

48%

	Category	Detail	Assessment Comments	Recommended Corrective Action
103E	Temp: 75	RH: 47%	Co2: 850	
	Maintain Student Health Records	Recognize indicators that health problems may be IAQ-related.		Site based administration will provide information to site based staff.
107	Temp: 76	RH: 53%	Co2: 900	
	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	Ceiling tiles are water damaged by back door.	Maintenance to inspect for leaks and repair as appropriate and replace ceiling tiles.
	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment. Dust accumulating on books.	Custodial staff should thoroughly clean all books.
112	Temp: 75	RH: 53%	Co2: 1150	
	Local Exhaust Fans	Confirm that fume hoods and local exhaust fans are used whenever activities that generate pollutants take place.	Checked home economics room for odors and none were present at time of assessment.	No corrective action recommended at this time.
	Local Exhaust Fans	Confirm that fume hoods and local exhaust fans function properly.	Checked home economics room for odors and none were present at time of assessment.	No corrective action recommended at this time.
	Local Exhaust Fans	General items.	Checked home economics room for odors and none were present at time of assessment.	No corrective action recommended at this time.
	Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.
112B	I have smells that come into my room through the ventilation system from the home economics room.		
	74.6	63%	1060
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>
	General Classroom Information		Dust accumulation was observed on environmental surfaces.
General Classroom Information		Damaged ceiling tiles.	Install new ceiling tiles.
Health and Hygiene Education	Provide information about IAQ and health.		Site based administration will provide information to site based staff.
Health and Hygiene Education	Inform students and staff about the importance of good hygiene in preventing the spread of airborne contagious diseases.		Site based administration will provide information to site based staff.
Health and Hygiene Education	Obtain Indoor Air Quality: An introduction for health professionals.		Contact EPA website www.epa.gov/iaq
Health Officer's Office	Ensure that the ventilation system is properly operating.	Ventilation is working properly.	No corrective action recommended at this time.
Maintain Student Health Records	Include information about sensitivities to IAQ problems in student health records.		Site based administration will provide information to site based staff.
Maintain Student Health Records	Recognize indicators that health problems may be IAQ-related.		Site based administration will provide information to site based staff.
Maintain Student Health Records	Track health-related complaints by students and staff.		Site based administration will provide information to site based staff.
114	Please make our environment comfortable and conducive for learning.		
	74.8	52%	980
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>
General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Industrial and Vocational Education Supplies	Minimize exposure to hazardous materials.	There were no problems observed at time of assessment.	No corrective action recommended at this time.

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
Science Supplies	Learn about your supplies. Read labels and identify precautions regarding fumes ventilation. Request information and Material Safety Data Sheets (MSDS) from supplies and manufacturers.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Science Supplies	Follow good safety, handling, and storage practices.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Science Supplies	Minimize exposure to hazardous materials.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.
Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.
<div style="border: 1px solid black; width: 100%; height: 20px; margin-bottom: 5px;"></div>			
116-118	78.6	50%	1071
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>
Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Check stove hood, ducts. There is no ventilation for adjoining rooms.	Maintenance to inspect and repair as appropriate.
<div style="border: 1px solid black; width: 100%; height: 20px; margin-bottom: 5px;"></div>			
124	72.5	59%	780
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>
Animals in the Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.
General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment. Flooring dirty.	Clean and sanitize flooring.

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
Thermal Comfort	Humidity level.	The humidity was 59% at the time of assessment. The desired humidity level is below 60%. Teacher advised that mold forms during the summer months.	Maintenance needs to inspect HVAC for proper operation.
Ventilation	If you have mechanical ventilation, confirm that air is flowing from the room into the air return grille(s).	Return air grill is functioning properly.	No corrective action recommended at this time.
Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.
Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.
125	Air temperature in my room needs major adjustment. Either it is frigid or the air is off. This is unacceptable!		
	73.5	58%	800
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>
	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.
Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
136			
	74.4	51%	1100
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>
Animals in the Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.
General Cleanliness	Check for pests.	Teacher advised that sometimes there are pests by the windows and cleans them.	No corrective action recommended at this time.
General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment. Carpeting is dirty.	Clean and sanitize carpeting.

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
Thermal Comfort	Humidity level.	The humidity was 51% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.
Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.
Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.
Ventilation	If you have mechanical ventilation, confirm that air is flowing from the room into the air return grille(s).	Return air grill is functioning properly.	No corrective action recommended at this time.
Ventilation	Check for unexplained odors.	Sometimes a musty odor is present. Temperature was within acceptable range at time of assessment. Teacher advised that the room is either too hot or too cold.	Maintenance needs to inspect HVAC for proper operation.

138

70.1	54%	
<i>Temp</i>	<i>RH</i>	<i>Co2</i>

Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	Ceiling tiles have water damage.	Maintenance to inspect for leak and repair as appropriate and replace ceiling tiles.
Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	Condensation on windows and vents.	Maintenance to inspect and repair as appropriate.
General Cleanliness	Check for pests.	Teacher advised that there are sometimes pests but she takes care of them.	No corrective action recommended at this time.
General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment. Flooring dirty.	Clean and sanitize flooring.
Local Exhaust Fans	Confirm that fume hoods and local exhaust fans are used whenever activities that generate pollutants take place.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Thermal Comfort	Humidity level.	The humidity was 54% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.
Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
Ventilation	If you have mechanical ventilation, confirm that air is flowing from the room into the air return grille(s).	Return air grill is functioning properly.	No corrective action recommended at this time.
Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.
Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.

139

74.6	51%	1320
<i>Temp</i>	<i>RH</i>	<i>Co2</i>

Animals in the Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.
Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	Ceiling tiles are bowed.	Maintenance to inspect and repair as appropriate.
General Cleanliness	Check for pests.	Teacher advised that bugs come into the room.	Maintenance to inspect closers and repair as appropriate.
Local Exhaust Fans	General items.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Local Exhaust Fans	Confirm that fume hoods and local exhaust fans function properly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
Thermal Comfort	Humidity level.	The humidity was 51% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.
Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.
Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.
Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Teacher reported room is sometimes hot.	See other item to check HVAC.
Ventilation	If you have mechanical ventilation, confirm that air is flowing from the room into the air return grille(s).	Teacher advised room is sometimes hot.	Maintenance needs to inspect HVAC for proper operation.

<i>Category</i>	<i>Detail</i>			<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
139A					
	75.3	51%	1370		
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>		
	General Cleanliness	Confirm that the classroom is cleaned properly		General cleanliness appeared adequate on date of assessment. Flooring dirty.	Clean and sanitize flooring.
Thermal Comfort	General items to watch for.		Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.	
Ventilation	If you have mechanical ventilation, confirm that air is flowing from the room into the air return grille(s).		Return air grill is functioning properly.	No corrective action recommended at this time.	
140					
	76.6	62%	1270		
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>		
	Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.		There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.		Check ceiling tiles.	Maintenance to inspect and repair as appropriate.
	General Cleanliness	Confirm that the classroom is cleaned properly		General cleanliness appeared adequate on date of assessment. Flooring dirty.	Clean and sanitize flooring.
	Thermal Comfort	General items to watch for.		Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
	Thermal Comfort	Humidity level.		Humidity slightly elevated.	Maintenance needs to inspect HVAC for proper operation.
Ventilation	Check for unexplained odors.		No odors were detected at time of assessment.	No corrective action recommended at this time.	
Ventilation	Determine how your classroom is ventilated.		Ventilation is working properly.	No corrective action recommended at this time.	

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
141	77.7 <i>Temp</i>	50% <i>RH</i>	1600 <i>Co2</i>	
	Exterior Inspection	Check outdoor equipment functionality.	Not applicable.	No corrective action recommended at this time.
	Exterior Inspection	Check preventative outdoor items.	Not applicable.	No corrective action recommended at this time.
	Exterior Inspection	Check for attic leaks.	There is no attic in this room.	No corrective action recommended at this time.
	Exterior Inspection	Attic residents.	There is no attic in this room.	No corrective action recommended at this time.
	Exterior Inspection	General considerations for roof.	Ceiling tiles are water damaged.	Maintenance to inspect and repair as appropriate.
	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment. Flooring dirty.	Clean and sanitize flooring.
	Interior Inspection	General considerations for classrooms and other areas.	Not applicable.	No corrective action recommended at this time.
	Interior Inspection	General maintenance items.	Not applicable.	No corrective action recommended at this time.
146A				
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	General Classroom Information		Room is very messy. This is a passageway.	Custodial staff to clean.
147A				
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	General Classroom Information		Ceiling tiles are damaged, window needs to be replaced, and vents and return grills need to be cleaned.	Maintenance to inspect and repair as appropriate.
	General Classroom Information		Moldy items, burned out bulb, and odor in room.	Custodial staff to remove moldy items, replace bulb, and check for odor in room.

	<i>Category</i>			<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
148	71.6	48%	1120			
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>			
Art Supplies				Follow good safety, handling, and storage practices.	School is working on removal of chemicals.	No corrective action recommended at this time.
Art Supplies				Minimize exposure to hazardous materials.	School is working on removal of chemicals.	No corrective action recommended at this time.
Drain Traps in the Classroom				Drain traps, if present, can become a problem when the water in the drain trap evaporates due to infrequent use, allowing sewer gases to enter the room.	Custodian will fill sink with water.	No corrective action recommended at this time.
Excess Moisture in Classrooms				Check for leaks or signs of moisture from plumbing or roofs.	Moisture in light diffuser cover.	Maintenance to inspect and repair as appropriate.
General Cleanliness				Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness				Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment. Floors are dirty.	Clean and sanitize flooring.
Industrial and Vocational Education Supplies				Minimize exposure to hazardous materials.	School is working on removal of chemicals.	No corrective action recommended at this time.
Industrial and Vocational Education Supplies				Follow good safety, handling, and storage practices.	School is working on removal of chemicals.	No corrective action recommended at this time.
Industrial and Vocational Education Supplies				Learn about your supplies.		Site based administration will provide information to site based staff.
Science Supplies				Learn about your supplies. Read labels and identify precautions regarding fumes ventilation. Request information and Material Safety Data Sheets (MSDS) from supplies and manufacturers.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Science Supplies				Follow good safety, handling, and storage practices.	School is working on removal of chemicals.	No corrective action recommended at this time.
Science Supplies				Minimize exposure to hazardous materials.	School is working on removal of chemicals.	No corrective action recommended at this time.
Thermal Comfort				General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
Thermal Comfort				Humidity level.	The humidity was 50% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.
Ventilation				Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.
Ventilation				Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
	Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.
	Ventilation	If you have mechanical ventilation, confirm that air is flowing from the room into the air return grille(s).	Return air grill is functioning properly.	No corrective action recommended at this time.
148A		The main problem is that the students add to the odor in the classroom.		
	67	52%	906	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	General Classroom Information		Room is a mess. Moldy items.	Dispose of moldy items.
150				
	71	58%	1010	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	Roof leak repaired. Ceiling tiles are damaged.	Install new ceiling tiles.
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Thermal Comfort	Humidity level.	The humidity was 58% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.
	Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.
151				
	72.1	66%	1210	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
152	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	Appears to be a roof leak.	Maintenance to inspect for roof leak and repair as appropriate and replace ceiling tiles.
	General Classroom Information		Humidity slightly elevated.	Maintenance needs to inspect HVAC for proper operation.
	Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.
		The ceiling tiles in my classroom have had black mildew on them. They have been changed but the room always smells very musty from mildew. I have frequent headaches and my students complain of headaches as well.		
		74.3	65%	1030
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
153	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	Moisture in light diffuser covers.	Maintenance to inspect and repair as appropriate.
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Thermal Comfort	Humidity level.	Humidity slightly elevated.	Maintenance needs to inspect HVAC for proper operation.
	Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.
	Ventilation	Check for unexplained odors.	Air freshener is plugged in.	Remove air freshener.
		72.1	60%	920
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	Stained ceiling tiles.	Maintenance to inspect for roof leak and repair as appropriate and replace ceiling tiles.
	Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
154	73.5 <i>Temp</i>	65% <i>RH</i>	910 <i>Co2</i>	
	General Classroom Information		Humidity slightly elevated.	Maintenance needs to inspect HVAC for proper operation.
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment. Floors dirty.	Clean and sanitize flooring.
157	69.9 <i>Temp</i>	62% <i>RH</i>	520 <i>Co2</i>	
	Drain Traps in the Classroom	Drain traps, if present, can become a problem when the water in the drain trap evaporates due to infrequent use, allowing sewer gases to enter the room.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.
159	72 <i>Temp</i>	58% <i>RH</i>	770 <i>Co2</i>	
	General Cleanliness	Check for pests.	Teacher reported roaches.	Maintenance needs to establish work order to inspect room for pests and implement appropriate corrective action.
	General Cleanliness	Clean spills promptly.	Floors need cleaning.	Clean and sanitize flooring.
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
Thermal Comfort	Humidity level.	The humidity was 58% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.
Ventilation	If you have mechanical ventilation, confirm that air is flowing from the room into the air return grille(s).	Return air grill is functioning properly.	No corrective action recommended at this time.
Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.
Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.
Ventilation	Check for unexplained odors.	Natural gas odor.	Maintenance to inspect and repair as appropriate.

I think there are rats in the air vents. I know I have roaches in my drawers around the perimeter of the room.

160

73.9	54%	1200
<i>Temp</i>	<i>RH</i>	<i>Co2</i>

Animals in the Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.
Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Check for pests.	Teacher reported an ant problem.	Maintenance needs to establish work order to inspect room for pests and implement appropriate corrective action.
Locker Room	Verify that showers and other locker room areas are cleaned regularly and properly.	There are no showers.	No corrective action recommended at this time.
Thermal Comfort	Humidity level.	The humidity was 54% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.
Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.
Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.

There is a mildew problem that is causing students and teachers taking medications that they wouldn't be taking if the problem was solved.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
--	-----------------	---------------	----------------------------	--------------------------------------

167

75	49%	1740
<i>Temp</i>	<i>RH</i>	<i>Co2</i>

Animals in the Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.
Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Thermal Comfort	Humidity level.	The humidity was 49% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.
Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment. Co2 slightly elevated.	Maintenance to inspect and repair as appropriate to lower Co2 level.
Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.
Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.
Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.

The air quality is poor. My fellow employees and I suffer from some serious ailments and we believe that it is because of the poor air quality. I think we should be able to have air fresheners in our rooms, because the students smell something foul. My room is by the bathroom and I can smell the horrific odor that permeates from that room.

168

73.9	68%	1120
<i>Temp</i>	<i>RH</i>	<i>Co2</i>

Animals in the Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.
Drain Traps in the Classroom	Drain traps, if present, can become a problem when the water in the drain trap evaporates due to infrequent use, allowing sewer gases to enter the room.	No drain traps in classroom.	No corrective action recommended at this time.
Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Clean spills promptly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Local Exhaust Fans	General items.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
Thermal Comfort	Humidity level.	Humidity slightly elevated.	Maintenance needs to inspect HVAC for proper operation.
Ventilation	If you have mechanical ventilation, confirm that air is flowing from the room into the air return grille(s).	Return air grill is functioning properly.	No corrective action recommended at this time.
Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.
Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.

The room(s) are often humid and you can feel a "wetness" in the air. The temperature is not consistent; one day it might be warm, the next very cold. There are occasional bad smells. Not familiar with what they are; sometimes can smell moldy.

168A

73.9	68%	1120
<i>Temp</i>	<i>RH</i>	<i>Co2</i>

Animals in the Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.
Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment. Teacher reported is a problem during summer months.	No corrective action recommended at this time.
General Classroom Information		Teacher sealed door.	No corrective action recommended at this time.
General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
Industrial and Vocational Education Supplies	Minimize exposure to hazardous materials.	Not applicable.	No corrective action recommended at this time.
Local Exhaust Fans	Confirm that fume hoods and local exhaust fans are used whenever activities that generate pollutants take place.	Not applicable.	No corrective action recommended at this time.
Science Supplies	Minimize exposure to hazardous materials.	Not applicable.	No corrective action recommended at this time.
Science Supplies	Follow good safety, handling, and storage practices.	Not applicable.	No corrective action recommended at this time.
Science Supplies	Learn about your supplies. Read labels and identify precautions regarding fumes ventilation. Request information and Material Safety Data Sheets (MSDS) from supplies and manufacturers.	Not applicable.	No corrective action recommended at this time.
Thermal Comfort	Humidity level.	Humidity slightly elevated.	Maintenance needs to inspect HVAC for proper operation.
Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment. Teacher reported sometimes too cold.	Maintenance needs to inspect HVAC for proper operation.
Ventilation	If you have mechanical ventilation, confirm that air is flowing from the room into the air return grille(s).	Return air grill is functioning properly.	No corrective action recommended at this time.
Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.
Ventilation	Determine how your classroom is ventilated.	Teacher cannot open window.	Maintenance to inspect and repair as appropriate.
<p>The window in the front door of the classroom has not been sealed. This is the case for all of the external classrooms. The windows in my room are covered with condensation in the AM (on the inside). I have had to remove many class projects and supplies due to mold growth. I have been sick more this year than any time before, and I am sure that it is related to the air quality in my room.</p>			

169

72.5	61%	1660
<i>Temp</i>	<i>RH</i>	<i>Co2</i>

Animals in the Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.
Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
Thermal Comfort	Humidity level.	Humidity slightly elevated.	Maintenance needs to inspect HVAC for proper operation.
Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.
Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.
Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Teacher advised room smells musty.	Custodial staff should clean and sanitize the air supply and return registers in this classroom.

For three years I have been getting sinus infections due to the mold spores coming out of my air vents. I have had to see an allergist, been placed on several medications, I've had to have a CAT scan of my sinuses and I now have to take an allergy pill everyday. I receive allergy shots on a weekly basis and I have to use a nasal spray every morning before I come to work. All of my illnesses are recorded at my allergist. He also recommended that I have a HEPA filter in my classroom which I brought in myself. I believe that the air we are breathing ni is making us sick.

170

71.5	57%	1320
<i>Temp</i>	<i>RH</i>	<i>Co2</i>

General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
Thermal Comfort	Humidity level.	The humidity was 57% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.
Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.

171

69	58%	940
<i>Temp</i>	<i>RH</i>	<i>Co2</i>

Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
-------------------------------	----------------------------------------------------------	--------------------------------------------------------	------------------------------------------------

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
180			
	<div style="display: flex; justify-content: space-around;"> <div style="border: 1px solid black; padding: 2px;">72.5</div> <div style="border: 1px solid black; padding: 2px;">54%</div> <div style="border: 1px solid black; padding: 2px;">530</div> </div> <p style="text-align: center;"><i>Temp RH Co2</i></p>		
General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.
180A			
	<div style="display: flex; justify-content: space-around;"> <div style="border: 1px solid black; padding: 2px;">75</div> <div style="border: 1px solid black; padding: 2px;">78%</div> <div style="border: 1px solid black; padding: 2px;">420</div> </div> <p style="text-align: center;"><i>Temp RH Co2</i></p>		
Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	Window does not close.	Maintenance to inspect and repair as appropriate.
General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
Thermal Comfort	Humidity level.	Humidity is elevated.	Maintenance needs to inspect HVAC for proper operation.
Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.
191			
	<div style="display: flex; justify-content: space-around;"> <div style="border: 1px solid black; padding: 2px;">75.9</div> <div style="border: 1px solid black; padding: 2px;">59%</div> <div style="border: 1px solid black; padding: 2px;">1470</div> </div> <p style="text-align: center;"><i>Temp RH Co2</i></p>		
Animals in the Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
	Local Exhaust Fans	Confirm that fume hoods and local exhaust fans are used whenever activities that generate pollutants take place.	There are no fume hoods or local exhaust fans in classroom.	No corrective action recommended at this time.
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
	Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.
192				
	73.9	49%	820	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Clean spills promptly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
425				
	71.2	52%	790	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
426				
	70	56%	1010	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Check for pests.	Teacher reported pests.	Maintenance needs to establish work order to inspect room for pests and implement appropriate corrective action.
General Cleanliness	Confirm that the classroom is cleaned properly	Dust accumulation was observed on environmental surfaces.	Custodial staff should thoroughly clean all environmental surfaces within classroom.
Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
Thermal Comfort	Humidity level.	The humidity was 56% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.
Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.

429

71	56%	910
<i>Temp</i>	<i>RH</i>	<i>Co2</i>

General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment. Flooring dirty.	Clean and sanitize flooring.
Thermal Comfort	General items to watch for.	Teacher reported the room is generally too cold. Temperature was within recommended range.	Maintenance needs to inspect HVAC for proper operation.
Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.

434

Floors need thorough cleaning from dirt that is brought in on students shoes. The room temperature is extremely cold with to way to adjust it. Mosquitos and ants are in the room.		
70.1	56%	720
<i>Temp</i>	<i>RH</i>	<i>Co2</i>

General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
---------------------	------------------	--------------------------------------------------------	------------------------------------------------

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
436	General Cleanliness	Clean spills promptly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment. Teacher advised not happy with cleaning.	Custodial staff should thoroughly clean all environmental surfaces within classroom.
	Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.
	69.5	57%	680	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
438	Animals in the Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.
	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
	General Cleanliness	Clean spills promptly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
	69	55%	690	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment. Floors are dirty.	Clean and sanitize flooring.
	The floors in room 438 always look dirty.			

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
442	71.6 <i>Temp</i>	54% <i>RH</i>	1010 <i>Co2</i>	
	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	Ceiling tiles are water damaged.	Maintenance to inspect for roof leak and repair as appropriate and replace ceiling tiles.
443	71.5 <i>Temp</i>	54% <i>RH</i>	810 <i>Co2</i>	
	Drain Traps in the Classroom	Drain traps, if present, can become a problem when the water in the drain trap evaporates due to infrequent use, allowing sewer gases to enter the room.	Only during summer months.	Custodial staff to fill traps weekly.
	General Activities	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment. Floors are dirty.	Clean and sanitize flooring.
	General Cleanliness	Clean spills promptly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
450	74.4 <i>Temp</i>	48% <i>RH</i>	590 <i>Co2</i>	
	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Confirm that the classroom is cleaned properly	Dust accumulation was observed on environmental surfaces.	Custodial staff should thoroughly clean all environmental surfaces within classroom.
	Thermal Comfort	Humidity level.	The humidity was 48% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
452	73.5 <i>Temp</i>	50% <i>RH</i>	520 <i>Co2</i>	
	Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Check for pests.	Teacher reported ants.	Maintenance needs to establish work order to inspect room for pests and implement appropriate corrective action.
	General Cleanliness	Confirm that the classroom is cleaned properly	Teacher advised that room is not cleaned properly.	Custodial staff should thoroughly clean all environmental surfaces within classroom.
	Local Exhaust Fans	Confirm that fume hoods and local exhaust fans function properly.	There are no fume hoods or local exhaust fans in classroom.	No corrective action recommended at this time.
	Local Exhaust Fans	Confirm that fume hoods and local exhaust fans are used whenever activities that generate pollutants take place.	There are no fume hoods or local exhaust fans in classroom.	No corrective action recommended at this time.
	Local Exhaust Fans	General items.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Thermal Comfort	Humidity level.	The humidity was 50% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.
	Thermal Comfort	General items to watch for.	Teacher reported the room is generally too warm. Temperature was within recommended range.	Maintenance needs to inspect HVAC for proper operation.
	Ventilation	If you have mechanical ventilation, confirm that air is flowing from the room into the air return grille(s).	Return air grill is functioning properly.	No corrective action recommended at this time.
	Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.
	Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.
	Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.
Room needs a thorough cleaning. The room is extremely dirty.				

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
453	73.2 <i>Temp</i>	52% <i>RH</i>	370 <i>Co2</i>	
	Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	Ceiling tiles are water damaged.	Maintenance to inspect for leak and repair as appropriate and replace ceiling tiles.
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
457	72.7 <i>Temp</i>	53% <i>RH</i>	380 <i>Co2</i>	
	General Cleanliness	Check for pests.	Pest control has taken care of problem.	No corrective action recommended at this time.
	General Cleanliness	Confirm that the classroom is cleaned properly	Dust accumulation was observed on environmental surfaces.	Custodial staff should thoroughly clean all environmental surfaces within classroom.
	General Cleanliness	Clean spills promptly.	Carpeting is stained.	Clean and sanitize carpeting.
	Locker Room	Verify that showers and other locker room areas are cleaned regularly and properly.	Not applicable.	No corrective action recommended at this time.
	Locker Room	Maintain cleanliness and reduce excess moisture in the locker room.	Not applicable.	No corrective action recommended at this time.
	Thermal Comfort	Humidity level.	The humidity was 53% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.
	Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.
Flea issue in classroom, ant problem, egg stain on window, consistent clean by custodial staff, spot mopping when necessary.				
464	72.5 <i>Temp</i>	51% <i>RH</i>	350 <i>Co2</i>	

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
Animals in the Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.
General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
General Cleanliness	Clean spills promptly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Local Exhaust Fans	Confirm that fume hoods and local exhaust fans function properly.	There are no fume hoods or local exhaust fans in classroom.	No corrective action recommended at this time.
Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.
Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.
Maintenance personnel needs to be consistent and more thorough in cleaning classrooms and teacher facilities.			
914	67 <i>Temp</i>	51% <i>RH</i>	600 <i>Co2</i>
General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Thermal Comfort	General items to watch for.	Teacher reported the room is generally too cold.	Maintenance needs to inspect HVAC for proper operation.
Room is too cold every day.			
914E	69.6 <i>Temp</i>	49% <i>RH</i>	600 <i>Co2</i>
Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Clean spills promptly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Confirm that the classroom is cleaned properly	Dust accumulation was observed on environmental surfaces.	Custodial staff should thoroughly clean all environmental surfaces within classroom.

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
Local Exhaust Fans	General items.	Not applicable.	No corrective action recommended at this time.
Local Exhaust Fans	Confirm that fume hoods and local exhaust fans function properly.	There are no fume hoods or local exhaust fans in classroom.	No corrective action recommended at this time.
Local Exhaust Fans	Confirm that fume hoods and local exhaust fans are used whenever activities that generate pollutants take place.	There are no fume hoods or local exhaust fans in classroom.	No corrective action recommended at this time.
Thermal Comfort	Humidity level.	The humidity was 49% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.
Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.
Ventilation	Determine how your classroom is ventilated.	Dust and debris was observed on the air supply and return registers at the time of the assessment.	Custodial staff should clean and sanitize the air supply and return registers in this classroom.

Room is never cleaned properly. Chalkboards and trays are never cleaned by custodian, nor is room ever dusted.

917A/B

70.1	50%	650
<i>Temp</i>	<i>RH</i>	<i>Co2</i>

Animals in the Classroom	General items to watch for.	No animals in the classroom.	No corrective action recommended at this time.
Drain Traps in the Classroom	Drain traps, if present, can become a problem when the water in the drain trap evaporates due to infrequent use, allowing sewer gases to enter the room.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Clean spills promptly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Confirm that the classroom is cleaned properly	Dust accumulation was observed on environmental surfaces.	Custodial staff should thoroughly clean all environmental surfaces within classroom.
Local Exhaust Fans	General items.	Not applicable.	No corrective action recommended at this time.

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
Local Exhaust Fans	Confirm that fume hoods and local exhaust fans are used whenever activities that generate pollutants take place.	There are no fume hoods or local exhaust fans in classroom.	No corrective action recommended at this time.
Local Exhaust Fans	Confirm that fume hoods and local exhaust fans function properly.	There are no fume hoods or local exhaust fans in classroom.	No corrective action recommended at this time.
Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
Thermal Comfort	Humidity level.	The humidity was 50% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.
Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.
Ventilation	If you have mechanical ventilation, confirm that air is flowing from the room into the air return grille(s).	Return air grill is functioning properly.	No corrective action recommended at this time.
Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.
Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.
920	71.7 <i>Temp</i>	69% <i>RH</i>	830 <i>Co2</i>
Health and Hygiene Education	Obtain Indoor Air Quality: An introduction for health professionals.		Site based administration will provide information to site based staff.
Health Officer's Office	Ensure that the ventilation system is properly operating.	Humidity slightly elevated.	Maintenance needs to inspect HVAC for proper operation.
The room does not have any windows and the doors open to an enclosed small hallway. The doors are closed at all times. The air is very stale.			
925	76.6 <i>Temp</i>	45% <i>RH</i>	870 <i>Co2</i>
Animals in the Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
Animals in the Classroom	General items to watch for.	No animals in the classroom.	No corrective action recommended at this time.
Art Supplies	Minimize exposure to hazardous materials.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Art Supplies	Follow good safety, handling, and storage practices.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Art Supplies	Learn about your supplies.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Drain Traps in the Classroom	Drain traps, if present, can become a problem when the water in the drain trap evaporates due to infrequent use, allowing sewer gases to enter the room.	Not applicable.	No corrective action recommended at this time.
Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
General Cleanliness	Clean spills promptly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Local Exhaust Fans	Confirm that fume hoods and local exhaust fans are used whenever activities that generate pollutants take place.	There are no fume hoods or local exhaust fans in classroom.	No corrective action recommended at this time.
Local Exhaust Fans	Confirm that fume hoods and local exhaust fans function properly.	There are no fume hoods or local exhaust fans in classroom.	No corrective action recommended at this time.
Local Exhaust Fans	General items.	Not applicable.	No corrective action recommended at this time.
Locker Room	Verify that showers and other locker room areas are cleaned regularly and properly.	Not applicable.	No corrective action recommended at this time.
Locker Room	Maintain cleanliness and reduce excess moisture in the locker room.	Not applicable.	No corrective action recommended at this time.
Thermal Comfort	Humidity level.	The humidity was 45% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.
Thermal Comfort	General items to watch for.	Teacher reported the room is generally too warm. Temperature was within recommended range. But there is no air circulation.	Maintenance needs to inspect HVAC for proper operation.
Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
Ventilation	If you have mechanical ventilation, confirm that air is flowing from the room into the air return grille(s).	No air circulation.	See other item.
Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	No air circulation.	See other item.
926	72.2	46%	710
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>
Animals in the Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.
Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
General Cleanliness	Clean spills promptly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Health and Hygiene Education	Obtain Indoor Air Quality: An introduction for health professionals.		Contact EPA website www.epa.gov/iaq
Health and Hygiene Education	Inform students and staff about the importance of good hygiene in preventing the spread of airborne contagious diseases.		Site based administration will provide information to site based staff.
Health and Hygiene Education	Provide information about IAQ and health.		Site based administration will provide information to site based staff.
Health Officer's Office	Ensure that the ventilation system is properly operating.	Ventilation is working properly.	No corrective action recommended at this time.
Local Exhaust Fans	Confirm that fume hoods and local exhaust fans are used whenever activities that generate pollutants take place.	There are no fume hoods or local exhaust fans in classroom.	No corrective action recommended at this time.
Locker Room	Maintain cleanliness and reduce excess moisture in the locker room.	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
Locker Room	Verify that showers and other locker room areas are cleaned regularly and properly.	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
Thermal Comfort	Humidity level.	The humidity was 46% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.
Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.
Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.
Ventilation	If you have mechanical ventilation, confirm that air is flowing from the room into the air return grille(s).	Return air grill is functioning properly.	No corrective action recommended at this time.
Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.

929

	72.3	49%	540
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>

General Classroom Information		Door was found left open by the teachers.	Keep door closed.
General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
General Cleanliness	Clean spills promptly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.

P-01

	72.3	48%	540
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>

General Classroom Information		Dust accumulation was observed on environmental surfaces.	Custodial staff should thoroughly clean all environmental surfaces within classroom.
-------------------------------	--	-----------------------------------------------------------	--------------------------------------------------------------------------------------

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>		
P-02	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.	
		A/C vents need to be replaced.			
		72 <i>Temp</i>	49% <i>RH</i>	540 <i>Co2</i>	
P-03	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.	
	General Cleanliness	Confirm that the classroom is cleaned properly	Dust accumulation was observed on environmental surfaces.	Custodial staff should thoroughly clean all environmental surfaces within classroom.	
		72 <i>Temp</i>	38% <i>RH</i>	1810 <i>Co2</i>	
P-04	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.	
	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.	
	Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.	
	Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.	
	Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.	
		75 <i>Temp</i>	50% <i>RH</i>	1150 <i>Co2</i>	
Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.	No corrective action recommended at this time.	

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
-----------------	---------------	----------------------------	--------------------------------------

P-05

General Cleanliness

Confirm that the classroom is cleaned properly

General cleanliness appeared adequate on date of assessment.

No corrective action recommended at this time.

74

75%

1410

Temp

RH

Co2

General Classroom Information

Humidity slightly elevated.

Maintenance needs to inspect HVAC for proper operation.

Health and Hygiene Education

Provide information about IAQ and health.

Site based administration will provide information to site based staff.

Health and Hygiene Education

Inform students and staff about the importance of good hygiene in preventing the spread of airborne contagious diseases.

Site based administration will provide information to site based staff.

Health and Hygiene Education

Obtain Indoor Air Quality: An introduction for health professionals.

Contact EPA website www.epa.gov/iaq

Health Officer's Office

Ensure that the ventilation system is properly operating.

Ventilation is working properly.

No corrective action recommended at this time.

Maintain Student Health Records

Recognize indicators that health problems may be IAQ-related.

Site based administration will provide information to site based staff.

Maintain Student Health Records

Track health-related complaints by students and staff.

Site based administration will provide information to site based staff.

Maintain Student Health Records

Include information about sensitivities to IAQ problems in student health records.

Site based administration will provide information to site based staff.

I've seen an enormous sized rat running from Portable 1 to Portable 5!!!!!!!!!!!!!!

P-06

74.2

46%

1460

Temp

RH

Co2

General Classroom Information

Dust and debris was observed on the air supply and return registers at the time of the assessment.

Custodial staff should clean and sanitize the air supply and return registers in this classroom.

Health and Hygiene Education

Obtain Indoor Air Quality: An introduction for health professionals.

Contact EPA website www.epa.gov/iaq

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
P-08	73.7 <i>Temp</i>	45% <i>RH</i>	620 <i>Co2</i>	
	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
P-09	75.5 <i>Temp</i>	50% <i>RH</i>	1070 <i>Co2</i>	
	Animals in the Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.
	Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Check for pests.	Teacher reported pests.	Maintenance needs to establish work order to inspect room for pests and implement appropriate corrective action.
	General Cleanliness	Confirm that the classroom is cleaned properly	Dust accumulation was observed on environmental surfaces.	Custodial staff should thoroughly clean all environmental surfaces within classroom.
	Ventilation	Determine how your classroom is ventilated.	Window will not shut.	Maintenance to inspect and repair as appropriate.
P-10	76.6 <i>Temp</i>	45% <i>RH</i>	1450 <i>Co2</i>	
	General Cleanliness	Confirm that the classroom is cleaned properly	Dust and dirt accumulation was observed on environmental surfaces.	Custodial staff should thoroughly clean all environmental surfaces within classroom.
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
P-12	77 <i>Temp</i>	44% <i>RH</i>	1140 <i>Co2</i>
Animals in the Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.
Animals in the Classroom	General items to watch for.	No animals in the classroom.	No corrective action recommended at this time.
Drain Traps in the Classroom	Drain traps, if present, can become a problem when the water in the drain trap evaporates due to infrequent use, allowing sewer gases to enter the room.	Not applicable.	No corrective action recommended at this time.
Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Clean spills promptly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Confirm that the classroom is cleaned properly	Dust accumulation was observed on environmental surfaces.	Custodial staff should thoroughly clean all environmental surfaces within classroom.
Local Exhaust Fans	Confirm that fume hoods and local exhaust fans function properly.	Not applicable.	No corrective action recommended at this time.
Local Exhaust Fans	Confirm that fume hoods and local exhaust fans are used whenever activities that generate pollutants take place.	Not applicable.	No corrective action recommended at this time.
Local Exhaust Fans	General items.	Not applicable.	No corrective action recommended at this time.
Thermal Comfort	Humidity level.	The humidity was 44% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.
Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.
Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.
Ventilation	If you have mechanical ventilation, confirm that air is flowing from the room into the air return grille(s).	Return air grill is functioning properly.	No corrective action recommended at this time.

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.