

Tools for Schools Phase II - Indoor Air Quality

Follow-up Action Plan for Site Based

Perry, Henry D. Middle

81.7 66.4 462

Principal: Mr. Steven Frazier



Walkthrough Date: 5/20/2005

Temp RH Co2
Outside Measurements

Room	Priority	Responsible	Response	Recommendation
120	2	Site Based	Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.
328	1	Site Based	Dust and dirt accumulation on floor.	Facilities serviceperson to strip and wax floor.
328	2	Site Based	Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
368	2	Site Based	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
368	2	Site Based	Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.