

Perry, Henry D. Middle

IAQ Walkthrough 5/20/2005

Outside Temp RH% CO2

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority
120	Temp <input type="text" value="75.8"/> RH% <input type="text" value="46.1"/> CO2 <input type="text" value="618"/>	Occupants: <input type="text"/>			
	THERMAL COMFORT Temperature in my classroom is generally comfortable (72F-76F)?	Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
328	Temp <input type="text" value="69.2"/> RH% <input type="text" value="61.5"/> CO2 <input type="text" value="879"/>	Occupants: <input type="text"/>			
	AIR CONDITIONING Room is free of smell of mold or mildew?	No odor detected at the time of assessment.	None	None	
	EXCESS MOISTURE IN CLASSROOMS Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	No leaks or signs of water intrusion identified.	None	None	
	Walkthrough	Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
		Dust and dirt accumulation on floor.	Facilities serviceperson to strip and wax floor.	Site Based	1
368	Temp <input type="text" value="75.4"/> RH% <input type="text" value="52.8"/> CO2 <input type="text" value="597"/>	Occupants: <input type="text"/>			
	AIR CONDITIONING Room is free of smell of mold or mildew?	No odor detected at the time of assessment.	None	None	
	EXCESS MOISTURE IN CLASSROOMS Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	No leaks or signs of water intrusion identified.	None	None	
	GENERAL CLEANLINESS				

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
368	Temp	75.4	RH%	52.8	CO2	597	Occupants:				
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based					2
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based					2
THERMAL COMFORT											
	Temperature in my classroom is generally comfortable (72F-76F)?			It is usually very cold.	Temperature was acceptable at the time of assessment.	None	None				
	Room is usually comfortable? (If no, please explain in the notes below.)			It is usually very cold.	Environmental parameters were within acceptable range at the time of assessment..	None	None				