

Pines Middle

1881

IAQ Walkthrough 5/9/2005

Outside Temp RH% CO2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
<i>101</i>	Temp	<input type="text" value="74.6"/>	RH% <input type="text" value="44.9"/>	CO2 <input type="text" value="617"/>	Occupants: <input type="text"/>		
	ANIMALS IN THE CLASSROOM						
	You are informed about the potential allergies of your students?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	EXCESS MOISTURE IN CLASSROOMS						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Stained ceiling tile in hallway by restroom 108.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
	LOCAL EXHAUST FANS						
	Bathroom exhaust fan is functioning properly?			Exhaust fan is functioning properly.	None		
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?			It gets very cold in Room 101 at times. Nothing can be done about it.	Environmental parameters were within acceptable range at the time of assessment..	None	
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)			It gets very cold in Room 101 at times. Nothing can be done about it.	Humidity was acceptable at the time of assessment.	None	
	Room is usually comfortable? (If no, please explain in the notes below.)			It gets very cold in Room 101 at times. Nothing can be done about it.	Environmental parameters were within acceptable range at the time of assessment..	None	
	Temperature in my classroom is generally comfortable (72F-76F)?			It gets very cold in Room 101 at times. Nothing can be done about it.	Temperature was acceptable at the time of assessment.		
<i>105</i>	Temp	<input type="text" value="72.9"/>	RH% <input type="text" value="49.3"/>	CO2 <input type="text" value="600"/>	Occupants: <input type="text"/>		
	GENERAL CLEANLINESS						
	Floor is cleaned on a regular basis?			Carpet was stained and soiled.	Facilities serviceperson should clean and sanitize carpet.	Site Based	2
	THERMAL COMFORT						
	Room is usually comfortable? (If no, please explain in the notes below.)			Too hot	Environmental parameters were within acceptable range at the time of assessment..	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
105	Temp	<input type="text" value="72.9"/>	RH% <input type="text" value="49.3"/>	CO2 <input type="text" value="600"/>	Occupants: <input type="text"/>		
	Temperature in my classroom is generally comfortable (72F-76F)?		Too hot	Temperature was acceptable at the time of assessment.		None	
109	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
	GENERAL CLEANLINESS						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			No dust observed on supply/return registers at the time of assessment.		None	
	Classroom is dusted/vacuumed thoroughly and regularly?			General cleanliness of the room at the time of assessment was acceptable.		None	
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.		None	
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?		Room is hot	No issues identified at the time of assessment.		None	
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		Room is hot	No issues identified at the time of assessment.		None	
	Room is usually comfortable? (If no, please explain in the notes below.)		Room is hot	No issues identified at the time of assessment.		None	
	Temperature in my classroom is generally comfortable (72F-76F)?		Room is hot	No issues identified at the time of assessment.		None	
115	Temp	<input type="text" value="72"/>	RH% <input type="text" value="51.2"/>	CO2 <input type="text" value="787"/>	Occupants: <input type="text"/>		
	AIR CONDITIONING						
	Room is free of smell of mold or mildew?			No odor detected at the time of assessment.		None	
	GENERAL CLEANLINESS						
	Floor is cleaned on a regular basis?			Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	THERMAL COMFORT						
	Room is usually comfortable? (If no, please explain in the notes below.)		Too cold	Environmental parameters were within acceptable range at the time of assessment..		None	
	Temperature in my classroom is generally comfortable (72F-76F)?		Too cold	Temperature was acceptable at the time of assessment.		None	
	Walkthrough						

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

115

Temp RH% CO2

Occupants:

Dust observed on supply/return registers at the time of assessment.

Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Site Based

2

Dust and debris inside HVAC duct.

Physical Plant operations to evaluate and clean HVAC ducts.

Physical Plant Operations

2

115B

Temp RH% CO2

Occupants:

AIR CONDITIONING

Room is free of smell of mold or mildew?

No odor detected at the time of assessment.

None

GENERAL CLEANLINESS

Classroom is dusted/vacuumed thoroughly and regularly?

There does not appear to be a dusting issue within this room.

None

Floor is cleaned on a regular basis?

Floor was clean at the time of assessment.

None

THERMAL COMFORT

Classroom is free of significant temperature shifts?

Too cold

Environmental parameters were within acceptable range at the time of assessment..

None

Room is usually comfortable? (If no, please explain in the notes below.)

Too cold

Environmental parameters were within acceptable range at the time of assessment..

None

Temperature in my classroom is generally comfortable (72F-76F)?

Too cold

Temperature was acceptable at the time of assessment.

None

Walkthrough

Dust and debris in HVAC ducts.

Physical Plant operations to evaluate and clean HVAC ducts.

Physical Plant Operations

2

Dust observed on supply/return registers at the time of assessment.

Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Site Based

2

115C

Temp RH% CO2

Occupants:

AIR CONDITIONING

Room is free of smell of mold or mildew?

No odor detected at the time of assessment.

None

GENERAL CLEANLINESS

Classroom is dusted/vacuumed thoroughly and regularly?

There does not appear to be a dusting issue within this room.

None

THERMAL COMFORT

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
115C	Temp	<input type="text" value="72.2"/>	RH%	<input type="text" value="50.7"/>	CO2	<input type="text" value="810"/>	Occupants:	<input type="text"/>
	Classroom is free of significant temperature shifts?	Too cold			Environmental parameters were within acceptable range at the time of assessment..	None		
	Room is usually comfortable? (If no, please explain in the notes below.)	Too cold			Environmental parameters were within acceptable range at the time of assessment..	None		
	Temperature in my classroom is generally comfortable (72F-76F)?	Too cold			Temperature was acceptable at the time of assessment.	None		
133	Temp	<input type="text" value="71.3"/>	RH%	<input type="text" value="51.8"/>	CO2	<input type="text" value="559"/>	Occupants:	<input type="text"/>
	EXCESS MOISTURE IN CLASSROOMS							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
	GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Rust on return register.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	2
	Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None		
	Room is free of pests?				No pests observed at the time of assessment.	None		
	THERMAL COMFORT							
	Classroom is free of significant temperature shifts?	Media Center is either very cold or warm.			Environmental parameters were within acceptable range at the time of assessment..	None		
	Room is usually comfortable? (If no, please explain in the notes below.)	Media Center is either very cold or warm.			Environmental parameters were within acceptable range at the time of assessment..	None		
Temperature in my classroom is generally comfortable (72F-76F)?	Media Center is either very cold or warm.			Temperature was acceptable at the time of assessment.	None			
133A	Temp	<input type="text" value="69.3"/>	RH%	<input type="text" value="55.4"/>	CO2	<input type="text" value="594"/>	Occupants:	<input type="text"/>
	GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Classrooms general appearance is clean and acceptable?				General cleanliness of the room at the time of assessment was acceptable.	None		
Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None			
THERMAL COMFORT								

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority			
133A	Temp	<input type="text" value="69.3"/>	RH%	<input type="text" value="55.4"/>	CO2	<input type="text" value="594"/>	Occupants:	<input type="text"/>		
	Classroom is free of significant temperature shifts?		Cold	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based				2
	Room is usually comfortable? (If no, please explain in the notes below.)		Cold	See other recommendation.						
	Temperature in my classroom is generally comfortable (72F-76F)?		Cold	Temperature was low at the time of assessment.						
133B	Temp	<input type="text" value="72.5"/>	RH%	<input type="text" value="50.1"/>	CO2	<input type="text" value="573"/>	Occupants:	<input type="text"/>		
	DRAIN TRAPS IN THE CLASSROOM									
	Water run in sinks at least once per week (about 2 cups of water).			It appears as though sink is utilized regularly. No sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.	None					
	EXCESS MOISTURE IN CLASSROOMS									
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations				1
	GENERAL CLEANLINESS									
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			No dust observed on supply/return registers at the time of assessment.	None					
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based				2
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None					
	THERMAL COMFORT									
	Classroom is free of significant temperature shifts?		cold	Environmental parameters were within acceptable range at the time of assessment..	None					
	Room is usually comfortable? (If no, please explain in the notes below.)		cold	Environmental parameters were within acceptable range at the time of assessment..	None					
	Temperature in my classroom is generally comfortable (72F-76F)?		cold	Temperature was acceptable at the time of assessment.	None					

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
133C	Temp	<input type="text" value="73.1"/>	RH% <input type="text" value="48"/>	CO2 <input type="text" value="607"/>	Occupants: <input type="text"/>		
AIR CONDITIONING							
Air flowing from air supply?				Air flowing without obstruction at the time of assessments.	None		
Air is flowing without obstruction?				Air flowing without obstruction at the time of assessments.	None		
LOCAL EXHAUST FANS							
My classroom has sufficient exhaust systems based on the activities/functionality of the room?				No issues identified at the time of assessment.	None		
133D	Temp	<input type="text" value="70.7"/>	RH% <input type="text" value="52.9"/>	CO2 <input type="text" value="611"/>	Occupants: <input type="text"/>		
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None		
Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None		
Room is free of pests?				No pests observed at the time of assessment.	None		
THERMAL COMFORT							
Classroom is free of significant temperature shifts?			Cold or too hot	Return and supply vents were blocked with paper at the time of the assessment.	Facilities serviceperson should remove paper and monitor this room for temperature.	Site Based	1
Room is usually comfortable? (If no, please explain in the notes below.)			Cold or too hot	See other recommendation.			
Temperature in my classroom is generally comfortable (72F-76F)?			Cold or too hot	See other recommendation.			
133E	Temp	<input type="text" value="70.2"/>	RH% <input type="text" value="53.1"/>	CO2 <input type="text" value="638"/>	Occupants: <input type="text"/>		
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None		
Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None		
THERMAL COMFORT							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority					
133E	Temp	70.2	RH%	53.1	CO2	638	Occupants:	<input type="text"/>				
	Classroom is free of significant temperature shifts?		too cold or too hot		Temperature was low at the time of assessment.		Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.		Site Based		2	
	Room is usually comfortable? (If no, please explain in the notes below.)		too cold or too hot		Temperature was low at the time of assessment.							
	Temperature in my classroom is generally comfortable (72F-76F)?		too cold or too hot		Temperature was low at the time of assessment.							
135	Temp	71.1	RH%	53.5	CO2	727	Occupants:	<input type="text"/>				
	AIR CONDITIONING											
	Room is free of smell of mold or mildew?						No odor detected at the time of assessment.		None			
	EXCESS MOISTURE IN CLASSROOMS											
	Indoor surfaces of exterior walls free of continuous condensation?						No exterior walls.		None			
	THERMAL COMFORT											
Classroom is free of significant temperature shifts?						No issues identified at the time of assessment.		None				
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)						Humidity was acceptable at the time of assessment.		None				
136	Temp	74.3	RH%	50.4	CO2	1147	Occupants:	<input type="text"/>				
	GENERAL CLEANLINESS											
Floor is cleaned on a regular basis?						Dust and dirt accumulation on floor.		Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.		Site Based	2	
Walkthrough												
						Dust and debris on ceiling tiles.		Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.		Site Based	2	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

137

Temp RH% CO2 Occupants:

AIR CONDITIONING

Air flowing from air supply?

Air flowing without obstruction at the time of assessments.

None

ANIMALS IN THE CLASSROOM

Activities and/or room conditions are modified to address student allergies?

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

EXCESS MOISTURE IN CLASSROOMS

Windows, windowsills and window frames free of continuous condensation?

No visible condensation at the time of assessment.

None

GENERAL CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

No dust observed on supply/return registers at the time of assessment.

None

Classroom is dusted/vacuumed thoroughly and regularly?

Slight dust accumulation was observed on environmental surfaces at the time of assessment.

Site based administration should address general cleanliness with facility serviceperson staff.

Site Based

2

THERMAL COMFORT

Classroom is free of significant temperature shifts?

Environmental parameters were within acceptable range at the time of assessment..

None

Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)

Humidity was acceptable at the time of assessment.

None

Room is usually comfortable? (If no, please explain in the notes below.)

Environmental parameters were within acceptable range at the time of assessment..

None

Temperature in my classroom is generally comfortable (72F-76F)?

Temperature was acceptable at the time of assessment.

None

138

Temp RH% CO2 Occupants:

AIR CONDITIONING

Air flowing from air supply?

Air flowing without obstruction at the time of assessments.

None

Air is flowing without obstruction?

Air flowing without obstruction at the time of assessments.

None

Room is free of smell of chemicals?

No odor detected at the time of assessment.

None

Room is free of smell of kitchen/food?

No odor detected at the time of assessment.

None

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
138	Temp	73.9	RH% 51.2	CO2 1130	Occupants:		
	Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None	
	Room is free of smell of vehicle exhaust?				No odor detected at the time of assessment.	None	
	GENERAL CLEANLINESS						
	Floor is cleaned on a regular basis?				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
	Walkthrough						
					Dust and debris on ceiling tiles.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
					Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations 1
140	Temp	74.2	RH% 51.2	CO2 1196	Occupants:		
	AIR CONDITIONING						
	Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None	
	EXCESS MOISTURE IN CLASSROOMS						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations 1
	Cold water pipes free of continuous condensation?				No issues identified at the time of assessment.	None	
	GENERAL CLEANLINESS						
	Floor is cleaned on a regular basis?				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
					Two moldy ceiling tiles were removed and not replaced; exposing open pipes etc in celing area. Room is very cold with a high level of humidity.		
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?				Environmental parameters were within acceptable range at the time of assessment..	None	
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)				Humidity was acceptable at the time of assessment.	None	
	Room is usually comfortable? (If no, please explain in the notes below.)				Environmental parameters were within acceptable range at the time of assessment..	None	
	Temperature in my classroom is generally comfortable (72F-76F)?				Temperature was acceptable at the time of assessment.	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
141	Temp	<input type="text" value="72.9"/>	RH% <input type="text" value="50.3"/>	CO2 <input type="text" value="1120"/>	Occupants: <input type="text"/>		
AIR CONDITIONING							
Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None		
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Moldy ceiling tiles have been removed and not replaced	Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
GENERAL CLEANLINESS							
Floor is cleaned on a regular basis?				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
THERMAL COMFORT							
Classroom is free of significant temperature shifts?				Environmental parameters were within acceptable range at the time of assessment..	None		
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)				Humidity was acceptable at the time of assessment.	None		
Room is usually comfortable? (If no, please explain in the notes below.)				Environmental parameters were within acceptable range at the time of assessment..	None		
Temperature in my classroom is generally comfortable (72F-76F)?				Temperature was acceptable at the time of assessment.	None		
141A	Temp	<input type="text"/>	RH% <input type="text"/>	CO2 <input type="text"/>	Occupants: <input type="text"/>		
Walkthrough							
				Boxes are blocking HVAC supply grills.	facilities serviceperson should remove boxes.	Site Based	2
				Dust and debris on ceiling tiles.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
160	Temp	<input type="text" value="71.6"/>	RH% <input type="text" value="50"/>	CO2 <input type="text" value="833"/>	Occupants: <input type="text"/>		
AIR CONDITIONING							
Air is flowing without obstruction?				Air flowing without obstruction at the time of assessments.	None		
Room is free of smell of mold or mildew?				Noticeable odor in building.	Physical Plant Operations to evaluate cause of odor.	Physical Plant Operations	1
EXCESS MOISTURE IN CLASSROOMS							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
160	Temp	71.6	RH% 50	CO2 833	Occupants:		
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			No issues identified at the time of assessment.	None		
	LOCAL EXHAUST FANS						
	Bathroom exhaust fan is functioning properly?	There is no bathroom in this room.		No bathroom. Identified in error.	None		
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?			Wind noise coming from A/C supply damper.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)			Humidity was acceptable at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)			Environmental parameters were within acceptable range at the time of assessment..	None		
	Temperature in my classroom is generally comfortable (72F-76F)?			Temperature was acceptable at the time of assessment.	None		
	Walkthrough						
				Room is cluttered - Boxes, papers and books.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts	Site Based	2
162	Temp	70.6	RH% 52.4	CO2 933	Occupants:		
	ANIMALS IN THE CLASSROOM						
	Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	EXCESS MOISTURE IN CLASSROOMS						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Excessive dust accumulation on ceiling tiles.	Facilities serviceperson to clean or replace ceiling tiles as appropriate.	Site Based	2
	Windows, windowsills and window frames free of continuous condensation?			No visible condensation at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

162

Temp RH% CO2 Occupants:

GENERAL CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	wall to wall carpet not vacuumed regularly, or cleaned often enough. A/C vents not clean	Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
Classroom is dusted/vacuumed thoroughly and regularly?	wall to wall carpet not vacuumed regularly, or cleaned often enough. A/C vents not clean	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Floor is cleaned on a regular basis?	wall to wall carpet not vacuumed regularly, or cleaned often enough. A/C vents not clean	Carpet was heavily stained.	Facilities serviceperson should clean and sanitize carpet.	Site Based	1

THERMAL COMFORT

Classroom is free of significant temperature shifts?	A/C controls are on the roof. Temp. is either 60 or 80+ degrees depending on if A/C is ON or OFF. (Not between 60 and 80) Sunny or cloudy days make it better or worse too.	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	A/C controls are on the roof. Temp. is either 60 or 80+ degrees depending on if A/C is ON or OFF. (Not between 60 and 80) Sunny or cloudy days make it better or worse too.	Humidity was acceptable at the time of assessment.	None		
Room is usually comfortable? (If no, please explain in the notes below.)	A/C controls are on the roof. Temp. is either 60 or 80+ degrees depending on if A/C is ON or OFF. (Not between 60 and 80) Sunny or cloudy days make it better or worse too.	Temperature was low at the time of assessment.			
Temperature in my classroom is generally comfortable (72F-76F)?	A/C controls are on the roof. Temp. is either 60 or 80+ degrees depending on if A/C is ON or OFF. (Not between 60 and 80) Sunny or cloudy days make it better or worse too.	Temperature was low at the time of assessment.			

164

Temp RH% CO2 Occupants:

ANIMALS IN THE CLASSROOM

Activities and/or room conditions are modified to address student allergies?			Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
--	--	--	--	------------	---

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
164	Temp	71.4	RH% 51.4	CO2 887	Occupants:			
	You are informed about the potential allergies of your students?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3	
	EXCESS MOISTURE IN CLASSROOMS							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Ceiling tiles stained and dusty.	Facilities serviceperson to replace or clean ceiling tiles as appropriate.	Site Based	2
	Windows, windowsills and window frames free of continuous condensation?				No visible condensation at the time of assessment.	None		
	GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		Floor cleaned recently, but not often. Air temp. is very cold or hot. A/C control is on the ROOF! Temp. varies by amount of sun or clouds and A/C being on or off. Often either 60 or 80 degrees, not between.		Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?		Floor cleaned recently, but not often. Air temp. is very cold or hot. A/C control is on the ROOF! Temp. varies by amount of sun or clouds and A/C being on or off. Often either 60 or 80 degrees, not between.		Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?		Floor cleaned recently, but not often. Air temp. is very cold or hot. A/C control is on the ROOF! Temp. varies by amount of sun or clouds and A/C being on or off. Often either 60 or 80 degrees, not between.		Carpet had minor stains.	Facilities serviceperson to thoroughly clean and sanitize carpet.	Site Based	2
	THERMAL COMFORT							
	Classroom is free of significant temperature shifts?		When A/C is on it is freezing, off-hot. Sunny/cloudy day makes it worse. Thermostat is on ROOF of building!		Occupant advised temperature changes daily.	Physical Plant Operations to evaluate HVAC system for proper operation.	Physical Plant Operations	2
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		When A/C is on it is freezing, off-hot. Sunny/cloudy day makes it worse. Thermostat is on ROOF of building!		Humidity was acceptable at the time of assessment.	None		
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)		When A/C is on it is freezing, off-hot. Sunny/cloudy day makes it worse. Thermostat is on ROOF of building!		No issues identified at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)		When A/C is on it is freezing, off-hot. Sunny/cloudy day makes it worse. Thermostat is on ROOF of building!		See other recommendation.			

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
164	Temp	71.4	RH% 51.4	CO2 887	Occupants:		
	Temperature in my classroom is generally comfortable (72F-76F)?		When A/C is on it is freezing, off-hot. Sunny/cloudy day makes it worse. Thermostat is on ROOF of building!	Temperature was acceptable at the time of assessment.		None	
167	Temp	65.8	RH% 58.2	CO2 878	Occupants:		
	AIR CONDITIONING						
	Room is free of smell of mold or mildew?			Musty odor in room.		Physical Plant Operations to evaluate cause of odor.	Physical Plant Operations 2
	EXCESS MOISTURE IN CLASSROOMS						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Signs of water intrusion. Stained ceiling tiles.		Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations 1
	GENERAL CLEANLINESS						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply register at the time of assessment.		Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
	Room is free of pests?			No pests observed at the time of assessment.		None	
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?			Temperature was low at the time of assessment.		Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based 2
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)			Humidity was acceptable at the time of assessment.		None	
	Room is usually comfortable? (If no, please explain in the notes below.)			Temperature was low at the time of assessment.			
	Temperature in my classroom is generally comfortable (72F-76F)?			Temperature was low at the time of assessment.			
	Walkthrough						
				Live plant in room.		facilities serviceperson should remove live plant.	Site Based 1
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.		Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based 1

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
168	Temp	65.3	RH% 63.4	CO2 859	Occupants:		
AIR CONDITIONING							
Room is free of smell of mold or mildew?				Musty odor in room.	Physical Plant Operations to evaluate cause of odor.	Physical Plant Operations	2
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
Windows, windowsills and window frames free of continuous condensation?				No visible condensation at the time of assessment.	None		
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
THERMAL COMFORT							
Classroom is free of significant temperature shifts?				Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)				Humidity was slightly elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	2
Room is free of the introduction of outdoor air? (Gaps in window/door frames.)				Windows and/or doors were open at the time of assessment. Open doors and windows allow humid untreated air into occupied environment.	Site based administration to encourage staff to keep doors and windows closed. Open doors and windows allow humid untreated air into occupied environment.	Site Based	1
Room is usually comfortable? (If no, please explain in the notes below.)				Temperature was low at the time of assessment.			
Temperature in my classroom is generally comfortable (72F-76F)?				Temperature was low at the time of assessment.			

180 Temp 71.8 RH% 50.9 CO2 991 Occupants:

AIR CONDITIONING

Air flowing from air supply?

Air flowing without obstruction at the time of assessments.

None

Air is flowing without obstruction?

Air flowing without obstruction at the time of assessments.

None

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

180

Temp RH% CO2

Occupants:

Room is free of smell of mold or mildew?

No odor detected at the time of assessment.

None

EXCESS MOISTURE IN CLASSROOMS

Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?

Signs of water intrusion. Stained ceiling tiles.

Physical Plant Operations to evaluate for leaks and repair as appropriate.

Physical Plant Operations

1

GENERAL CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

Dust observed on supply/return registers at the time of assessment.

Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Site Based

2

Food, if any, is stored in tightly sealed containers?

No issues identified at the time of assessment.

None

LOCAL EXHAUST FANS

Bathroom exhaust fan is functioning properly?

No bathroom. Identified in error.

None

THERMAL COMFORT

Classroom is free of significant temperature shifts?

Too Warm

Environmental parameters were within acceptable range at the time of assessment..

None

Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)

Too Warm

Humidity was acceptable at the time of assessment.

None

Room is free of the introduction of outdoor air? (Gaps in window/door frames.)

Too Warm

No windows in room.

None

Room is usually comfortable? (If no, please explain in the notes below.)

Too Warm

Environmental parameters were within acceptable range at the time of assessment..

None

Temperature in my classroom is generally comfortable (72F-76F)?

Too Warm

Temperature was acceptable at the time of assessment.

None

181

Temp RH% CO2

Occupants:

AIR CONDITIONING

Air flowing from air supply?

Air flowing without obstruction at the time of assessments.

None

Air is flowing without obstruction?

Air flowing without obstruction at the time of assessments.

None

EXCESS MOISTURE IN CLASSROOMS

Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?

Ceiling tiles show signs of dust impaction.

Facilities serviceperson to clean ceiling tiles as appropriate.

Site Based

2

Windows, windowsills and window frames free of continuous condensation?

No visible condensation at the time of assessment.

None

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

181

Temp RH% CO2 Occupants:

GENERAL CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

No dust observed on supply/return registers at the time of assessment. None

LOCAL EXHAUST FANS

Bathroom exhaust fan is functioning properly?

No bathroom. Identified in error. None

My classroom has sufficient exhaust systems based on the activities/functionality of the room?

No issues identified at the time of assessment. None

Other exhaust fans that may exist in the classroom are functioning properly?

No issues identified at the time of assessment. None

THERMAL COMFORT

Classroom is free of significant temperature shifts?

Very warm, little air flow.

Environmental parameters were within acceptable range at the time of assessment.. None

Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)

Very warm, little air flow.

Humidity was acceptable at the time of assessment. None

Room is free of the introduction of outdoor air? (Gaps in window/door frames.)

Very warm, little air flow.

No issues identified at the time of assessment. None

Room is usually comfortable? (If no, please explain in the notes below.)

Very warm, little air flow.

Environmental parameters were within acceptable range at the time of assessment.. None

Temperature in my classroom is generally comfortable (72F-76F)?

Very warm, little air flow.

Temperature was acceptable at the time of assessment. None

182

Temp RH% CO2 Occupants:

AIR CONDITIONING

Room is free of smell of chemicals?

Odor in room from shop next door (FISH 183). None

EXCESS MOISTURE IN CLASSROOMS

Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?

Signs of water intrusion. Stained ceiling tiles. Physical Plant Operations to evaluate for leaks and repair as appropriate. Physical Plant Operations

1

LOCAL EXHAUST FANS

Bathroom exhaust fan is functioning properly?

No bathroom. Identified in error. None

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
183	Temp	<input type="text" value="68.6"/>	RH%	<input type="text" value="56.5"/>	CO2	<input type="text" value="1232"/>	Occupants:	<input type="text"/>
AIR CONDITIONING								
Room is free of smell of chemicals?			Shop Class - odor in room and no exhaust fans in room.	Physical Plant Operations to evaluate cause of odor and install exhaust fan.	Physical Plant Operations	1		
Room is free of smell of mold or mildew?			No odor detected at the time of assessment.	None				
EXCESS MOISTURE IN CLASSROOMS								
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1		
LOCAL EXHAUST FANS								
Bathroom exhaust fan is functioning properly?			We need more exhaust when using paints, varnishes etc.	See other recommendation for exhaust fans.				
My classroom has sufficient exhaust systems based on the activities/functionality of the room?			We need more exhaust when using paints, varnishes etc.	See other recommendation for exhaust fans.				
Other exhaust fans that may exist in the classroom are functioning properly?			We need more exhaust when using paints, varnishes etc.	See other recommendation for exhaust fans.				
183F	Temp	<input type="text" value="73.4"/>	RH%	<input type="text" value="49"/>	CO2	<input type="text" value="1140"/>	Occupants:	<input type="text"/>
AIR CONDITIONING								
Room is free of smell of mold or mildew?			Odor in room from shop next door (FISH 183).	None				
EXCESS MOISTURE IN CLASSROOMS								
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1		
189	Temp	<input type="text" value="73.9"/>	RH%	<input type="text" value="49.6"/>	CO2	<input type="text" value="1186"/>	Occupants:	<input type="text"/>
AIR CONDITIONING								
Air flowing from air supply?			Air flowing without obstruction at the time of assessments.	None				
Air is flowing without obstruction?			Air flowing without obstruction at the time of assessments.	None				
Room is free of smell of chemicals?			No odor detected at the time of assessment.	None				
Room is free of smell of mold or mildew?			No odor detected at the time of assessment.	None				
DRAIN TRAPS IN THE CLASSROOM								
Water poured down floor drains once per week (approx. 1 quart of water).			No floor drain in room.	None				

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
189	Temp	73.9	RH% 49.6	CO2 1186	Occupants:		
	Water run in sinks at least once per week (about 2 cups of water).			It appears as though sink is utilized regularly. No sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.	None		
	EXCESS MOISTURE IN CLASSROOMS						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Ceiling tiles show signs of dust impaction.	Facilities serviceperson to clean or replace ceiling tiles as appropriate.	Site Based	2
	Windows, windowsills and window frames free of continuous condensation?			No visible condensation at the time of assessment.	None		
	GENERAL CLEANLINESS						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Classrooms general appearance is clean and acceptable?			Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Food, if any, is stored in tightly sealed containers?			No issues identified at the time of assessment.	None		
	Room is free of pests?			No pests observed at the time of assessment.	None		
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?			Environmental parameters were within acceptable range at the time of assessment..	None		
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)			Humidity was acceptable at the time of assessment.	None		
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)			No issues identified at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)			Environmental parameters were within acceptable range at the time of assessment..	None		
	Temperature in my classroom is generally comfortable (72F-76F)?			Temperature was acceptable at the time of assessment.	None		

189A

Temp 75.1 RH% 46.2 CO2 1086 Occupants:

AIR CONDITIONING

Air flowing from air supply?	Air flowing without obstruction at the time of assessments.	None
Air is flowing without obstruction?	Air flowing without obstruction at the time of assessments.	None

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
189A	Temp	75.1	RH% 46.2	CO2 1086	Occupants:		
	Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None	
	Windows/doors are operable and are kept closed?				No issues identified at the time of assessment.	None	
	EXCESS MOISTURE IN CLASSROOMS						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations 1
	GENERAL CLEANLINESS						
	Food, if any, is stored in tightly sealed containers?				No issues identified at the time of assessment.	None	
	LOCAL EXHAUST FANS						
	Bathroom exhaust fan is functioning properly?				No bathroom. Identified in error.	None	
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)				No issues identified at the time of assessment.	None	
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?				No issues identified at the time of assessment.	None	
	Other exhaust fans that may exist in the classroom are functioning properly?				No issues identified at the time of assessment.	None	
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?		Room is unbearably hot. Definite health hazard.		Environmental parameters were within acceptable range at the time of assessment..	None	
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		Room is unbearably hot. Definite health hazard.		Humidity was acceptable at the time of assessment.	None	
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)		Room is unbearably hot. Definite health hazard.		No issues identified at the time of assessment.	None	
	Room is usually comfortable? (If no, please explain in the notes below.)		Room is unbearably hot. Definite health hazard.		Environmental parameters were within acceptable range at the time of assessment..	None	
	Temperature in my classroom is generally comfortable (72F-76F)?		Room is unbearably hot. Definite health hazard.		Temperature was acceptable at the time of assessment.	None	
190	Temp	73.2	RH% 46.4	CO2 1054	Occupants:		
	EXCESS MOISTURE IN CLASSROOMS						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Signs of water intrusion. Stained ceiling tiles. Also ceiling tiles damaged and/or missing.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations 1

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
191	Temp	73.2	RH% 46.4	CO2 1054	Occupants:		
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			See recommendation for 190 (190 and 191 are one large room).				
522C	Temp	69.9	RH% 48.4	CO2 1895	Occupants:		
AIR CONDITIONING							
Air flowing from air supply?			Mold is present on the walls, and floor is full of mold		Air flowing without obstruction at the time of assessments.		None
Room is free of smell of mold or mildew?			Mold is present on the walls, and floor is full of mold		No odor detected at the time of assessment.		None
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?			none		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.		Site Based 3
You are informed about the potential allergies of your students?			none		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.		Site Based 3
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Roof has lot of condensation		Signs of water intrusion. Stained ceiling tiles.		Physical Plant Operations to evaluate for leaks and repair as appropriate. Physical Plant Operations 1
Indoor surfaces of exterior walls free of continuous condensation?			Roof has lot of condensation		No visible condensation at the time of assessment.		None
Windows, windowsills and window frames free of continuous condensation?			Roof has lot of condensation		No visible condensation at the time of assessment.		None
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?					Slight dust accumulation was observed on environmental surfaces at the time of assessment.		Site based administration should address general cleanliness with facility serviceperson staff. Site Based 2
Classrooms general appearance is clean and acceptable?					Dust on walls and floor has glue coming up from tiles.		Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. Site Based 2
LOCAL EXHAUST FANS							
My classroom has sufficient exhaust systems based on the activities/functionality of the room?					No issues identified at the time of assessment.		None

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
522C	Temp	<input type="text" value="69.9"/>	RH% <input type="text" value="48.4"/>	CO2 <input type="text" value="1895"/>	Occupants: <input type="text"/>			
THERMAL COMFORT								
	Classroom is free of significant temperature shifts?	During hot weather,it is very hot inside the classroom as air condition unit is very old.			Only one A/C unit was turned on.	Facilities serviceperson should ensure that both A/C units are on.	Site Based	2
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	During hot weather,it is very hot inside the classroom as air condition unit is very old.			Humidity was acceptable at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)	During hot weather,it is very hot inside the classroom as air condition unit is very old.			Environmental parameters were within acceptable range at the time of assessment..	None		
	Temperature in my classroom is generally comfortable (72F-76F)?	During hot weather,it is very hot inside the classroom as air condition unit is very old.			Temperature was low at the time of assessment. Only one A/C unit was turned on.	Physical Plant Operations to evaluate HVAC system for proper operation.	Physical Plant Operations	2
609	Temp	<input type="text" value="70.3"/>	RH% <input type="text" value="50.1"/>	CO2 <input type="text" value="1029"/>	Occupants: <input type="text"/>			
EXCESS MOISTURE IN CLASSROOMS								
	Windows, windowsills and window frames free of continuous condensation?				No visible condensation at the time of assessment.	None		
GENERAL CLEANLINESS								
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				No dust observed on supply/return registers at the time of assessment.	None		
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None		
	Room is free of pests?				No pests observed at the time of assessment.	None		
R23A	Temp	<input type="text" value="75.1"/>	RH% <input type="text" value="46.5"/>	CO2 <input type="text" value="801"/>	Occupants: <input type="text"/>			
AIR CONDITIONING								
	Air is flowing without obstruction?				Air flowing without obstruction at the time of assessments.	None		
	Room is free of smell of mold or mildew?				Odor detected in room.	Physical Plant Operations to evaluate cause of odor.	Physical Plant Operations	2
ANIMALS IN THE CLASSROOM								

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority			
R23A	Temp	<input type="text" value="75.1"/>	RH%	<input type="text" value="46.5"/>	CO2	<input type="text" value="801"/>	Occupants:	<input type="text"/>		
Activities and/or room conditions are modified to address student allergies?							Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3	
You are informed about the potential allergies of your students?							Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3	
EXCESS MOISTURE IN CLASSROOMS										
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Ceiling tiles are disgusting. They are discolored severely. Some have holes in them exposing fiberglass. There are obvious signs of leaks throughout the room.	Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations			1	
GENERAL CLEANLINESS										
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Floors are very dirty. The dirt is very visible first thing in the morning.	Heavy dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based			1	
Classrooms general appearance is clean and acceptable?			Floors are very dirty. The dirt is very visible first thing in the morning.	General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based			2	
Floor is cleaned on a regular basis?			Floors are very dirty. The dirt is very visible first thing in the morning.	Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based			2	
Room is free of pests?			Floors are very dirty. The dirt is very visible first thing in the morning.	No pests observed at the time of assessment.						
R23B	Temp	<input type="text" value="76.8"/>	RH%	<input type="text" value="47.6"/>	CO2	<input type="text" value="953"/>	Occupants:	<input type="text"/>		
AIR CONDITIONING										
Air is flowing without obstruction?							Air flowing without obstruction at the time of assessments.	None		
Room is free of smell of mold or mildew?							Odor detected.	Physical Plant Operations to evaluate cause of odor.	Physical Plant Operations	2
ANIMALS IN THE CLASSROOM										
Activities and/or room conditions are modified to address student allergies?							Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

R23B

Temp RH% CO2

Occupants:

You are informed about the potential allergies of your students?

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

EXCESS MOISTURE IN CLASSROOMS

Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?

Signs of water intrusion. Stained ceiling tiles.

Physical Plant Operations to evaluate for leaks and repair as appropriate.

Physical Plant Operations

1

GENERAL CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

Heavy dust observed on supply/return registers at the time of assessment.

Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Site Based

2

Classroom is dusted/vacuumed thoroughly and regularly?

Slight dust accumulation was observed on environmental surfaces at the time of assessment.

Site based administration should address general cleanliness with facility serviceperson staff.

Site Based

2

Classrooms general appearance is clean and acceptable?

General cleanliness of the room at the time of assessment was not acceptable.

Site based administration should address general cleanliness with facility serviceperson staff.

Site Based

2

Floor is cleaned on a regular basis?

Heavy dust and dirt accumulation on floor.

Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Site Based

1

Room is free of pests?

No pests observed at the time of assessment.

None

THERMAL COMFORT

Classroom is free of significant temperature shifts?

Both A/C units were off at the time of assessment.

None

Room is usually comfortable? (If no, please explain in the notes below.)

Both A/C units were off at the time of assessment.

None

Temperature in my classroom is generally comfortable (72F-76F)?

Both A/C units were off at the time of assessment.

None

R23C

Temp RH% CO2

Occupants:

AIR CONDITIONING

Air is flowing without obstruction?

Air flowing without obstruction at the time of assessments.

None

Room is free of smell of mold or mildew?

Odor detected in room.

Physical Plant Operations to evaluate cause of odor.

Physical Plant Operations

2

ANIMALS IN THE CLASSROOM

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
R23C	Temp	72.9	RH% 47	CO2 1070	Occupants:		
	Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
	You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
EXCESS MOISTURE IN CLASSROOMS							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Signs of water intrusion. Stained ceiling tiles.		Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations 1
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Heavy dust observed on supply/return registers at the time of assessment.		Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 1
	Classroom is dusted/vacuumed thoroughly and regularly?			Excessive dust accumulation was observed on environmental surfaces at the time of assessment.		Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	Classrooms general appearance is clean and acceptable?			General cleanliness of the room at the time of assessment was not acceptable.		Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	Floor is cleaned on a regular basis?			Dust and dirt accumulation on floor.		Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
	Room is free of pests?			No pests observed at the time of assessment.		None	
R23D	Temp	72.6	RH% 53.1	CO2 642	Occupants:		
AIR CONDITIONING							
	Air is flowing without obstruction?			Air flowing without obstruction at the time of assessments.		None	
	Room is free of smell of mold or mildew?			Odor detected in room.		Physical Plant Operations to evaluate cause of odor.	Physical Plant Operations 2
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
<i>R23D</i>	Temp	72.6	RH% 53.1	CO2 642	Occupants: <input type="text"/>			
	You are informed about the potential allergies of your students?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3	
	EXCESS MOISTURE IN CLASSROOMS							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
	GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Classrooms general appearance is clean and acceptable?				General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2