

# Plantation Middle

## IAQ Walkthrough 5/24/2005

0551

Outside Temp  RH%  CO2

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority
050	Temp <input type="text" value="75.8"/> RH% <input type="text" value="52.2"/> CO2 <input type="text" value="2274"/>	Occupants: <input type="text" value="17"/>			
	<b>AIR CONDITIONING</b>				
	Room is free of smell of chemicals?	Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	1
	Room is free of smell of kitchen/food?	No odor detected from kitchen/food at the time of assessment.	None		
	Room is free of smell of mold or mildew?	No odor detected from mold and mildew at the time of assessment.	None		
	Room is free of smell of vehicle exhaust?	No odor detected from vehicle exhaust at the time of assessment.	None		
	<b>ANIMALS IN THE CLASSROOM</b>				
	Activities and/or room conditions are modified to address student allergies?		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	<b>DRAIN TRAPS IN THE CLASSROOM</b>				
	Water poured down floor drains once per week (approx. 1 quart of water).	No issues identified at the time of assessment.	None		
	Water run in sinks at least once per week (about 2 cups of water).	No issues identified at the time of assessment.	None		
	<b>EXCESS MOISTURE IN CLASSROOMS</b>				
	Indoor surfaces of exterior walls free of continuous condensation?	No visible condensation at the time of assessment.	None		
	Windows, windowsills and window frames free of continuous condensation?	No visible condensation at the time of assessment.	None		
	<b>GENERAL CLEANLINESS</b>				

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority		
050	Temp	75.8	RH% 52.2	CO2 2274	Occupants: 17				
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2	
	Walkthrough				CO2 level was elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower CO2 level.	Physical Plant Operations	1	
					A/C unit behind teacher's desk has doubled filters.	Facilities serviceperson to replace HVAC filters.	Site Based	2	
					Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2	
105	Temp	76.8	RH% 53.4	CO2 1745	Occupants: 19				
	<b>ANIMALS IN THE CLASSROOM</b>								
	Activities and/or room conditions are modified to address student allergies?				Need help determining if students have allergies.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3	
	You are informed about the potential allergies of your students?				Need help determining if students have allergies.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3	
	<b>GENERAL CLEANLINESS</b>								
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2	
	Room is free of the use of scented cleaners and air fresheners?				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	1	
	Trash is removed daily and trash bags are changed as appropriate?				No issues identified regarding trash removal practices.	None			
	<b>THERMAL COMFORT</b>								
	Classroom is free of significant temperature shifts?				Just recently, the room is either too hot or too cold.	Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
105	Temp	76.8	RH%	53.4	CO2	1745	Occupants:	19			
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		Just recently, the room is either too hot or too cold.	Humidity was acceptable at the time of assessment.	None						
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)		Just recently, the room is either too hot or too cold.	No issues identified at the time of assessment.	None						
	Room is usually comfortable? (If no, please explain in the notes below.)		Just recently, the room is either too hot or too cold.	Temperature was elevated at the time of assessment.							
	Temperature in my classroom is generally comfortable (72F-76F)?		Just recently, the room is either too hot or too cold.	Temperature was elevated at the time of assessment.							
	Walkthrough			CO2 level was elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower CO2 level.	Physical Plant Operations					1
106	Temp	75.2	RH%	51.5	CO2	1364	Occupants:	24			
	EXCESS MOISTURE IN CLASSROOMS										
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			No leaks or signs of water intrusion identified.	None						
	GENERAL CLEANLINESS										
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based					2
	Walkthrough										
				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based					2
				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based					2
107	Temp	71.2	RH%	50.5	CO2	904	Occupants:	22			
	AIR CONDITIONING										
	Room is free of smell of mold or mildew?			No odor detected at the time of assessment.	None						
	Windows/doors are operable and are kept closed?			No issues identified at the time of assessment.	None						
	ANIMALS IN THE CLASSROOM										

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
107	Temp	71.2	RH% 50.5	CO2 904	Occupants: 22			
	Activities and/or room conditions are modified to address student allergies?	Need help determining if students have allergies.			Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3	
	Classroom is free of animals and pets?	Need help determining if students have allergies.			No animals identified at the time of assessment.	None		
	You are informed about the potential allergies of your students?	Need help determining if students have allergies.			Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3	
<b>GENERAL CLEANLINESS</b>								
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
<b>THERMAL COMFORT</b>								
	Classroom is free of significant temperature shifts?				Environmental parameters were within acceptable range at the time of assessment..	None		
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)				Humidity was acceptable at the time of assessment.	None		
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)				No issues identified at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)				Environmental parameters were within acceptable range at the time of assessment..	None		
	Temperature in my classroom is generally comfortable (72F-76F)?				Temperature was acceptable at the time of assessment.	None		
<b>Walkthrough</b>								
					Carpet was stained and soiled.	Facilities serviceperson should clean and sanitize carpet.	Site Based	2
					Ceiling tiles broken, damaged or missing.	Facilities serviceperson to replace damaged ceiling tiles.	Site Based	2
					Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
108	Temp	73.8	RH% 51.3	CO2 1247	Occupants:			
<b>ANIMALS IN THE CLASSROOM</b>								
Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3	
You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3	
<b>GENERAL CLEANLINESS</b>								
Classroom is dusted/vacuumed thoroughly and regularly?			The only cleaning that is done is the emptying of garbage and sweeping of the floor.	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2	
Floor is cleaned on a regular basis?			The only cleaning that is done is the emptying of garbage and sweeping of the floor.	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2	
<b>Walkthrough</b>								
				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2	
				Dust observed on ceiling tiles at supply vents.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2	
109	Temp	74.1	RH% 52.6	CO2 1366	Occupants:			
<b>DRAIN TRAPS IN THE CLASSROOM</b>								
Water poured down floor drains once per week (approx. 1 quart of water).					No issues identified at the time of assessment.	None		
Water run in sinks at least once per week (about 2 cups of water).					No issues identified at the time of assessment.	None		
<b>EXCESS MOISTURE IN CLASSROOMS</b>								
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?					Dust and debris on ceiling tiles.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner or replace ceiling tiles for dust impaction.	Site Based	2
<b>Walkthrough</b>								

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
109	Temp	74.1	RH% 52.6	CO2 1366	Occupants: <input type="text"/>		
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	1
				Fountain at sink requires repair.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	2
110	Temp	74.9	RH% 51.6	CO2 1106	Occupants: <input type="text"/>		
<b>AIR CONDITIONING</b>							
	Room is free of smell of mold or mildew?		At times the room smells moldy.	No odor detected at the time of assessment.	None		
	Windows/doors are operable and are kept closed?		At times the room smells moldy.	No issues identified at the time of assessment.	None		
<b>ART SUPPLIES</b>							
	Exposure minimized for industrial supplies?		Need help determining impacts of industrial/vocational supplies	No issues identified at the time of assessment.	None		
<b>EXCESS MOISTURE IN CLASSROOMS</b>							
	Windows, windowsills and window frames free of continuous condensation?			No visible condensation at the time of assessment.	None		
<b>GENERAL CLEANLINESS</b>							
	Classroom is dusted/vacuumed thoroughly and regularly?		Survey is for room 110E - Not on FISH list. Had issues with ants but no longer a problem. , We got help for our ant problem.	There does not appear to be a dusting issue within this room.	None		
	Room is free of pests?		Survey is for room 110E - Not on FISH list. Had issues with ants but no longer a problem. , We got help for our ant problem.	No pests observed at the time of assessment.	None		
<b>THERMAL COMFORT</b>							
	Classroom is free of significant temperature shifts?		Building is extremely cold. Need help, room frequently uncomfortable.	Environmental parameters were within acceptable range at the time of assessment..	None		
	Room is usually comfortable? (If no, please explain in the notes below.)		Building is extremely cold. Need help, room frequently uncomfortable.	Environmental parameters were within acceptable range at the time of assessment..	None		
	Temperature in my classroom is generally comfortable (72F-76F)?		Building is extremely cold. Need help, room frequently uncomfortable.	Temperature was acceptable at the time of assessment.	None		
<b>Walkthrough</b>							
				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
110	Temp	74.9	RH% 51.6	CO2 1106	Occupants: <input type="text"/>		
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	1
111	Temp	72.7	RH% 48	CO2 1120	Occupants: <input type="text"/>		
	<b>EXCESS MOISTURE IN CLASSROOMS</b>						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Dust and debris on ceiling tiles at HVAC vents.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner or replace tiles for dust impaction.	Site Based	2
	<b>GENERAL CLEANLINESS</b>						
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	<b>THERMAL COMFORT</b>						
	Classroom is free of significant temperature shifts?		Either too hot or too cold. There is no happy medium.	Environmental parameters were within acceptable range at the time of assessment..	None		
	Room is usually comfortable? (If no, please explain in the notes below.)		Either too hot or too cold. There is no happy medium.	Environmental parameters were within acceptable range at the time of assessment..	None		
	Temperature in my classroom is generally comfortable (72F-76F)?		Either too hot or too cold. There is no happy medium.	Temperature was acceptable at the time of assessment.	None		
	<b>Walkthrough</b>						
				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
112	Temp	68.4	RH% 54.1	CO2 1025	Occupants: <input type="text"/>		
	<b>EXCESS MOISTURE IN CLASSROOMS</b>						
	Area around and under classroom sinks free of leaks?			No leaks or signs of water intrusion identified.	None		
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			No leaks or signs of water intrusion identified.	None		
	Classroom lavatories/water fountains free of leaks?			No leaks or signs of water intrusion identified.	None		
	<b>GENERAL CLEANLINESS</b>						

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

112

Temp  RH%  CO2

Occupants:

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

Computers and counters are dusty. Only the floor is cleaned. Air vents need cleaning.

Dust observed on supply/return registers at the time of assessment.

Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Site Based

2

Classroom is dusted/vacuumed thoroughly and regularly?

Computers and counters are dusty. Only the floor is cleaned. Air vents need cleaning.

Slight dust accumulation was observed on environmental surfaces at the time of assessment.

Site based administration should address general cleanliness with facility serviceperson staff.

Site Based

2

Classrooms general appearance is clean and acceptable?

Computers and counters are dusty. Only the floor is cleaned. Air vents need cleaning.

General cleanliness of the room at the time of assessment was not acceptable.

Site based administration should address general cleanliness with facility serviceperson staff.

Site Based

2

**LOCAL EXHAUST FANS**

Bathroom exhaust fan is functioning properly?

No bathroom. Identified in error.

None

My classroom has sufficient exhaust systems based on the activities/functionality of the room?

No exhaust fans in room. Identified in error.

None

Other exhaust fans that may exist in the classroom are functioning properly?

No exhaust fans in room. Identified in error.

None

**Walkthrough**

Dust and dirt accumulation on floor.

Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Site Based

2

Temperature was low at the time of assessment.

Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Site Based

2

113

Temp  RH%  CO2

Occupants:

**DRAIN TRAPS IN THE CLASSROOM**

Water poured down floor drains once per week (approx. 1 quart of water).

No issues identified at the time of assessment.

None

Water run in sinks at least once per week (about 2 cups of water).

No issues identified at the time of assessment.

None

**GENERAL CLEANLINESS**

Classroom is dusted/vacuumed thoroughly and regularly?

Corners of the classroom are always dusty.

Slight dust accumulation was observed on environmental surfaces at the time of assessment.

Site based administration should address general cleanliness with facility serviceperson staff.

Site Based

2

**Walkthrough**



FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
113	Temp	70.6	RH% 52.2	CO2 1053	Occupants: <input type="text"/>		
				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
				No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
116	Temp	72.3	RH% 50.4	CO2 1075	Occupants: <input type="text" value="26"/>		
<b>AIR CONDITIONING</b>							
	Room is free of smell of mold or mildew?		Musty smell	No odor detected at the time of assessment.	None		
<b>EXCESS MOISTURE IN CLASSROOMS</b>							
	Area around and under classroom sinks free of leaks?		Found leaks or signs of moisture.	Leak identified at eye wash station.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	1
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?		Found leaks or signs of moisture.	No leaks or signs of water intrusion identified.	None		
<b>GENERAL CLEANLINESS</b>							
	Classroom is dusted/vacuumed thoroughly and regularly?		Teacher dusts the room. Ants in room.	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Room is free of pests?		Teacher dusts the room. Ants in room.	No pests observed at the time of assessment.	None		
<b>LOCAL EXHAUST FANS</b>							
	Other exhaust fans that may exist in the classroom are functioning properly?		Fans are loud	No issues identified at the time of assessment.	None		
<b>THERMAL COMFORT</b>							
	Classroom is free of significant temperature shifts?		Hallways and common areas (lounge and office) are too cold.	Environmental parameters were within acceptable range at the time of assessment..	None		
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		Hallways and common areas (lounge and office) are too cold.	Humidity was acceptable at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)		Hallways and common areas (lounge and office) are too cold.	Environmental parameters were within acceptable range at the time of assessment..	None		
	Temperature in my classroom is generally comfortable (72F-76F)?		Hallways and common areas (lounge and office) are too cold.	Temperature was acceptable at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
116	Temp	72.3	RH% 50.4	CO2 1075	Occupants: 26		
Walkthrough				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	1
				Caulking at shower is worn.	Recaulk shower at top along tile.	Site Based	2
120	Temp	69	RH% 54.4	CO2 1420	Occupants:		
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?			Classroom is swept daily of floor objects. Dust accumulation is evident on shelves, equipment, and elsewhere.	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Walkthrough				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
				Ceiling tiles broken, damaged or missing.	Facilities serviceperson to replace damaged ceiling tiles.	Site Based	2
121	Temp	67.9	RH% 53.2	CO2 1266	Occupants: 19		
AIR CONDITIONING							
Windows/doors are operable and are kept closed?				No issues identified at the time of assessment.	None		
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
LOCAL EXHAUST FANS							
Other exhaust fans that may exist in the classroom are functioning properly?				No issues identified at the time of assessment.	None		
THERMAL COMFORT							
Room is usually comfortable? (If no, please explain in the notes below.)			Room is drafty	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
<i>121</i>	Temp	<input type="text" value="67.9"/>	RH% <input type="text" value="53.2"/>	CO2 <input type="text" value="1266"/>	Occupants: <input type="text" value="19"/>		
Walkthrough				Dead plants and soil in room.	Facilities serviceperson should remove dead plants and soil.	Site Based	1
				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
<i>122</i>	Temp	<input type="text" value="73.5"/>	RH% <input type="text" value="53.6"/>	CO2 <input type="text" value="1701"/>	Occupants: <input type="text" value="26"/>		
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Classrooms general appearance is clean and acceptable?				General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Room is free of pests?				No pests observed at the time of assessment.	None		
Walkthrough							
				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
				CO2 level was elevated at the time of the assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower CO2 level.	Physical Plant Operations	1
				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
<i>123</i>	Temp	<input type="text" value="72.5"/>	RH% <input type="text" value="50.6"/>	CO2 <input type="text" value="1358"/>	Occupants: <input type="text" value="18"/>		
AIR CONDITIONING							
Room is free of smell of chemicals?				No odor detected at the time of assessment.	None		
Room is free of smell of kitchen/food?				No odor detected at the time of assessment.	None		
Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None		
Room is free of smell of vehicle exhaust?				No odor detected at the time of assessment.	None		
Windows/doors are operable and are kept closed?				No issues identified at the time of assessment.	None		
ANIMALS IN THE CLASSROOM							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
123	Temp	72.5	RH% 50.6	CO2 1358	Occupants: 18			
	Activities and/or room conditions are modified to address student allergies?	Where does this information come from?			Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3	
	You are informed about the potential allergies of your students?	Where does this information come from?			Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3	
<b>EXCESS MOISTURE IN CLASSROOMS</b>								
	Area around and under classroom sinks free of leaks?	No leaks or signs of water intrusion identified.			None			
	Windows, windowsills and window frames free of continuous condensation?	No visible condensation at the time of assessment.			None			
<b>GENERAL CLEANLINESS</b>								
	Classroom is dusted/vacuumed thoroughly and regularly?	Occasional small red ants			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Classrooms general appearance is clean and acceptable?	Occasional small red ants			General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Room is free of pests?	Occasional small red ants			No pests observed at the time of assessment.	None		
<b>Walkthrough</b>								
		Dust and dirt accumulation on floor.			Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2	
		Dust observed on supply/return registers at the time of assessment.			Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2	

127A Temp 74.4 RH% 52.5 CO2 1497 Occupants: 20

<b>EXCESS MOISTURE IN CLASSROOMS</b>								
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	During heavy rain the back ceiling may leak.			No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
<b>GENERAL CLEANLINESS</b>								

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
<b>127A</b>	Temp	74.4	RH% 52.5	CO2 1497	Occupants: 20		
Room is free of pests?	Small ants are seen periodically. I currently use an orange scented spray to wipe desks on a regular basis (will change if needed.)			No pests observed at the time of assessment.	None		
Room is free of the use of scented cleaners and air fresheners?	Small ants are seen periodically. I currently use an orange scented spray to wipe desks on a regular basis (will change if needed.)			No scented cleaners, air fresheners or non-approved chemicals found at the time of assessment.	None		
Walkthrough				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
<b>127F</b>	Temp	71	RH% 51	CO2 1057	Occupants:		
<b>GENERAL CLEANLINESS</b>							
Classroom is dusted/vacuumed thoroughly and regularly?	Would like supplies to dust. Ceiling tiles are broken.			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
<b>THERMAL COMFORT</b>							
Classroom is free of significant temperature shifts?	Room is really cold especially when it is cold outside.			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
Room is usually comfortable? (If no, please explain in the notes below.)	Room is really cold especially when it is cold outside.			Temperature was low at the time of assessment.			
Temperature in my classroom is generally comfortable (72F-76F)?	Room is really cold especially when it is cold outside.			Temperature was low at the time of assessment.			
Walkthrough				Stained ceiling tiles.	Physical Plant Operations to evaluate for roof leaks and repair as appropriate.	Physical Plant Operations	1
				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
				Signs of water intrusion. Leak identified.	Repair 2 sinks at front of room.	Physical Plant Operations	1

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
131	Temp	69.1	RH% 53.1	CO2 1426	Occupants: 16		
<b>ANIMALS IN THE CLASSROOM</b>							
	Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
	You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
<b>GENERAL CLEANLINESS</b>							
	Classroom is dusted/vacuumed thoroughly and regularly?		Room is not dusted regularly.	Slight dust accumulation was observed on environmental surfaces at the time of assessment.		Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	Walkthrough			Dust observed on supply/return registers at the time of assessment.		Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
				Ceiling tiles stained and dust impaction.		Facilities serviceperson to replace ceiling tiles as appropriate.	Site Based 2
132	Temp	74.1	RH% 47.1	CO2 1333	Occupants:		
<b>GENERAL CLEANLINESS</b>							
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.		Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.		None	
133	Temp	74.2	RH% 48.5	CO2 1706	Occupants:		
<b>GENERAL CLEANLINESS</b>							
	Classroom is dusted/vacuumed thoroughly and regularly?		Room is clean except for dust.	Slight dust accumulation was observed on environmental surfaces at the time of assessment.		Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
<b>THERMAL COMFORT</b>							
	Classroom is free of significant temperature shifts?			Environmental parameters were within acceptable range at the time of assessment..		None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority			
133	Temp	74.2	RH%	48.5	CO2	1706	Occupants:			
	Temperature in my classroom is generally comfortable (72F-76F)?						Temperature was acceptable at the time of assessment.	None		
	Walkthrough						Throw rugs in room.	Occupant advised to remove rugs from room.	Site Based	2
							Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	1
134	Temp	69.6	RH%	52.5	CO2	1360	Occupants:	4		
	GENERAL CLEANLINESS									
	Room is free of the use of scented cleaners and air fresheners?		I wipe the desks with Lysol and it has a scent.				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	1
	THERMAL COMFORT									
	Classroom is free of significant temperature shifts?		The temperature in the room varies. Some days the humidity feels high.				Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		The temperature in the room varies. Some days the humidity feels high.				Humidity was acceptable at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?		The temperature in the room varies. Some days the humidity feels high.				Temperature was low at the time of assessment.	None		
	Walkthrough						Ceiling tiles broken, damaged or missing.	Facilities serviceperson to replace damaged ceiling tiles.	Site Based	2
							Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
							Diverter in A/C vent is broken.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

135

Temp  RH%  CO2  Occupants:

**AIR CONDITIONING**

Air flowing from air supply?	Because the circulation is poor there is often an unpleasant smell in the classroom.	Air supply/return ventilation is not functioning qualitatively.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
Air is flowing without obstruction?	Because the circulation is poor there is often an unpleasant smell in the classroom.	Air flowing without obstruction at the time of assessments.	None		

**GENERAL CLEANLINESS**

Classroom is dusted/vacuumed thoroughly and regularly?		Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Classrooms general appearance is clean and acceptable?		General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Floor is cleaned on a regular basis?		Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2

**THERMAL COMFORT**

Classroom is free of significant temperature shifts?	My room is often stuffy and the air circulation quality is poor.	Environmental parameters were within acceptable range at the time of assessment..	None		
Room is usually comfortable? (If no, please explain in the notes below.)	My room is often stuffy and the air circulation quality is poor.	Environmental parameters were within acceptable range at the time of assessment..	None		

**Walkthrough**

		CO2 level was elevated.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower CO2 level.	Physical Plant Operations	1
		Ceiling tiles broken, damaged or missing.	Facilities serviceperson to replace damaged ceiling tiles.	Site Based	2

136

Temp  RH%  CO2  Occupants:

**THERMAL COMFORT**

Classroom is free of significant temperature shifts?	The room is always cold.	Environmental parameters were within acceptable range at the time of assessment..	None		
Room is usually comfortable? (If no, please explain in the notes below.)	The room is always cold.	Environmental parameters were within acceptable range at the time of assessment..	None		

**Walkthrough**

		Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
--	--	--------------------------------------	--	------------	---



FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

136

Temp  RH%  CO2

Occupants:

Dust observed on supply/return registers at the time of assessment.

Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Site Based

2

144

Temp  RH%  CO2

Occupants:

**AIR CONDITIONING**

Room is free of smell of chemicals?

Sometimes smell of gas and electrical heat is in the classroom.

No odor detected at the time of assessment.

None

**ANIMALS IN THE CLASSROOM**

You are informed about the potential allergies of your students?

Teacher is not notified about specific student allergies.

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

**GENERAL CLEANLINESS**

Classroom is dusted/vacuumed thoroughly and regularly?

Sometimes a lysol spray is used to combat student scents.

Slight dust accumulation was observed on environmental surfaces at the time of assessment.

Site based administration should address general cleanliness with facility serviceperson staff.

Site Based

2

Classrooms general appearance is clean and acceptable?

Sometimes a lysol spray is used to combat student scents.

General cleanliness of the room at the time of assessment was not acceptable.

Site based administration should address general cleanliness with facility serviceperson staff.

Site Based

2

Room is free of pests?

Sometimes a lysol spray is used to combat student scents.

No pests observed at the time of assessment.

Room is free of the use of scented cleaners and air fresheners?

Sometimes a lysol spray is used to combat student scents.

Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.

Facilities serviceperson to open supply vents.

Site Based

1

**THERMAL COMFORT**

Room is usually comfortable? (If no, please explain in the notes below.)

Room is usually too cold or too hot. No middle ground temperature.

Environmental parameters were within acceptable range at the time of assessment..

None

Temperature in my classroom is generally comfortable (72F-76F)?

Room is usually too cold or too hot. No middle ground temperature.

Temperature was acceptable at the time of assessment.

None

157

Temp  RH%  CO2

Occupants:

**AIR CONDITIONING**

Air flowing from air supply?

There is no air flow in the locker rooms. Locker room office has odor as well as locker rooms (not just "smelly bodies"). Could be mold. Often told the gym smells.

Air supply/return ventilation is not functioning qualitatively.

Physical Plant Operations to evaluate and repair as appropriate.

Physical Plant Operations

1

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
157	Temp	73.7	RH% 54.9	CO2 1856	Occupants: 91		
	Air is flowing without obstruction?	There is no air flow in the locker rooms. Locker room office has odor as well as locker rooms (not just "smelly bodies"). Could be mold. Often told the gym smells.			Air supply/return ventilation is not functioning qualitatively.		
	Room is free of smell of mold or mildew?	There is no air flow in the locker rooms. Locker room office has odor as well as locker rooms (not just "smelly bodies"). Could be mold. Often told the gym smells.			Odor detected at the time of assessment. Cause not found.	Physical Plant Operations to evaluate cause of odor.	Physical Plant Operations 2
	Windows/doors are operable and are kept closed?	There is no air flow in the locker rooms. Locker room office has odor as well as locker rooms (not just "smelly bodies"). Could be mold. Often told the gym smells.			No issues identified at the time of assessment. None		
<b>EXCESS MOISTURE IN CLASSROOMS</b>							
	Area around and under classroom sinks free of leaks?				Signs of water intrusion. Leak identified.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations 1
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Signs of water intrusion. Leak not identified.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations 1
	Classroom lavatories/water fountains free of leaks?				Signs of water intrusion. Leak identified.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations 1
<b>GENERAL CLEANLINESS</b>							
	Classroom is dusted/vacuumed thoroughly and regularly?	Rats observed under bleachers and pipes that run across ceiling.			No issues identified at the time of assessment. None		
	Floor is cleaned on a regular basis?	Rats observed under bleachers and pipes that run across ceiling.			Floor was clean at the time of assessment. None		
	Room is free of pests?	Rats observed under bleachers and pipes that run across ceiling.			No pests observed at the time of assessment. None		
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?	Rats observed under bleachers and pipes that run across ceiling.			No issues identified at the time of assessment. None		
<b>LOCAL EXHAUST FANS</b>							
	Bathroom exhaust fan is functioning properly?	The exhaust fan in the locker room is not operating. One small fan to circulate air works.			Exhaust fan is not functioning properly. Physical Plant Operations to evaluate and repair/replace as appropriate. Physical Plant Operations 1		
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?	The exhaust fan in the locker room is not operating. One small fan to circulate air works.			Exhaust fan is not functioning properly. Physical Plant Operations to evaluate and repair/replace as appropriate. Physical Plant Operations 1		
	Other exhaust fans that may exist in the classroom are functioning properly?	The exhaust fan in the locker room is not operating. One small fan to circulate air works.			Exhaust fan is not functioning properly. Physical Plant Operations to evaluate and repair/replace as appropriate. Physical Plant Operations 1		
<b>THERMAL COMFORT</b>							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
157	Temp	73.7	RH%	54.9	CO2	1856	Occupants:	91			
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		Can be too cold and locker rooms are too hot. No AC or proper ventilation.	Humidity was acceptable at the time of assessment.	None						
	Room is usually comfortable? (If no, please explain in the notes below.)		Can be too cold and locker rooms are too hot. No AC or proper ventilation.	Environmental parameters were within acceptable range at the time of assessment..	None						
	Walkthrough			Exhaust fans are not functioning properly.	Physical Plant Operations to evaluate and repair/replace all exhaust fans as appropriate.	Physical Plant Operations					1
				Shower faucets are leaking.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations					1
				Broken tiles in shower.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations					1
168	Temp	69.1	RH%	59.3	CO2	734	Occupants:				
	AIR CONDITIONING										
	Room is free of smell of mold or mildew?				Odor detected from carpet.	Facilities serviceperson to thoroughly clean and sanitize carpet.	Site Based				1
	EXCESS MOISTURE IN CLASSROOMS										
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Stained ceiling tiles in room and in hallway outside of room. Appears to be leak at A/C vent.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations				1
	GENERAL CLEANLINESS										
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based				2
	THERMAL COMFORT										
	Classroom is free of significant temperature shifts?		Room is frequently uncomfortable.	No issues identified at the time of assessment.							
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		Room is frequently uncomfortable.	Humidity was acceptable at the time of assessment.	None						
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)		Room is frequently uncomfortable.	No issues identified at the time of assessment.	None						
	Room is usually comfortable? (If no, please explain in the notes below.)		Room is frequently uncomfortable.	No issues identified at the time of assessment.							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
168	Temp	69.1	RH%	59.3	CO2	734	Occupants:				
	Temperature in my classroom is generally comfortable (72F-76F)?		Room is frequently uncomfortable.	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based					2
	Walkthrough			Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based					2
181	Temp	70.6	RH%	54	CO2	758	Occupants:	72			
	AIR CONDITIONING										
	Room is free of smell of kitchen/food?		Smell of kitchen/food is constant	No odor detected at the time of assessment.	None						
	DRAIN TRAPS IN THE CLASSROOM										
	Water poured down floor drains once per week (approx. 1 quart of water).		Sink and drain in closet	No issues identified at the time of assessment.	None						
	Water run in sinks at least once per week (about 2 cups of water).		Sink and drain in closet	No issues identified at the time of assessment.	None						
	GENERAL CLEANLINESS										
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based					2
	Walkthrough			Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based					2
				Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations					1
182	Temp	71.2	RH%	52.4	CO2	791	Occupants:	22			
	AIR CONDITIONING										
	Room is free of smell of kitchen/food?		There is an odor by some of the stoves.	Odor detected by the stoves. This is the old home economics room.	Physical Plant Operations to evaluate cause of odor and repair as appropriate.	Physical Plant Operations					1
	Windows/doors are operable and are kept closed?		There is an odor by some of the stoves.	No issues identified at the time of assessment.	None						

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
182	Temp	71.2	RH% 52.4	CO2 791	Occupants: 22		
<b>ANIMALS IN THE CLASSROOM</b>							
	Activities and/or room conditions are modified to address student allergies?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
	Classroom is free of animals and pets?			No animals identified at the time of assessment.	None		
	You are informed about the potential allergies of your students?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
<b>EXCESS MOISTURE IN CLASSROOMS</b>							
	Area around and under classroom sinks free of leaks?		There is a sink that is missing pipes.	Signs of water intrusion. Leak identified.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
<b>GENERAL CLEANLINESS</b>							
	Classroom is dusted/vacuumed thoroughly and regularly?		Never dusted or vacuumed and there are ants., Room is very dusty. The stoves in the room need to be cleaned. Also there are some broken partitions that need to be removed.	Excessive dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Classrooms general appearance is clean and acceptable?		Never dusted or vacuumed and there are ants., Room is very dusty. The stoves in the room need to be cleaned. Also there are some broken partitions that need to be removed.	General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?		Never dusted or vacuumed and there are ants., Room is very dusty. The stoves in the room need to be cleaned. Also there are some broken partitions that need to be removed.	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Room is free of pests?		Never dusted or vacuumed and there are ants., Room is very dusty. The stoves in the room need to be cleaned. Also there are some broken partitions that need to be removed.	Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations	1
<b>Walkthrough</b>							
				Signs of water intrusion. Leak identified.	Sink piping is leaking.	Physical Plant Operations	1
				Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
183	Temp	70.4	RH% 53.7	CO2 982	Occupants: 24		
<b>AIR CONDITIONING</b>							
	Room is free of smell of mold or mildew?		Rugs are moldy	Odor detected and is coming from rugs in room.	Facilities serviceperson should remove rugs from the room.	Site Based	1
	Windows/doors are operable and are kept closed?		Rugs are moldy	No issues identified at the time of assessment.	None		
<b>GENERAL CLEANLINESS</b>							
	Classroom is dusted/vacuumed thoroughly and regularly?		Sink needs to be cleaned and the rug by the sink needs to be cleaned -- smells like mold. The classroom is sometimes clean and spills are sometimes cleaned in a timely manner.	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Classrooms general appearance is clean and acceptable?		Sink needs to be cleaned and the rug by the sink needs to be cleaned -- smells like mold. The classroom is sometimes clean and spills are sometimes cleaned in a timely manner.	General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?		Sink needs to be cleaned and the rug by the sink needs to be cleaned -- smells like mold. The classroom is sometimes clean and spills are sometimes cleaned in a timely manner.	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?		Sink needs to be cleaned and the rug by the sink needs to be cleaned -- smells like mold. The classroom is sometimes clean and spills are sometimes cleaned in a timely manner.	There appears to be a problem with spill clean up practices. To address all spills in a timely manner, all moisture effected materials must be dried within a 24-hour timeframe.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
<b>THERMAL COMFORT</b>							
	Temperature in my classroom is generally comfortable (72F-76F)?			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
<b>Walkthrough</b>							
				Signs of water intrusion. Leak identified.	Sink is leaking.	Physical Plant Operations	1
				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
				Ceiling tiles broken, damaged or stained.	Facilities serviceperson to replace damaged ceiling tiles.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
211	Temp	76.8	RH% 66.4	CO2 921	Occupants: 25			
	<b>EXCESS MOISTURE IN CLASSROOMS</b>							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Ceiling tiles are stained, sagging and show signs of dust impactation.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1	
	<b>GENERAL CLEANLINESS</b>							
	Classroom is dusted/vacuumed thoroughly and regularly?			Window ledges are dirty. Shelves need damp cloth dusting and floors need to be stripped and waxed.	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Classrooms general appearance is clean and acceptable?			Window ledges are dirty. Shelves need damp cloth dusting and floors need to be stripped and waxed.	General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?			Window ledges are dirty. Shelves need damp cloth dusting and floors need to be stripped and waxed.	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	<b>Walkthrough</b>							
				Temperature and humidity were elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	2	
				Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1	
212	Temp	75.7	RH% 66.7	CO2 798	Occupants: 24			
	<b>GENERAL CLEANLINESS</b>							
	Classroom is dusted/vacuumed thoroughly and regularly?			Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2	
	Classrooms general appearance is clean and acceptable?			General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2	
	Room is free of pests?			No pests observed at the time of assessment.	None			
	<b>Walkthrough</b>							
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	1	
				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
212	Temp	75.7	RH% 66.7	CO2 798	Occupants: 24		
				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
				Temperature and humidity were elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	2
213	Temp	76.5	RH% 66.6	CO2 689	Occupants:		
<b>AIR CONDITIONING</b>							
	Room is free of smell of chemicals?		Mold and mildew is noticeable	Odor detected.	Physical Plant Operations to evaluate cause of odor.	Physical Plant Operations	1
	Room is free of smell of kitchen/food?		Mold and mildew is noticeable	Odor detected.	Physical Plant Operations to evaluate cause of odor.	Physical Plant Operations	1
	Room is free of smell of vehicle exhaust?		Mold and mildew is noticeable	Odor detected.	Physical Plant Operations to evaluate cause of odor.	Physical Plant Operations	1
<b>EXCESS MOISTURE IN CLASSROOMS</b>							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?		Ceiling tiles are warped and have visible signs of dirt and/or mold. The ceiling leaks after a hard rain.				
	Indoor surfaces of exterior walls free of continuous condensation?		Ceiling tiles are warped and have visible signs of dirt and/or mold. The ceiling leaks after a hard rain.				
	Windows, windowsills and window frames free of continuous condensation?		Ceiling tiles are warped and have visible signs of dirt and/or mold. The ceiling leaks after a hard rain.	Ceiling tiles are stained, sagging and show signs of dust impaction.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	1
<b>GENERAL CLEANLINESS</b>							
	Classroom is dusted/vacuumed thoroughly and regularly?		Main walkways are swept. With the higher humidity there seems to be more ants. When dumpsters are emptied, flies are present in the classroom along with an odor.	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?		Main walkways are swept. With the higher humidity there seems to be more ants. When dumpsters are emptied, flies are present in the classroom along with an odor.	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Room is free of pests?		Main walkways are swept. With the higher humidity there seems to be more ants. When dumpsters are emptied, flies are present in the classroom along with an odor.	No pests observed at the time of assessment.	None		
<b>LOCAL EXHAUST FANS</b>							



FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
213	Temp	76.5	RH% 66.6	CO2 689	Occupants:		
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)		Do not have any fans in classroom.	No issues identified at the time of assessment.	None		
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?		Do not have any fans in classroom.	No issues identified at the time of assessment.	None		
	Other exhaust fans that may exist in the classroom are functioning properly?		Do not have any fans in classroom.	No issues identified at the time of assessment.	None		
	Walkthrough			Temperature and humidity were elevated at the time of assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	2
				Ceiling tiles broken, damaged or stained.	Facilities serviceperson to replace ceiling tiles as appropriate.	Site Based	2
275	Temp	76.7	RH% 46.8	CO2 2068	Occupants:	10	
	GENERAL CLEANLINESS						
	Classroom is dusted/vacuumed thoroughly and regularly?	Ants		Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Classrooms general appearance is clean and acceptable?	Ants		General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Room is free of pests?	Ants		Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations	1
	Walkthrough			CO2 level was elevated at time of the assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower CO2 level.	Physical Plant Operations	2
				Dust and debris on HVAC filters.	Facilities serviceperson to replace HVAC filters.	Site Based	1
				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	1

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
299	Temp	75.1	RH% 47.6	CO2 3181	Occupants:		
<b>GENERAL CLEANLINESS</b>							
	Classroom is dusted/vacuumed thoroughly and regularly?	Ants		Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Classrooms general appearance is clean and acceptable?	Ants		General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?	Ants		Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based	2
	Food, if any, is stored in tightly sealed containers?	Ants		No issues identified at the time of assessment.	None		
	Room is free of pests?	Ants		No pests observed at the time of assessment.	None		
<b>Walkthrough</b>							
				CO2 level was elevated at the time of the assessment.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower CO2 level.	Physical Plant Operations	2
				A/C unit on North wall was not functioning.	Physical Plant Operations to evaluate need for test and balance.	Physical Plant Operations	1
314C	Temp	72.8	RH% 41.6	CO2 3077	Occupants:	25	
<b>ANIMALS IN THE CLASSROOM</b>							
	Activities and/or room conditions are modified to address student allergies?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?				Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
<b>GENERAL CLEANLINESS</b>							
	Classroom is dusted/vacuumed thoroughly and regularly?	Roaches		Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Classrooms general appearance is clean and acceptable?	Roaches		General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority			
<b>314C</b>	<b>Temp</b>	<input type="text" value="72.8"/>	<b>RH%</b>	<input type="text" value="41.6"/>	<b>CO2</b>	<input type="text" value="3077"/>	<b>Occupants:</b>	<input type="text" value="25"/>		
Floor is cleaned on a regular basis?			Roaches	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based				2
Room is free of pests?			Roaches	No pests observed at the time of assessment.	None					
Walkthrough				Ceiling tiles broken, damaged or missing.	Facilities serviceperson to replace damaged ceiling tiles.	Site Based				2
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based				1
				Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based				2
<b>319C</b>	<b>Temp</b>	<input type="text" value="75.2"/>	<b>RH%</b>	<input type="text" value="53.2"/>	<b>CO2</b>	<input type="text" value="1289"/>	<b>Occupants:</b>	<input type="text"/>		
<b>ANIMALS IN THE CLASSROOM</b>										
You are informed about the potential allergies of your students?			Need help determining if students have allergies.		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based				3
Walkthrough				Signs of water intrusion. Stained ceiling tiles.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations				1
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based				1
				Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based				2
				Excessive dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based				2
<b>774C</b>	<b>Temp</b>	<input type="text" value="74.3"/>	<b>RH%</b>	<input type="text" value="40.1"/>	<b>CO2</b>	<input type="text" value="1826"/>	<b>Occupants:</b>	<input type="text"/>		
<b>AIR CONDITIONING</b>										
Room is free of smell of chemicals?					Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based			1

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
774C	Temp	74.3	RH% 40.1	CO2 1826	Occupants:		
	Room is free of smell of kitchen/food?				No odor detected at the time of assessment.	None	
	Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None	
	Room is free of smell of vehicle exhaust?				No odor detected at the time of assessment.	None	
	Windows/doors are operable and are kept closed?				No issues identified at the time of assessment.	None	
<b>ANIMALS IN THE CLASSROOM</b>							
	You are informed about the potential allergies of your students?					Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
<b>EXCESS MOISTURE IN CLASSROOMS</b>							
	Windows, windowsills and window frames free of continuous condensation?				No visible condensation at the time of assessment.	None	
<b>GENERAL CLEANLINESS</b>							
	Classroom is dusted/vacuumed thoroughly and regularly?		Portables need to be dusted and mopped regularly.		Excessive dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts	Site Based 2
	Floor is cleaned on a regular basis?		Portables need to be dusted and mopped regularly.		Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2
<b>LOCAL EXHAUST FANS</b>							
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)				No issues identified at the time of assessment.	None	
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?				No issues identified at the time of assessment.	None	
<b>Walkthrough</b>							
					Ceiling tiles broken, damaged or missing.	Facilities serviceperson to replace damaged ceiling tiles.	Site Based 2
					Dust observed on supply/return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site Based 2