

# Tools for Schools - Indoor Air Quality

## Follow-up Action Plan for Site



Pompano Beach Middle

85.2 47% 310

Principal: Ms. Sonja Smith Braziel

Walkthrough Date: 5/25/2004

Temp RH Co2  
Outside Measurements

Assignment Member: Mark Dorsett

Room	Priority	Responsible	Assessment Comments	Recommended Corrective Action
120	3	Site	General cleanliness appeared adequate on date of assessment. Ceiling tiles need to be replaced.	Install new ceiling tiles.
136	2	Site	Dust and debris was observed on the air supply and return registers at the time of the assessment.	Custodial staff should clean and sanitize the air supply and return registers in this classroom.
169A	2	Site	Dust and debris was observed on the air supply and return registers at the time of the assessment.	Custodial staff should clean and sanitize the air supply and return registers in this classroom.
183	2	Site	Industrial hand wash and stuffed animals in room.	Teacher to remove hand wash and stuffed animals.
183	3	Site	There were no problems observed at time of assessment. However, ceiling tiles are stained.	Install new ceiling tiles.
185E	1	Site	Teacher does not use sink.	Water needs to be run in sink regularly.
191	2	Site	Locker room is being used for storage.	Work order to be generated for storage space.
193	1	Site	Drains are dry.	Water needs to be run in sink regularly.
195	1	Site	Items are in shower area.	Items need to be removed from shower area.
195	1	Site	Items are in shower area.	Items need to be removed from shower area.
408	2	Site	Dust and debris was observed on the air supply and return registers at the time of the assessment.	Custodial staff should clean and sanitize the air supply and return registers in this classroom.
410	2	Site	Dust and debris was observed on the air supply at the time of the assessment.	Custodial staff should clean and sanitize the air supply in this classroom.
788C	3	Site	Dust accumulation was observed on books.	Custodial staff should thoroughly clean all environmental surfaces within classroom.