

Report: Site

**RAMBLEWOOD MIDDLE**

Walkthrough Date: 03/14/2007 Temp RH CO2

Outdoor Parameters: 81.5 49.5 405

Room	Priority	Responsible	Answer	Recommendation
101	Inside Parameters:	Temp	RH	CO2
		71.7	51.1	694

2 Site Dust observed on supply and return registers at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Room	Priority	Responsible	Answer	Recommendation
101G	Inside Parameters:	Temp	RH	CO2
		72.5	51.2	626

3 Site This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Room	Priority	Responsible	Answer	Recommendation
103	Inside Parameters:	Temp	RH	CO2
		70.3	51.1	590

3 Site This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Room	Priority	Responsible	Answer	Recommendation
105	Inside Parameters:	Temp	RH	CO2
		70.1	51	960

2 Site Temperature was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
109	Inside Parameters:	Temp	RH	CO2

		70.4	52.6	1015
2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.		Site based administration should address general cleanliness with facility serviceperson staff.
3	Site	This is a general issue requiring approved communication among all stakeholders.		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
2	Site	Temperate was low at the time of assessment.		Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
133	Inside Parameters:	Temp	RH	CO2
		72.9	47.4	710
2	Site	Dust observed on supply and return registers at the time of assessment.		Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Room	Priority	Responsible	Answer	Recommendation
150	Inside Parameters:	Temp	RH	CO2
		74.7	50.2	1080
2	Site	Excessive dust accumulation was observed on environmental surfaces at the time of assessment.		Site based administration should address general cleanliness with facility serviceperson staff.
2	Site	Dust and dirt accumulation on floor.		Facilities serviceperson to thoroughly clean and sanitize.
2	Site	Water is not poured down floor drain at least once a week.		Site based administration should address maintenance of sinks toilets and drains with facility serviceperson staff.
2	Site	Dust and debris identified in locker room and showers at the time of assessment.		Site based administration should address locker room and shower maintenance/general cleanliness with facility serviceperson staff.
2	Site	Excessive clothes and towels in locker room/shower at the time of assessment.		Site based administration should address locker room and shower maintenance/general cleanliness with facility serviceperson staff.

Room	Priority	Responsible	Answer	Recommendation
154	Inside Parameters:	Temp	RH	CO2
		73.7	46.1	827

3 Site This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

2 Site Dust and debris identified in locker room and showers at the time of assessment. Site based administration should address locker room and shower maintenance/general cleanliness with facility serviceperson staff.

Room	Priority	Responsible	Answer	Recommendation
155	Inside Parameters:	Temp	RH	CO2
		71.9	51.4	918

2 Site Temperature was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
161	Inside Parameters:	Temp	RH	CO2
		70.1	50.2	822

2 Site Temperature was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
163	Inside Parameters:	Temp	RH	CO2
		69.3	56.1	878

2 Site Temperature was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
178	Inside Parameters:	Temp	RH	CO2
		69.3	50.4	1192

2 Site Dust observed on return register at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

2 Site Temperature was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical

Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
201	Inside Parameters:	Temp	RH	CO2
		72.4	54.9	1460

3 Site This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Room	Priority	Responsible	Answer	Recommendation
243	Inside Parameters:	Temp	RH	CO2
		74.5	41.8	1522

2 Site Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.

2 Site Dust and dirt accumulation on floor. Facilities serviceperson to thoroughly clean and sanitize.

Room	Priority	Responsible	Answer	Recommendation
401	Inside Parameters:	Temp	RH	CO2
		72.5	55.1	1411

2 Site Dust and dirt accumulation on floor. Facilities serviceperson to thoroughly clean and sanitize.

Room	Priority	Responsible	Answer	Recommendation
405	Inside Parameters:	Temp	RH	CO2
		73.3	54.3	1306

2 Site Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.

2 Site Dust and dirt accumulation on floor. Facilities serviceperson to thoroughly clean and sanitize.

3 Site This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Room	Priority	Responsible	Answer	Recommendation
407	Inside	Temp	RH	CO2

Parameters:	70.4	48.5	1308
-------------	------	------	------

2 Site Dust and dirt accumulation on floor. Facilities serviceperson to thoroughly clean and sanitize.

Room	Priority	Responsible	Answer	Recommendation
412	Inside Parameters:	Temp	RH	CO2
		73.8	43.9	1264

2 Site Dust and dirt accumulation on floor. Facilities serviceperson to thoroughly clean and sanitize.