

**RAMBLEWOOD MIDDLE**

Walkthrough Date: 03/14/2007 Temp RH CO2

Outdoor Parameters: 81.5 49.5 405

Room	Section	Question	Answer	Recommendation	Responsible
101	Inside Parameters:	Temp 71.7	RH 51.1	CO2 694	
	GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
	GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Carpet was stained torn rippled or buckled.	Physical Plant Operations to evaluate and repair/replace as appropriate.	PPO
	EXCESS MOISTURE IN CLASSROOMS	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	No leaks or signs of water intrusion identified.		
	THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F- 76F)?	Temperature was acceptable at the time of assessment.		
	THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
	THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was acceptable at the time of assessment.		
	THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were within acceptable range at the time of assessment..		
	AIR CONDITIONING	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		
	LOCAL EXHAUST FANS	Bathroom exhaust fan is functioning properly?	No bathroom. Identified in error.		
	LOCKER ROOM	Locker room and showers cleaned regularly and properly?	Issues not applicable. Room is not a locker room.		

Room	Section	Question	Answer	Recommendation	Responsible
101A	Inside Parameters:	Temp 74.2	RH 48.6	CO2 643	

AIR  
CONDITIONING

Room is free of smell of mold or mildew?

No microbial growth identified. No odor identified at the time of assessment.

Room	Section	Question	Answer	Recommendation	Responsible
101G	Inside Parameters:	Temp 72.5	RH 51.2	CO2 626	

ANIMALS IN THE  
CLASSROOM

Activities and/or room conditions are modified to address student allergies?

This is a general issue requiring approved communication among all stakeholders.

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site

Room	Section	Question	Answer	Recommendation	Responsible
102	Inside Parameters:	Temp 72.1	RH 51.6	CO2 758	

LOCAL EXHAUST  
FANS

Other exhaust fans that may exist in the classroom are functioning properly?

Carpet is severely stained. Occupants complaining of odor from carpet.

Physical Plant Operations to evaluate carpeting in all admin offices.

PPO

Room	Section	Question	Answer	Recommendation	Responsible
103	Inside Parameters:	Temp 70.3	RH 51.1	CO2 590	

GENERAL  
CLEANLINESS

Classroom is dusted/vacuumed thoroughly and regularly?

There does not appear to be a dusting issue within this room.

GENERAL  
CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

No dust observed on supply/return registers at the time of assessment.

GENERAL  
CLEANLINESS

Floor is cleaned on a regular basis?

Carpet was stained torn ripped or buckled.

Physical Plant Operations to evaluate and repair/replace as appropriate.

PPO

ANIMALS IN THE  
CLASSROOM

Activities and/or room conditions are modified to address student allergies?

This is a general issue requiring approved communication among all stakeholders.

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site

THERMAL COMFORT Temperature in my classroom is generally comfortable (72F- 76F)? Temperature was acceptable at the time of assessment.

THERMAL COMFORT Classroom is free of significant temperature shifts? Temperature was acceptable at the time of assessment.

THERMAL COMFORT Room is free of the introduction of outdoor air? (Gaps in window/door frames.) No gaps in windows or doors identified at the time of assessment.

THERMAL COMFORT Room is usually comfortable? (If no, please explain in the notes below.) Environmental parameters were within acceptable range at the time of assessment..

AIR CONDITIONING Room is free of smell of vehicle exhaust? No odor detected at the time of assessment.

Room	Section	Question	Answer	Recommendation	Responsible
105	Inside Parameters:	Temp	RH	CO2	
		70.1	51	960	

GENERAL CLEANLINESS Classroom is dusted/vacuumed thoroughly and regularly? There does not appear to be a dusting issue within this room.

GENERAL CLEANLINESS Air supply/return registers are cleaned regularly and free of dust and debris accumulation? No dust observed on supply/return registers at the time of assessment.

GENERAL CLEANLINESS Room is free of pests? No pests observed at the time of assessment.

THERMAL COMFORT Temperature in my classroom is generally comfortable (72F- 76F)? Temperature was low at the time of assessment.

THERMAL COMFORT Classroom is free of significant temperature shifts? Temperature was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

THERMAL COMFORT Room is usually comfortable? (If no, please explain in the notes below.) Environmental parameters were within acceptable range at the time of assessment..

LOCAL EXHAUST FANS	My classroom has sufficient exhaust systems based on the activities/functionality of the room?	It appears that the ventilation system is adequate based on room activities.
LOCAL EXHAUST FANS	Other exhaust fans that may exist in the classroom are functioning properly?	Exhaust fan is functioning properly.
ART SUPPLIES	Science supplies okay?	No science supplies in room. Room not being used as a science room.

Room	Section	Question	Answer	Recommendation	Responsible
107	Inside Parameters:	Temp 70.5	RH 51.5	CO2 970	

DRAIN TRAPS IN THE CLASSROOM Water poured down floor drains once per week (approx. 1 quart of water). No floor drain in room.

LOCAL EXHAUST FANS Other exhaust fans that may exist in the classroom are functioning properly? No exhaust fans in room. Identified in error.

Room	Section	Question	Answer	Recommendation	Responsible
109	Inside Parameters:	Temp 70.4	RH 52.6	CO2 1015	

GENERAL CLEANLINESS Classroom is dusted/vacuumed thoroughly and regularly? Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.

ANIMALS IN THE CLASSROOM Activities and/or room conditions are modified to address student allergies? This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary. Site

THERMAL COMFORT Temperature in my classroom is generally comfortable (72F- 76F)? Temperate was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve. Site

THERMAL COMFORT Room is usually comfortable? (If no, please explain in the notes Environmental parameters were within acceptable

below.)

range at the time of  
assessment..

Room	Section	Question	Answer	Recommendation	Responsible
120	Inside Parameters:	Temp 73.7	RH 47.9	CO2 1064	
	THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F- 76F)?	Temperature was acceptable at the time of assessment.		
	THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
	THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were within acceptable range at the time of assessment..		
	AIR CONDITIONING	Air flowing from air supply?	Air supply/return ventilation is functioning.		
	AIR CONDITIONING	Room is free of smell of kitchen/food?	No odor detected at the time of assessment.		
	LOCAL EXHAUST FANS	Bathroom exhaust fan is functioning properly?	Bathroom exhaust fan is functioning properly.		

Room	Section	Question	Answer	Recommendation	Responsible
120B	Inside Parameters:	Temp 72.9	RH 44.5	CO2 902	
	THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F- 76F)?	Temperature was acceptable at the time of assessment.		
	THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
	AIR CONDITIONING	Room is free of smell of kitchen/food?	No odor detected at the time of assessment.		

Room	Section	Question	Answer	Recommendation	Responsible
120C	Inside Parameters:	Temp 72.3	RH 51.7	CO2 915	
	THERMAL	Temperature in my classroom is	Temperature was		

COMFORT	generally comfortable (72F- 76F)?	acceptable at the time of assessment.
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.
AIR CONDITIONING	Room is free of smell of kitchen/food?	No odor detected at the time of assessment.

Room	Section	Question	Answer	Recommendation	Responsible
133	Inside Parameters:	Temp 72.9	RH 47.4	CO2 710	
	GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on supply and return registers at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site
	THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F- 76F)?	Temperature was acceptable at the time of assessment.		
	THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were within acceptable range at the time of assessment..		

Room	Section	Question	Answer	Recommendation	Responsible
150	Inside Parameters:	Temp 74.7	RH 50.2	CO2 1080	
	GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	Excessive dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site
	GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize.	Site
	DRAIN TRAPS IN THE CLASSROOM	Water poured down floor drains once per week (approx. 1 quart of water).	Water is not poured down floor drain at least once a week.	Site based administration should address maintenance of sinks toilets and drains with facility serviceperson staff.	Site
	EXCESS MOISTURE IN CLASSROOMS	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	No leaks or signs of water intrusion identified.		
	THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F- 76F)?	Temperature was acceptable at the time of		

			assessment.	
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were within acceptable range at the time of assessment..		
AIR CONDITIONING	Air flowing from air supply?	Locker room - no a/c.		
AIR CONDITIONING	Air is flowing without obstruction?	Locker room - no a/c.		
AIR CONDITIONING	Room is free of smell of chemicals?	Odor detected at the time of assessment. - locker room		
AIR CONDITIONING	Room is free of smell of mold or mildew?	No microbial growth identified. No odor identified at the time of assessment.		
LOCAL EXHAUST FANS	My classroom has sufficient exhaust systems based on the activities/functionality of the room?	It appears that the ventilation system is adequate based on room activities.		
LOCAL EXHAUST FANS	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)	It appears that the ventilation system is not adequate based on room activities.		
LOCAL EXHAUST FANS	Bathroom exhaust fan is functioning properly?	Bathroom exhaust fan is functioning properly.		
LOCAL EXHAUST FANS	Other exhaust fans that may exist in the classroom are functioning properly?	Exhaust fan is not functioning properly.	Physical Plant Operations to evaluate and repair as appropriate.	PPO
LOCKER ROOM	Locker room and showers cleaned regularly and properly?	Dust and debris identified in locker room and showers at the time of assessment.	Site based administration should address locker room and shower maintenance/general cleanliness with facility serviceperson staff.	Site
LOCKER ROOM	Soiled clothes and towels are removed regularly?	Excessive clothes and towels in locker room/shower at the time of assessment.	Site based administration should address locker room and shower maintenance/general cleanliness with facility serviceperson staff.	Site

Room	Section	Question	Answer	Recommendation	Responsible
154	Inside Parameters:	Temp	RH	CO2	

		73.7	46.1	827	
GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?		There does not appear to be a dusting issue within this room.		
GENERAL CLEANLINESS	Trash is removed daily and trash bags are changed as appropriate?		No issues identified regarding trash removal practices.		
GENERAL CLEANLINESS	Floor is cleaned on a regular basis?		Floor was clean at the time of assessment.		
ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?		This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
EXCESS MOISTURE IN CLASSROOMS	Windows, windowsills and window frames free of continuous condensation?		No windows in room.		
EXCESS MOISTURE IN CLASSROOMS	Cold water pipes free of continuous condensation?		No pipes in room.		
EXCESS MOISTURE IN CLASSROOMS	Indoor surfaces of exterior walls free of continuous condensation?		No visible condensation or signs of water intrusion identified at the time of assessment.		
LOCKER ROOM	Locker room and showers cleaned regularly and properly?		Dust and debris identified in locker room and showers at the time of assessment.	Site based administration should address locker room and shower maintenance/general cleanliness with facility serviceperson staff.	Site
LOCKER ROOM	Soiled clothes and towels are removed regularly?		Appears that clothes and towels are removed regularly.		

Room	Section	Question	Answer	Recommendation	Responsible
155	Inside Parameters:	Temp	RH	CO2	
		71.9	51.4	918	
THERMAL COMFORT	Classroom is free of significant temperature shifts?		Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does	Site



not improve.

Room	Section	Question	Answer	Recommendation	Responsible
161	Inside Parameters:	Temp 70.1	RH 50.2	CO2 822	
	GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	There does not appear to be a dusting issue within this room.		
	THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
	THERMAL COMFORT	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)	No gaps in windows or doors identified at the time of assessment.		
	THERMAL COMFORT	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Humidity was acceptable at the time of assessment.		
	THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were within acceptable range at the time of assessment..		
	AIR CONDITIONING	Air is flowing without obstruction?	Air flowing without obstruction at the time of assessments.		

Room	Section	Question	Answer	Recommendation	Responsible
163	Inside Parameters:	Temp 69.3	RH 56.1	CO2 878	
	GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	No dust observed on supply/return registers at the time of assessment.		
	GENERAL CLEANLINESS	Room is free of pests?	No pests observed at the time of assessment.		
	THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F- 76F)?	Temperature was low at the time of assessment.		

THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site
THERMAL COMFORT	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)	Gaps in doors identified at the time of assessment.	Physical Plant Operations to evaluate and repair as appropriate.	PPO
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were within acceptable range at the time of assessment..		

Room	Section	Question	Answer	Recommendation	Responsible
178	Inside Parameters:	Temp 69.3	RH 50.4	CO2 1192	

GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	There does not appear to be a dusting issue within this room.			
GENERAL CLEANLINESS	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Dust observed on return register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.	Site	
GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.			
THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F- 76F)?	Temperature was low at the time of assessment.			
THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site	
THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment. CO2 level was elevated.	Physical Plant Operations to evaluate and repair as appropriate to lower CO2 level.	PPO	

Room	Section	Question	Answer	Recommendation	Responsible

184	Inside Parameters:	Temp 72.1	RH 45	CO2 768	
	GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	There does not appear to be a dusting issue within this room.		
	GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Floor was clean at the time of assessment.		
	THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F- 76F)?	Temperature was acceptable at the time of assessment.		
	THERMAL COMFORT	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)	No gaps in windows or doors identified at the time of assessment.		
	THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were within acceptable range at the time of assessment..		

Room	Section	Question	Answer	Recommendation	Responsible
201	Inside Parameters:	Temp 72.4	RH 54.9	CO2 1460	
	GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	There does not appear to be a dusting issue within this room.		
	ANIMALS IN THE CLASSROOM	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site
	THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F- 76F)?	Temperature was acceptable at the time of assessment.		
	THERMAL COMFORT	Classroom is free of significant temperature shifts?	Temperature was acceptable at the time of assessment.		
	THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment. CO2 level was elevated.	Physical Plant Operations to evaluate and repair as appropriate to lower CO2 level.	PPO

AIR  
CONDITIONING

Room is free of smell of mold or  
mildew?

No microbial growth  
identified. No odor  
identified at the time of  
assessment.

Room	Section	Question	Answer	Recommendation	Responsible
203	Inside Parameters:	Temp	RH	CO2	
		73	47.5	1497	

GENERAL  
CLEANLINESS

Classroom is dusted/vacuumed  
thoroughly and regularly?

There does not appear to be  
a dusting issue within this  
room.

GENERAL  
CLEANLINESS

Room is free of pests?

No pests observed at the  
time of assessment.

THERMAL  
COMFORT

Temperature in my classroom is  
generally comfortable (72F- 76F)?

Temperature was  
acceptable at the time of  
assessment.

THERMAL  
COMFORT

Room is usually comfortable? (If  
no, please explain in the notes  
below.)

Environmental parameters  
were not within acceptable  
range at the time of  
assessment. CO2 level was  
elevated.

Physical Plant Operations to evaluate and repair PPO  
as appropriate to lower CO2 level.

Room	Section	Question	Answer	Recommendation	Responsible
243	Inside Parameters:	Temp	RH	CO2	
		74.5	41.8	1522	

GENERAL  
CLEANLINESS

Classroom is dusted/vacuumed  
thoroughly and regularly?

Slight dust accumulation  
was observed on  
environmental surfaces at  
the time of assessment.

Site based administration should address general Site  
cleanliness with facility serviceperson staff.

GENERAL  
CLEANLINESS

Air supply/return registers are  
cleaned regularly and free of dust  
and debris accumulation?

No dust observed on  
supply/return registers at  
the time of assessment.

GENERAL  
CLEANLINESS

Floor is cleaned on a regular basis?

Dust and dirt accumulation  
on floor.

Facilities serviceperson to thoroughly clean and Site  
sanitize.

EXCESS  
MOISTURE IN  
CLASSROOMS

Windows, windowsills and window  
frames free of continuous  
condensation?

No condensation on  
windows at the time of  
assessment.

THERMAL  
COMFORT

Room is free of the introduction of  
outdoor air? (Gaps in window/door  
frames.)

Gaps in doors identified at  
the time of assessment.

Physical Plant Operations to evaluate and repair PPO  
as appropriate.

**THERMAL COMFORT** Room is usually comfortable? (If no, please explain in the notes below.) Environmental parameters were not within acceptable range at the time of assessment. CO2 level was elevated. Physical Plant Operations to evaluate and repair as appropriate to lower CO2 level. PPO

**AIR CONDITIONING** Room is free of smell of mold or mildew? No microbial growth identified. No odor identified at the time of assessment.

Room	Section	Question	Answer	Recommendation	Responsible
401	Inside Parameters:	Temp	RH	CO2	
		72.5	55.1	1411	

**GENERAL CLEANLINESS** Classroom is dusted/vacuumed thoroughly and regularly? There does not appear to be a dusting issue within this room. CO2 level was elevated. Physical Plant Operations to evaluate and repair as appropriate to lower CO2 level. PPO

**GENERAL CLEANLINESS** Floor is cleaned on a regular basis? Dust and dirt accumulation on floor. Facilities serviceperson to thoroughly clean and sanitize. Site

Room	Section	Question	Answer	Recommendation	Responsible
402	Inside Parameters:	Temp	RH	CO2	
		73.2	51.6	561	

**GENERAL CLEANLINESS** Classroom is dusted/vacuumed thoroughly and regularly? There does not appear to be a dusting issue within this room.

**GENERAL CLEANLINESS** Air supply/return registers are cleaned regularly and free of dust and debris accumulation? No dust observed on supply/return registers at the time of assessment.

**GENERAL CLEANLINESS** Room is free of pests? No pests observed at the time of assessment.

**GENERAL CLEANLINESS** Floor is cleaned on a regular basis? Floor was clean at the time of assessment.

**DRAIN TRAPS IN THE CLASSROOM** Water poured down floor drains once per week (approx. 1 quart of water). No floor drain in room.

**EXCESS MOISTURE IN CLASSROOMS** Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)? No leaks or signs of water intrusion identified.

AIR  
CONDITIONING

Room is free of smell of mold or  
mildew?

No microbial growth  
identified. No odor  
identified at the time of  
assessment.

Room	Section	Question	Answer	Recommendation	Responsible
403	Inside Parameters:	Temp 73.5	RH 57.7	CO2 1598	

GENERAL  
CLEANLINESS

Classroom is dusted/vacuumed  
thoroughly and regularly?

There does not appear to be  
a dusting issue within this  
room. CO level was  
elevated.

Physical Plant Operations to evaluate and repair PPO  
as appropriate to lower CO2 level.

GENERAL  
CLEANLINESS

Floor is cleaned on a regular basis?

Floor was clean at the time  
of assessment.

Room	Section	Question	Answer	Recommendation	Responsible
405	Inside Parameters:	Temp 73.3	RH 54.3	CO2 1306	

GENERAL  
CLEANLINESS

Classrooms general appearance is  
clean and acceptable?

General cleanliness of the  
room at the time of  
assessment was acceptable.

GENERAL  
CLEANLINESS

Classroom is dusted/vacuumed  
thoroughly and regularly?

Slight dust accumulation  
was observed on  
environmental surfaces at  
the time of assessment.

Site based administration should address general Site  
cleanliness with facility serviceperson staff.

GENERAL  
CLEANLINESS

Room is free of pests?

No pests observed at the  
time of assessment.

GENERAL  
CLEANLINESS

Spills and other such issues  
requiring custodial assistance are  
addressed in a timely manner?

No issues identified  
relating to spill clean up  
practices at the time of  
assessment..

GENERAL  
CLEANLINESS

Floor is cleaned on a regular basis?

Dust and dirt accumulation  
on floor.

Facilities serviceperson to thoroughly clean and Site  
sanitize.

ANIMALS IN THE  
CLASSROOM

Activities and/or room conditions  
are modified to address student  
allergies?

This is a general issue  
requiring approved  
communication among all  
stakeholders.

Site based administration is encouraged to Site  
communicate all known student allergies to the  
appropriate personnel in order to modify  
classroom activities/conditions when necessary.

THERMAL  
COMFORT

Classroom is free of significant  
temperature shifts?

Temperature was  
acceptable at the time of  
assessment.

THERMAL  
COMFORT

Room is usually comfortable? (If no, please explain in the notes below.)

Environmental parameters were not within acceptable range at the time of assessment.. CO2 level was elevated.

Physical Plant Operations to evaluate and repair PPO as appropriate to lower CO2 level.

Room	Section	Question	Answer	Recommendation	Responsible
407	Inside Parameters:	Temp	RH	CO2	
		70.4	48.5	1308	

GENERAL  
CLEANLINESS

Classrooms general appearance is clean and acceptable?

General cleanliness of the room at the time of assessment was acceptable.

GENERAL  
CLEANLINESS

Room is free of pests?

No pests observed at the time of assessment. CO2 level was elevated.

Physical Plant Operations to evaluate and repair PPO as appropriate to lower CO2 level.

GENERAL  
CLEANLINESS

Floor is cleaned on a regular basis?

Dust and dirt accumulation on floor.

Facilities serviceperson to thoroughly clean and Site sanitize.

Room	Section	Question	Answer	Recommendation	Responsible
409	Inside Parameters:	Temp	RH	CO2	
		71.5	58.4	1182	

GENERAL  
CLEANLINESS

Classroom is dusted/vacuumed thoroughly and regularly?

There does not appear to be a dusting issue within this room.

GENERAL  
CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

No dust observed on supply/return registers at the time of assessment.

GENERAL  
CLEANLINESS

Floor is cleaned on a regular basis?

Floor was clean at the time of assessment.

EXCESS  
MOISTURE IN  
CLASSROOMS

Windows, windowsills and window frames free of continuous condensation?

No windows in room.

THERMAL  
COMFORT

Temperature in my classroom is generally comfortable (72F- 76F)?

Temperature was acceptable at time of assessment. CO2 level was elevated.

Physical Plant Operations to evaluate and repair PPO as appropriate to lower CO2 level.

AIR  
CONDITIONING

Room is free of smell of kitchen/food?

No odor detected at the time of assessment.

## AIR

Room is free of smell of mold or

No microbial growth

CONDITIONING mildew?

identified. No odor identified at the time of assessment.

Room	Section	Question	Answer	Recommendation	Responsible
412	Inside Parameters:	Temp 73.8	RH 43.9	CO2 1264	
	GENERAL CLEANLINESS	Classroom is dusted/vacuumed thoroughly and regularly?	There does not appear to be a dusting issue within this room. CO2 level was elevated.	Physical Plant Operations to evaluate and repair as appropriate to lower CO2 level.	PPO
	GENERAL CLEANLINESS	Floor is cleaned on a regular basis?	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize.	Site

Room	Section	Question	Answer	Recommendation	Responsible
417	Inside Parameters:	Temp 72.6	RH 47.8	CO2 1143	
	THERMAL COMFORT	Temperature in my classroom is generally comfortable (72F- 76F)?	Temperature was acceptable at time of assessment.		
	THERMAL COMFORT	Room is usually comfortable? (If no, please explain in the notes below.)	Environmental parameters were not within acceptable range at the time of assessment. CO2 level was elevated.	Physical Plant Operations to evaluate and repair as appropriate to lower CO2 level.	PPO