

Rickards Middle

IAQ Walkthrough 5/17/2005

2121

Outside Temp RH% CO2

FISH/Room	Participant Comments	Response	Recommendation	Responsible	Priority
071N	Temp <input type="text" value="83.6"/> RH% <input type="text" value="46.2"/> CO2 <input type="text" value="1403"/>	Occupants: <input type="text"/>			
AIR CONDITIONING					
	Room is free of smell of mold or mildew?	Odor detected at the time of assessment.	Physical Plant Operations to evaluate cause of odor.	Physical Plant Operations	1
ANIMALS IN THE CLASSROOM					
	Activities and/or room conditions are modified to address student allergies?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
EXCESS MOISTURE IN CLASSROOMS					
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?	Signs of water intrusion. Leak identified.	Physical Plant Operations to evaluate for roof leaks and repair as appropriate.	Physical Plant Operations	1
	Indoor surfaces of exterior walls free of continuous condensation?	No condensation at the time of assessment.	None		
	Windows, windowsills and window frames free of continuous condensation?	Condensation on windows at the time of assessment. Temperature was not within acceptable range and leaks were identified.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	1
GENERAL CLEANLINESS					
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Portable has termites. Termites leave their remains (little poppy seed looking beads). These are all over shelves, floors, tables, window sills, etc. It needs to be cleaned on a daily basis, but is not, and I have to do it myself, weekly.	Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	Classroom is dusted/vacuumed thoroughly and regularly?	Portable has termites. Termites leave their remains (little poppy seed looking beads). These are all over shelves, floors, tables, window sills, etc. It needs to be cleaned on a daily basis, but is not, and I have to do it myself, weekly.	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
<i>071N</i>	Temp	83.6	RH% 46.2	CO2 1403	Occupants:		
Room is free of pests?	Portable has termites. Termites leave their remains (little poppy seed looking beads). These are all over shelves, floors, tables, window sills, etc. It needs to be cleaned on a daily basis, but is not, and I have to do it myself, weekly.			Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations	2
Room is free of the use of scented cleaners and air fresheners?	Portable has termites. Termites leave their remains (little poppy seed looking beads). These are all over shelves, floors, tables, window sills, etc. It needs to be cleaned on a daily basis, but is not, and I have to do it myself, weekly.			Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	2
THERMAL COMFORT							
Room is free of the introduction of outdoor air? (Gaps in window/door frames.)				Gaps in windows or doors identified at the time of assessment.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
Walkthrough							
				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	2
<i>084</i>	Temp	81.8	RH% 49.8	CO2 1019	Occupants:		
AIR CONDITIONING							
Room is free of smell of mold or mildew?	mold behind whiteboard			No odor detected at the time of assessment.	None		
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?	Mold behind the whiteboard from dripping airconditioner. It has been there since last year. I put in a request at the end of last year to have it fixed and it was never done.			There does not appear to be a dusting issue within this room.	None		
Floor is cleaned on a regular basis?	Mold behind the whiteboard from dripping airconditioner. It has been there since last year. I put in a request at the end of last year to have it fixed and it was never done.			Floor was clean at the time of assessment.	None		
Room is free of pests?	Mold behind the whiteboard from dripping airconditioner. It has been there since last year. I put in a request at the end of last year to have it fixed and it was never done.			No pests observed at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
084	Temp	81.8	RH%	49.8	CO2	1019	Occupants:				
	Room is free of the use of scented cleaners and air fresheners?		Mold behind the whiteboard from dripping airconditioner. It has been there since last year. I put in a request at the end of last year to have it fixed and it was never done.	No scented cleaners, air fresheners or non-approved chemicals found at the time of assessment.	None						
105	Temp	72.0	RH%	58.1	CO2	652	Occupants:				
	AIR CONDITIONING										
	Windows/doors are operable and are kept closed?			Windows and doors are operable and are kept closed.	None						
	ANIMALS IN THE CLASSROOM										
	Activities and/or room conditions are modified to address student allergies?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based					3
	EXCESS MOISTURE IN CLASSROOMS										
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based					2
	GENERAL CLEANLINESS										
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None						
	Classrooms general appearance is clean and acceptable?			General cleanliness of the room at the time of assessment was acceptable.	None						
	Floor is cleaned on a regular basis?			Floor was clean at the time of assessment.	None						
	Room is free of pests?			No pests observed at the time of assessment.	None						
	LOCAL EXHAUST FANS										
	Bathroom exhaust fan is functioning properly?			Bathroom exhaust fan is functioning properly.	None						
	THERMAL COMFORT										
	Classroom is free of significant temperature shifts?		IT HAS BEEN LATELY. AT TIMES THE TEMPERATURE IS VERY COLD, often too cold or too hot	Temperature was acceptable at the time of assessment. Occupant advised that temperature fluctuates.	Facilities serviceperson should monitor this room.	Site Based					2
	Room is usually comfortable? (If no, please explain in the notes below.)		IT HAS BEEN LATELY. AT TIMES THE TEMPERATURE IS VERY COLD, often too cold or too hot	Temperature was acceptable at the time of assessment.	None						

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
105	Temp	72.0	RH%	58.1	CO2	652	Occupants:				
	Temperature in my classroom is generally comfortable (72F-76F)?		IT HAS BEEN LATELY. AT TIMES THE TEMPERATURE IS VERY COLD, often too cold or too hot	Temperature was acceptable at the time of assessment.	None						
105A	Temp	70.8	RH%	61.7	CO2	747	Occupants:	4			
	GENERAL CLEANLINESS										
	Floor is cleaned on a regular basis?						Replace carpet.		Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	2
	Room is free of pests?						No pests observed at the time of assessment.		None		
	LOCAL EXHAUST FANS										
	Bathroom exhaust fan is functioning properly?						Bathroom exhaust fan is functioning properly.		None		
	THERMAL COMFORT										
	Classroom is free of significant temperature shifts?		Office is often much too cold or much too hot.				Temperature was acceptable at the time of assessment.		None		
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		Office is often much too cold or much too hot.				Humidity was slightly elevated at the time of assessment - 10% greater than outdoors.		Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	2
	Room is usually comfortable? (If no, please explain in the notes below.)		Office is often much too cold or much too hot.				Temperature was acceptable at the time of assessment.		None		
	Temperature in my classroom is generally comfortable (72F-76F)?		Office is often much too cold or much too hot.				Temperature was low at the time of assessment.		Facilities serviceperson should monitor this room.	Site Based	2
105B	Temp	72.1	RH%	57.0	CO2	678	Occupants:				
	GENERAL CLEANLINESS										
	Classroom is dusted/vacuumed thoroughly and regularly?		carpets are in this office....need to be vacuumed several times per week due to amt. of traffic				Slight dust accumulation was observed on environmental surfaces at the time of assessment.		Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Floor is cleaned on a regular basis?		carpets are in this office....need to be vacuumed several times per week due to amt. of traffic				Replace existing carpet.		Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations	2
	THERMAL COMFORT										
	Classroom is free of significant temperature shifts?		This office is warmer than almost any other location in the building. The humidity in here is often high...so is the rest of the building-particularly when it is humid outside.				Temperature was acceptable at the time of assessment.		None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
105B	Temp	<input type="text" value="72.1"/>	RH%	<input type="text" value="57.0"/>	CO2	<input type="text" value="678"/>	Occupants:	<input type="text"/>
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	This office is warmer than almost any other location in the building. The humidity in here is often high...so is the rest of the building-particularly when it is humid outside.			Humidity was acceptable at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)	This office is warmer than almost any other location in the building. The humidity in here is often high...so is the rest of the building-particularly when it is humid outside.			Temperature was acceptable at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?	This office is warmer than almost any other location in the building. The humidity in here is often high...so is the rest of the building-particularly when it is humid outside.			Temperature was acceptable at the time of assessment.	None		
105C	Temp	<input type="text" value="71.7"/>	RH%	<input type="text" value="58.6"/>	CO2	<input type="text" value="691"/>	Occupants:	<input type="text"/>
	THERMAL COMFORT							
	Classroom is free of significant temperature shifts?				Temperature was acceptable at the time of assessment.	None		
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)				Humidity was acceptable at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)				Temperature was acceptable at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?				Temperature was acceptable at the time of assessment.	None		
	Walkthrough							
					Remove existing carpeting	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations	2
105D	Temp	<input type="text" value="72.2"/>	RH%	<input type="text" value="57.1"/>	CO2	<input type="text" value="656"/>	Occupants:	<input type="text"/>
	AIR CONDITIONING							
	Windows/doors are operable and are kept closed?	I have no windows.			Windows and doors are operable and are kept closed.	None		
	LOCAL EXHAUST FANS							
	Bathroom exhaust fan is functioning properly?	I have no exhaust fans.			Bathroom exhaust fan is functioning properly.	None		
	Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)	I have no exhaust fans.			It appears that the ventilation system is adequate based on room activities.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
105D	Temp	<input type="text" value="72.2"/>	RH%	<input type="text" value="57.1"/>	CO2	<input type="text" value="656"/>	Occupants:	<input type="text"/>
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?		I have no exhaust fans.	It appears that the ventilation system is adequate based on room activities.	None			
	Other exhaust fans that may exist in the classroom are functioning properly?		I have no exhaust fans.	Exhaust fan is functioning properly.	None			
	THERMAL COMFORT							
	Classroom is free of significant temperature shifts?			Temperature was acceptable at the time of assessment.	None			
105H	Temp	<input type="text" value="71.5"/>	RH%	<input type="text" value="59.8"/>	CO2	<input type="text" value="741"/>	Occupants:	<input type="text"/>
	GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based		2
	Classroom is dusted/vacuumed thoroughly and regularly?			Replace existing carpet.	Physical Plant Operations to evaluate and repair/replace as appropriate.	Physical Plant Operations		2
106	Temp	<input type="text" value="71.9"/>	RH%	<input type="text" value="60.2"/>	CO2	<input type="text" value="687"/>	Occupants:	<input type="text" value="32"/>
	AIR CONDITIONING							
	Air is flowing without obstruction?			Air flowing without obstruction at the time of assessments.	None			
	Room is free of smell of chemicals?			No odor detected at the time of assessment.	None			
	Room is free of smell of kitchen/food?			No odor detected at the time of assessment.	None			
	Room is free of smell of mold or mildew?			No odor detected at the time of assessment.	None			
	Windows/doors are operable and are kept closed?			Windows and doors are operable and are kept closed.	None			
	ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based		3
	You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based		3
	DRAIN TRAPS IN THE CLASSROOM							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
106	Temp	71.9	RH% 60.2	CO2 687	Occupants: 32		
	Water poured down floor drains once per week (approx. 1 quart of water).				It appears as though water is poured down the floor drain at least once a week.	None	
	Water run in sinks at least once per week (about 2 cups of water).				It appears as though sink is utilized regularly. No sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.	None	
EXCESS MOISTURE IN CLASSROOMS							
	Indoor surfaces of exterior walls free of continuous condensation?				No condensation at the time of assessment.	None	
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				No dust observed on supply/return registers at the time of assessment.	None	
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	
	Food, if any, is stored in tightly sealed containers?				No unsealed food items were observed at the time of assessment.	None	
	Room is free of pests?				No pests observed at the time of assessment.	None	
	Room is free of the use of scented cleaners and air fresheners?				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based 2
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?				Temperatures range from 68 to 76 degrees. Computers in room make it even warmer on days of 76 degrees and humidity usually goes up also on those days., too cold. usually temperature is 68		
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)				Temperatures range from 68 to 76 degrees. Computers in room make it even warmer on days of 76 degrees and humidity usually goes up also on those days., too cold. usually temperature is 68	Humidity was acceptable at the time of assessment.	None
	Room is usually comfortable? (If no, please explain in the notes below.)				Temperatures range from 68 to 76 degrees. Computers in room make it even warmer on days of 76 degrees and humidity usually goes up also on those days., too cold. usually temperature is 68	Temperature was acceptable at the time of assessment.	None
	Temperature in my classroom is generally comfortable (72F-76F)?				Temperatures range from 68 to 76 degrees. Computers in room make it even warmer on days of 76 degrees and humidity usually goes up also on those days., too cold. usually temperature is 68	Temperature was acceptable at the time of assessment.	None

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
106	Temp	71.9	RH% 60.2	CO2 687	Occupants: 32		
Walkthrough				Ceiling tiles broken, damaged or missing.	Facilities serviceperson to replace damaged ceiling tiles.	Site Based	2
106A	Temp	70.6	RH% 67.8	CO2 518	Occupants:		
AIR CONDITIONING							
Room is free of smell of chemicals?				No odor detected at the time of assessment.	None		
Room is free of smell of kitchen/food?				There appears to be an issue regarding daily trash removal practices. Food identified in the trash can.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None		
DRAIN TRAPS IN THE CLASSROOM							
Water poured down floor drains once per week (approx. 1 quart of water).				It appears as though water is poured down the floor drain at least once a week.	None		
Water run in sinks at least once per week (about 2 cups of water).				It appears as though sink is utilized regularly. No sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.	None		
EXCESS MOISTURE IN CLASSROOMS							
Area around and under classroom sinks free of leaks?				Signs of water intrusion. Leak identified.	Physical Plant Operations to evaluate for leaks and repair as appropriate.	Physical Plant Operations	2
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Room is free of pests?				No pests observed at the time of assessment.	None		
THERMAL COMFORT							
Classroom is free of significant temperature shifts?			Some days the temperature runs around 69 degrees. Other days as low as 68 and as high as 76. For the Media Center 76 is generally too warm and our computers heat us up even more.	Temperature was low at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
106A	Temp	70.6	RH%	67.8	CO2	518	Occupants:	
Room is usually comfortable? (If no, please explain in the notes below.)	Some days the temperature runs around 69 degrees. Other days as low as 68 and as high as 76. For the Media Center 76 is generally too warm and our computers heat us up even more.			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based		2
Temperature in my classroom is generally comfortable (72F-76F)?	Some days the temperature runs around 69 degrees. Other days as low as 68 and as high as 76. For the Media Center 76 is generally too warm and our computers heat us up even more.			Temperature was low at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based		2
Walkthrough				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based		2
108	Temp	70.5	RH%	61.9	CO2	752	Occupants:	1
DRAIN TRAPS IN THE CLASSROOM								
Water run in sinks at least once per week (about 2 cups of water).	I have a portable sink and do not pour water down the drain unless I need to.			It appears as though water is poured down the floor drain at least once a week.	None			
THERMAL COMFORT								
Classroom is free of significant temperature shifts?	The classroom is too cold on warmer days. Temperature shifts mentioned above are not shift within the day but are in reference to how warm the room is in the winter months and how cold it is for the other months.			Temperature was low at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based		2
Room is usually comfortable? (If no, please explain in the notes below.)	The classroom is too cold on warmer days. Temperature shifts mentioned above are not shift within the day but are in reference to how warm the room is in the winter months and how cold it is for the other months.			Temperature was low at the time of assessment.	Facilities serviceperson should monitor this room.	Physical Plant Operations		2
Temperature in my classroom is generally comfortable (72F-76F)?	The classroom is too cold on warmer days. Temperature shifts mentioned above are not shift within the day but are in reference to how warm the room is in the winter months and how cold it is for the other months.			Temperature was low at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based		2
Walkthrough				Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations		2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
109	Temp	70.5	RH% 63.0	CO2 791	Occupants: 9		
	EXCESS MOISTURE IN CLASSROOMS						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
110	Temp	71.9	RH% 61.3	CO2 921	Occupants: 26		
	GENERAL CLEANLINESS						
	Room is free of pests?			Ant problem	No pests observed at the time of assessment.	None	
111	Temp	74.1	RH% 56.5	CO2 776	Occupants: 1		
	ANIMALS IN THE CLASSROOM						
	Activities and/or room conditions are modified to address student allergies?			This is a general issue requiring approved communication among all stakeholders. Stuffed animals on teachers desk.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?			At this time my classroom is currently 64 degrees. I have a thermometer in my room. I have notified the school principal and a/c repairman have been here before, and I am told it will either be too cold or too hot and cannot be adjusted to a comfortable	Temperature was acceptable at the time of assessment.	None	
	Room is usually comfortable? (If no, please explain in the notes below.)			At this time my classroom is currently 64 degrees. I have a thermometer in my room. I have notified the school principal and a/c repairman have been here before, and I am told it will either be too cold or too hot and cannot be adjusted to a comfortable	Temperature was acceptable at the time of assessment.	None	
	Temperature in my classroom is generally comfortable (72F-76F)?			At this time my classroom is currently 64 degrees. I have a thermometer in my room. I have notified the school principal and a/c repairman have been here before, and I am told it will either be too cold or too hot and cannot be adjusted to a comfortable	Temperature was acceptable at the time of assessment.	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority					
111	Temp	74.1	RH%	56.5	CO2	776	Occupants:	1				
Walkthrough									Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
112	Temp	73.2	RH%	57.4	CO2	847	Occupants:	19				
THERMAL COMFORT									Temperature was acceptable at the time of assessment.	None		
Classroom is free of significant temperature shifts?												
Walkthrough									Ceiling tiles broken, damaged or missing.	Facilities serviceperson to replace damaged ceiling tiles.	Site Based	2
113	Temp	73.4	RH%	54.5	CO2	912	Occupants:	26				
THERMAL COMFORT									Temperature was acceptable at the time of assessment.	None		
Classroom is free of significant temperature shifts?									Unfortunately, the room temp is often too cold or too warm. I am unable to control temp in any way. Students complain frequently .			
Room is usually comfortable? (If no, please explain in the notes below.)									Unfortunately, the room temp is often too cold or too warm. I am unable to control temp in any way. Students complain frequently .			
Temperature in my classroom is generally comfortable (72F-76F)?									Unfortunately, the room temp is often too cold or too warm. I am unable to control temp in any way. Students complain frequently .			
Walkthrough									Dust and debris identified in locker room and showers at the time of assessment.	Facilities serviceperson to replace soiled ceiling tiles.	Site Based	2
114	Temp	71.6	RH%	60.4	CO2	866	Occupants:	15				
EXCESS MOISTURE IN CLASSROOMS									Dust and debris on ceiling tiles.	Facilities serviceperson to replace soiled ceiling tiles.	Site Based	2
Indoor surfaces of exterior walls free of continuous condensation?												

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
115	Temp	72.2	RH% 59.6	CO2 910	Occupants: 18		
GENERAL CLEANLINESS							
Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None		
THERMAL COMFORT							
Classroom is free of significant temperature shifts?			It is too cold.	Temperature was acceptable at the time of assessment.	None		
Room is usually comfortable? (If no, please explain in the notes below.)			It is too cold.	Temperature was acceptable at the time of assessment.	None		
Temperature in my classroom is generally comfortable (72F-76F)?			It is too cold.	Temperature was acceptable at the time of assessment.	None		
Walkthrough							
				Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
118	Temp	72.4	RH% 60.1	CO2 979	Occupants: 28		
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
THERMAL COMFORT							
Classroom is free of significant temperature shifts?				Temperature was acceptable at the time of assessment.	None		
Temperature in my classroom is generally comfortable (72F-76F)?				Temperature was acceptable at the time of assessment.	None		
Walkthrough							
				Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

119

Temp RH% CO2 Occupants:

AIR CONDITIONING

Air flowing from air supply?

Air flowing without obstruction at the time of assessments. None

Air is flowing without obstruction?

Air flowing without obstruction at the time of assessments. None

EXCESS MOISTURE IN CLASSROOMS

Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?

Stained ceiling tiles. Facilities serviceperson to replace stained ceiling tiles. Site Based 2

GENERAL CLEANLINESS

Room is free of the use of scented cleaners and air fresheners?

No scented cleaners, air fresheners or non-approved chemicals found at the time of assessment. None

THERMAL COMFORT

Classroom is free of significant temperature shifts?

My classroom is freezing. I have to wear sweaters plus a jacket 4 out of 5 days in the week.

Temperature was acceptable at the time of assessment. None

Room is usually comfortable? (If no, please explain in the notes below.)

My classroom is freezing. I have to wear sweaters plus a jacket 4 out of 5 days in the week.

Temperature was acceptable at the time of assessment. None

Temperature in my classroom is generally comfortable (72F-76F)?

My classroom is freezing. I have to wear sweaters plus a jacket 4 out of 5 days in the week.

Temperature was acceptable at the time of assessment. None

Walkthrough

Stained ceiling tiles. Facilities serviceperson to replace stained ceiling tiles. Site Based 2

121

Temp RH% CO2 Occupants:

THERMAL COMFORT

Classroom is free of significant temperature shifts?

Sometimes the room is extremely cold and at other times its warm.

Temperature was acceptable at the time of assessment. None

Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)

Sometimes the room is extremely cold and at other times its warm.

Humidity was slightly elevated at the time of assessment - 10% greater than outdoors. Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level. Physical Plant Operations 2

Walkthrough

Pests observed at the time of assessment. Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action. Physical Plant Operations 2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
121	Temp	<input type="text" value="72.1"/>	RH% <input type="text" value="63.6"/>	CO2 <input type="text" value="920"/>	Occupants: <input type="text" value="24"/>			
126	Temp	<input type="text" value="72.1"/>	RH% <input type="text" value="62.3"/>	CO2 <input type="text" value="990"/>	Occupants: <input type="text" value="23"/>			
THERMAL COMFORT								
	Room is usually comfortable? (If no, please explain in the notes below.)	It is usually too cold. Average temperature is 68 degrees.			Temperature was acceptable at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?	It is usually too cold. Average temperature is 68 degrees.			Temperature was acceptable at the time of assessment.	None		
128	Temp	<input type="text" value="73.1"/>	RH% <input type="text" value="60.2"/>	CO2 <input type="text" value="821"/>	Occupants: <input type="text" value="1"/>			
GENERAL CLEANLINESS								
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				No dust observed on supply/return registers at the time of assessment.	None		
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None		
	Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None		
THERMAL COMFORT								
	Classroom is free of significant temperature shifts?				Temperature was acceptable at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)				Temperature was acceptable at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?				Temperature was acceptable at the time of assessment.	None		
137	Temp	<input type="text" value="73.1"/>	RH% <input type="text" value="60.9"/>	CO2 <input type="text" value="1443"/>	Occupants: <input type="text" value="19"/>			
ANIMALS IN THE CLASSROOM								
	Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
GENERAL CLEANLINESS								

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
137	Temp	73.1	RH% 60.9	CO2 1443	Occupants: 19		
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				No dust observed on supply/return registers at the time of assessment.	None	
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?				Temperature was acceptable at the time of assessment.	None	
	Temperature in my classroom is generally comfortable (72F-76F)?				Temperature was acceptable at the time of assessment.	None	
138	Temp	72.4	RH% 61.5	CO2 802	Occupants: 2		
	THERMAL COMFORT						
	Room is usually comfortable? (If no, please explain in the notes below.)		Room is often too cold.		Temperature was acceptable at the time of assessment.	None	
	Temperature in my classroom is generally comfortable (72F-76F)?		Room is often too cold.		Temperature was acceptable at the time of assessment.	None	
140	Temp	72.1	RH% 65.8	CO2 793	Occupants: 13		
	ANIMALS IN THE CLASSROOM						
	Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
	EXCESS MOISTURE IN CLASSROOMS						
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based 2
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?		My room is usually very cold - I wear a jacket almost every day.		Temperature was acceptable at the time of assessment.	None	
	Room is usually comfortable? (If no, please explain in the notes below.)		My room is usually very cold - I wear a jacket almost every day.		Temperature was acceptable at the time of assessment.	None	
	Temperature in my classroom is generally comfortable (72F-76F)?		My room is usually very cold - I wear a jacket almost every day.		Temperature was acceptable at the time of assessment.	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
141	Temp	73.1	RH% 62.9	CO2 915	Occupants: 2			
GENERAL CLEANLINESS								
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.	None			
	Room is free of pests?			Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations	2	
THERMAL COMFORT								
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		This room is generally very cold (below 72 degrees)		Humidity was slightly elevated at the time of assessment - 10% greater than outdoors.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	2
	Room is usually comfortable? (If no, please explain in the notes below.)		This room is generally very cold (below 72 degrees)		Temperature was acceptable at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?		This room is generally very cold (below 72 degrees)		Temperature was acceptable at the time of assessment.	None		
143	Temp	72.4	RH% 64.3	CO2 911	Occupants: 18			
AIR CONDITIONING								
	Room is free of smell of mold or mildew?		My room smelled of mildew in the beginning of the year. I used Damp Rid and took a lot of the moisture out. My closet in the back of the room constantly smells of mold or mildew. It has a very strong scent that is not pleasing.		No odor detected at the time of assessment.	None		
ANIMALS IN THE CLASSROOM								
	Activities and/or room conditions are modified to address student allergies?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3	
	You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3	
THERMAL COMFORT								
	Classroom is free of significant temperature shifts?		sometimes cold but I am not complaining. Its better than a warm classroom		Temperature was acceptable at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?		sometimes cold but I am not complaining. Its better than a warm classroom		Temperature was acceptable at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
143	Temp	72.4	RH% 64.3	CO2 911	Occupants: 18		
144	Temp	72.1	RH% 65.6	CO2 814	Occupants: 17		
DRAIN TRAPS IN THE CLASSROOM							
Water poured down floor drains once per week (approx. 1 quart of water).				It appears as though water is poured down the floor drain at least once a week.	None		
Water run in sinks at least once per week (about 2 cups of water).				It appears as though sink is utilized regularly. No sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.	None		
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
THERMAL COMFORT							
Classroom is free of significant temperature shifts?			My room is too cold. The children are uncomfortable and so am I.	Temperature was acceptable at the time of assessment.	None		
Room is usually comfortable? (If no, please explain in the notes below.)			My room is too cold. The children are uncomfortable and so am I.	Temperature was acceptable at the time of assessment.	None		
Temperature in my classroom is generally comfortable (72F-76F)?			My room is too cold. The children are uncomfortable and so am I.	Temperature was acceptable at the time of assessment.	None		
146	Temp	71.1	RH% 64.4	CO2 954	Occupants: 25		
AIR CONDITIONING							
Room is free of smell of mold or mildew?			I was not issued a tissue to preform the test indicated in questions A & B	Odor detected at the time of assessment.	Physical Plant Operations to evaluate cause of odor.	Physical Plant Operations	1
ANIMALS IN THE CLASSROOM							
Classroom is free of animals and pets?				No animals identified at the time of assessment.	None		
LOCAL EXHAUST FANS							
Bathroom exhaust fan is functioning properly?			No Bathroom in Room	No bathroom. Identified in error.	None		
Indoor classroom activities do not cause problems with excessive fumes? (If no, please explain in notes section)			No Bathroom in Room	No bathroom. Identified in error.	None		
THERMAL COMFORT							

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
146	Temp	71.1	RH% 64.4	CO2 954	Occupants: 25			
	Classroom is free of significant temperature shifts?	Temperatures vary greatly			Temperature was low at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based	2
	Room is usually comfortable? (If no, please explain in the notes below.)	Temperatures vary greatly			Temperature was low at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based	2
	Temperature in my classroom is generally comfortable (72F-76F)?	Temperatures vary greatly			Temperature was low at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based	2
151	Temp	69.9	RH% 67.3	CO2 909	Occupants: 26			
	ANIMALS IN THE CLASSROOM							
	You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	EXCESS MOISTURE IN CLASSROOMS							
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based	2
152	Temp	70.9	RH% 66.8	CO2 864	Occupants: 18			
	DRAIN TRAPS IN THE CLASSROOM							
	Water poured down floor drains once per week (approx. 1 quart of water).				It appears as though water is poured down the floor drain at least once a week.	None		
	Water run in sinks at least once per week (about 2 cups of water).				It appears as though sink is utilized regularly. No sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.	None		
	LOCAL EXHAUST FANS							
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?	Science room without fume hood.			It appears that the ventilation system is adequate based on room activities.	None		
	THERMAL COMFORT							
	Room is usually comfortable? (If no, please explain in the notes below.)	Many students say it is too cold (I sometimes agree).			Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
153	Temp	71.7	RH% 68.4	CO2 887	Occupants: 26		
AIR CONDITIONING							
Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None		
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
DRAIN TRAPS IN THE CLASSROOM							
Water poured down floor drains once per week (approx. 1 quart of water).				It appears as though water is poured down the floor drain at least once a week.	None		
Water run in sinks at least once per week (about 2 cups of water).				It appears as though sink is utilized regularly. No sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.	None		
EXCESS MOISTURE IN CLASSROOMS							
Area around and under classroom sinks free of leaks?				No leaks or signs of water intrusion identified.	None		
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				No leaks or signs of water intrusion identified.	None		
Classroom lavatories/water fountains free of leaks?				No lavatories/water fountains in room.	None		
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				No dust observed on supply/return registers at the time of assessment.	None		
Room is free of pests?				No pests observed at the time of assessment.	None		
LOCAL EXHAUST FANS							
Bathroom exhaust fan is functioning properly?				No bathroom. Identified in error.	None		
THERMAL COMFORT							
Classroom is free of significant temperature shifts?		Average Temperature 64 F		Temperature was low at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based	2
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)		Average Temperature 64 F		Humidity was slightly elevated at the time of assessment - 10% greater than outdoors.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	2
Room is free of the introduction of outdoor air? (Gaps in window/door frames.)		Average Temperature 64 F		No gaps in windows or doors identified at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
153	Temp	71.7	RH%	68.4	CO2	887	Occupants:	26			
	Room is usually comfortable? (If no, please explain in the notes below.)	Average Temperature 64 F			Temperature was low at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based		2		
	Temperature in my classroom is generally comfortable (72F-76F)?	Average Temperature 64 F			Temperature was low at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based		2		
154	Temp	72.5	RH%	65.2	CO2	806	Occupants:				
	ANIMALS IN THE CLASSROOM										
	Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based		3		
	You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based		3		
EXCESS MOISTURE IN CLASSROOMS											
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based		2		
GENERAL CLEANLINESS											
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				No dust observed on supply/return registers at the time of assessment.	None					
	Room is free of pests?				No pests observed at the time of assessment.	None					
154C	Temp	73.9	RH%	63.7	CO2	747	Occupants:	24			
	AIR CONDITIONING										
	Room is free of smell of mold or mildew?				Supply and return vents closed at the time of assessment.	Facilities serviceperson to open supply and return vents.	Site Based		2		
EXCESS MOISTURE IN CLASSROOMS											
	Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?				Stained ceiling tiles.	Facilities serviceperson to replace stained ceiling tiles.	Site Based		2		
GENERAL CLEANLINESS											
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				No dust observed on supply/return registers at the time of assessment.	None					

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

154C

Temp RH% CO2 Occupants:

Classroom is dusted/vacuumed thoroughly and regularly?		This is a general issue requiring approved communication among all stakeholders.	None
Floor is cleaned on a regular basis?		Floor was clean at the time of assessment.	None
Room is free of pests?		No pests observed at the time of assessment.	None

THERMAL COMFORT

Classroom is free of significant temperature shifts?	too cold average temp. 64 F	Temperature was acceptable at the time of assessment.	None
Room is usually comfortable? (If no, please explain in the notes below.)	too cold average temp. 64 F	Temperature was acceptable at the time of assessment.	None
Temperature in my classroom is generally comfortable (72F-76F)?	too cold average temp. 64 F	Temperature was acceptable at the time of assessment.	None

162

Temp RH% CO2 Occupants:

AIR CONDITIONING

Room is free of smell of chemicals?	Periodically at the end of the day the room will get a smell of sewer which is a result from the hallway towards the back of the room.	No odor detected at the time of assessment.	None
-------------------------------------	--	---	------

GENERAL CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?	Registers were supposed to be cleaned last year during a planning day. The custodian set up the stuff but never cleaned them. Since then they have Black Markings around the registers.	Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Classroom is dusted/vacuumed thoroughly and regularly?	Registers were supposed to be cleaned last year during a planning day. The custodian set up the stuff but never cleaned them. Since then they have Black Markings around the registers.	There does not appear to be a dusting issue within this room.		None	
Classrooms general appearance is clean and acceptable?	Registers were supposed to be cleaned last year during a planning day. The custodian set up the stuff but never cleaned them. Since then they have Black Markings around the registers.	General cleanliness of the room at the time of assessment was acceptable.		None	
Room is free of pests?	Registers were supposed to be cleaned last year during a planning day. The custodian set up the stuff but never cleaned them. Since then they have Black Markings around the registers.	No pests observed at the time of assessment.		None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

166

Temp RH% CO2 Occupants:

AIR CONDITIONING

Room is free of smell of chemicals?	The room smells from mildew and once in a while there is a chemical/gas like smell that takes my breath away.	No odor detected at the time of assessment.	None
Room is free of smell of mold or mildew?	The room smells from mildew and once in a while there is a chemical/gas like smell that takes my breath away.	No odor detected at the time of assessment.	None

EXCESS MOISTURE IN CLASSROOMS

Indoor surfaces of exterior walls free of continuous condensation?		No condensation at the time of assessment.	None
--	--	--	------

GENERAL CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?		No dust observed on supply/return registers at the time of assessment.	None
Classroom is dusted/vacuumed thoroughly and regularly?		There does not appear to be a dusting issue within this room.	None

THERMAL COMFORT

Classroom is free of significant temperature shifts?	Room is humid most of the time. There is mold growing on walls. Room is full of dust.	Temperature was elevated at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based	2
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Room is humid most of the time. There is mold growing on walls. Room is full of dust.	General cleanliness of the room at the time of assessment was not acceptable.	None		
Room is usually comfortable? (If no, please explain in the notes below.)	Room is humid most of the time. There is mold growing on walls. Room is full of dust.	Temperature was acceptable at the time of assessment.	None		

167

Temp RH% CO2 Occupants:

AIR CONDITIONING

Room is free of smell of kitchen/food?		No odor detected at the time of assessment.	None
--	--	---	------

GENERAL CLEANLINESS

Classroom is dusted/vacuumed thoroughly and regularly?	Area around my desk is very rarely swept.	There does not appear to be a dusting issue within this room.	None		
Floor is cleaned on a regular basis?	Area around my desk is very rarely swept.	Dust and dirt accumulation on floor. Floor needs wax.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Room is free of pests?	Area around my desk is very rarely swept.	No pests observed at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
167	Temp	76.5	RH%	51.1	CO2	978	Occupants:	2			
	Room is free of the use of scented cleaners and air fresheners?	Area around my desk is very rarely swept.			No scented cleaners, air fresheners or non-approved chemicals found at the time of assessment.	None					
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?	Area around my desk is very rarely swept.			No issues identified relating to spill clean up practices at the time of assessment..	None					
	THERMAL COMFORT										
	Classroom is free of significant temperature shifts?	I see humidity rise especially after returning from a weekend or break. This room tends to be significantly warmer during the warmer months than the rest of the school.			Supply vents closed at the time of assessment.	None					
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	I see humidity rise especially after returning from a weekend or break. This room tends to be significantly warmer during the warmer months than the rest of the school.			Humidity was acceptable at the time of assessment.	None					
	Room is usually comfortable? (If no, please explain in the notes below.)	I see humidity rise especially after returning from a weekend or break. This room tends to be significantly warmer during the warmer months than the rest of the school.			Temperature was acceptable at the time of assessment.	None					
	Temperature in my classroom is generally comfortable (72F-76F)?	I see humidity rise especially after returning from a weekend or break. This room tends to be significantly warmer during the warmer months than the rest of the school.			Temperature was acceptable at the time of assessment.	None					
168	Temp	74.8	RH%	53.7	CO2	1045	Occupants:	27			
	DRAIN TRAPS IN THE CLASSROOM										
	Water run in sinks at least once per week (about 2 cups of water).				It appears as though water is poured down the floor drain at least once a week.	None					
	GENERAL CLEANLINESS										
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				No dust observed on supply/return registers at the time of assessment.	None					
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None					
	THERMAL COMFORT										
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)				Humidity was acceptable at the time of assessment.	None					

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
175B	Temp	76.0	RH% 55.5	CO2 935	Occupants:		
ANIMALS IN THE CLASSROOM							
You are informed about the potential allergies of your students?			This is a general issue requiring approved communication among all stakeholders.		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.		Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
LOCAL EXHAUST FANS							
Bathroom exhaust fan is functioning properly?			Bathroom exhaust fan is functioning properly.		None		
Other exhaust fans that may exist in the classroom are functioning properly?			Exhaust fan is functioning properly.		None		
183	Temp	69.0	RH% 58.6	CO2 874	Occupants:	21	
AIR CONDITIONING							
Room is free of smell of kitchen/food?			No odor detected at the time of assessment.		None		
ANIMALS IN THE CLASSROOM							
Activities and/or room conditions are modified to address student allergies?			Occasionally informed about student allergy issues. Have never modified for student allergies.		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
EXCESS MOISTURE IN CLASSROOMS							
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?			Signs of water intrusion. Leak identified.		Physical Plant Operations to evaluate for roof leaks and repair as appropriate.	Physical Plant Operations	1
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			No dust observed on supply/return registers at the time of assessment.		None		
185	Temp	71.5	RH% 57.9	CO2 979	Occupants:	31	
AIR CONDITIONING							
Windows/doors are operable and are kept closed?			Have no window in my classroom.		No windows in room.	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
185	Temp	71.5	RH% 57.9	CO2 979	Occupants: 31		
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?	Room is very cold many times.		Temperature was acceptable at the time of assessment.	None		
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)	Room is very cold many times.		Humidity was acceptable at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)	Room is very cold many times.		Temperature was acceptable at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?	Room is very cold many times.		Temperature was acceptable at the time of assessment.	None		
186	Temp	70.5	RH% 59.8	CO2 854	Occupants: 1		
AIR CONDITIONING							
	Room is free of smell of mold or mildew?			No odor detected at the time of assessment.	None		
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
GENERAL CLEANLINESS							
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None		
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?	The regular temperature of the room is very cold. Since the air conditioning system is turned off at nights and on weekends, there are significant temperature shifts throughout the week.		Temperature was low at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based	2
	Room is usually comfortable? (If no, please explain in the notes below.)	The regular temperature of the room is very cold. Since the air conditioning system is turned off at nights and on weekends, there are significant temperature shifts throughout the week.		Temperature was low at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
186	Temp	70.5	RH%	59.8	CO2	854	Occupants:	1			
	Temperature in my classroom is generally comfortable (72F-76F)?		The regular temperature of the room is very cold. Since the air conditioning system is turned off at nights and on weekends, there are significant temperature shifts throughout the week.	Temperature was low at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based					2
187	Temp	71.7	RH%	58.5	CO2	929	Occupants:	18			
	ANIMALS IN THE CLASSROOM										
	Activities and/or room conditions are modified to address student allergies?						This is a general issue requiring approved communication among all stakeholders.		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Physical Plant Operations	3
	EXCESS MOISTURE IN CLASSROOMS										
	Indoor surfaces of exterior walls free of continuous condensation?						No condensation at the time of assessment.		None		
	LOCAL EXHAUST FANS										
	Bathroom exhaust fan is functioning properly?						Bathroom exhaust fan is functioning properly.		None		
189	Temp	73.5	RH%	56.2	CO2	840	Occupants:	33			
	EXCESS MOISTURE IN CLASSROOMS										
	Indoor surfaces of exterior walls free of continuous condensation?						No condensation at the time of assessment.		None		
	GENERAL CLEANLINESS										
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?						No dust observed on supply/return registers at the time of assessment.		None		
	Floor is cleaned on a regular basis?						Floor was clean at the time of assessment.		None		
	Room is free of pests?						No pests observed at the time of assessment.		None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

190

Temp RH% CO2

Occupants:

ANIMALS IN THE CLASSROOM

Activities and/or room conditions are modified to address student allergies?

This is a general issue requiring approved communication among all stakeholders.

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

You are informed about the potential allergies of your students?

This is a general issue requiring approved communication among all stakeholders.

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

DRAIN TRAPS IN THE CLASSROOM

Water poured down floor drains once per week (approx. 1 quart of water).

It appears as though water is poured down the floor drain at least once a week.

None

EXCESS MOISTURE IN CLASSROOMS

Classroom lavatories/water fountains free of leaks?

No lavatories/water fountains in room.

None

GENERAL CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

The gym floor is damp mopped approx. once every two weeks. The area above the entrance doors is very dusty.

No dust observed on supply/return registers at the time of assessment.

None

Classroom is dusted/vacuumed thoroughly and regularly?

The gym floor is damp mopped approx. once every two weeks. The area above the entrance doors is very dusty.

There does not appear to be a dusting issue within this room.

None

Classrooms general appearance is clean and acceptable?

The gym floor is damp mopped approx. once every two weeks. The area above the entrance doors is very dusty.

General cleanliness of the room at the time of assessment was acceptable.

None

Floor is cleaned on a regular basis?

The gym floor is damp mopped approx. once every two weeks. The area above the entrance doors is very dusty.

Floor was clean at the time of assessment.

None

Room is free of pests?

The gym floor is damp mopped approx. once every two weeks. The area above the entrance doors is very dusty.

No pests observed at the time of assessment.

None

Spills and other such issues requiring custodial assistance are addressed in a timely manner?

The gym floor is damp mopped approx. once every two weeks. The area above the entrance doors is very dusty.

No issues identified relating to spill clean up practices at the time of assessment..

None

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
<i>190</i>	Temp	<input type="text" value="74.3"/>	RH% <input type="text" value="57.7"/>	CO2 <input type="text" value="729"/>	Occupants: <input type="text"/>			
LOCKER ROOM								
Locker room and showers cleaned regularly and properly?					Issues not applicable. Room is not a locker room.	None		
Soiled clothes and towels are removed regularly?					Appears that clothes and towels are removed regularly.	None		
THERMAL COMFORT								
Classroom is free of significant temperature shifts?					Temperature was acceptable at the time of assessment.	None		
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)					Humidity was acceptable at the time of assessment.	None		
Room is usually comfortable? (If no, please explain in the notes below.)					Temperature was acceptable at the time of assessment.	None		
Temperature in my classroom is generally comfortable (72F-76F)?					Temperature was acceptable at the time of assessment.	None		
<i>190A</i>	Temp	<input type="text" value="77.5"/>	RH% <input type="text" value="52.0"/>	CO2 <input type="text" value="725"/>	Occupants: <input type="text"/>			
ANIMALS IN THE CLASSROOM								
Activities and/or room conditions are modified to address student allergies?					This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
Classroom is free of animals and pets?					No animals identified at the time of assessment.	None		
You are informed about the potential allergies of your students?					This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
DRAIN TRAPS IN THE CLASSROOM								
If not regularly used, toilets flushed once each week.					It appears as though toilet is utilized regularly. No sewer gas odor detected. By flushing toilet regularly it eliminates the potential for sewer gas odors.	None		
Water poured down floor drains once per week (approx. 1 quart of water).					It appears as though water is poured down the floor drain at least once a week.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
190A	Temp	77.5	RH% 52.0	CO2 725	Occupants:		
	Water run in sinks at least once per week (about 2 cups of water).				It appears as though sink is utilized regularly. No sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors.	None	
	EXCESS MOISTURE IN CLASSROOMS						
	Cold water pipes free of continuous condensation?				No condensation on pipes at the time of assessment.	None	
	Indoor surfaces of exterior walls free of continuous condensation?				Signs of water intrusion.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations 2
	Windows, windowsills and window frames free of continuous condensation?				No condensation on windows at the time of assessment.	None	
	GENERAL CLEANLINESS						
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				No dust observed on supply/return registers at the time of assessment.	None	
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	
	Classrooms general appearance is clean and acceptable?				General cleanliness of the room at the time of assessment was acceptable.	None	
	Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None	
	Room is free of pests?				No pests observed at the time of assessment.	None	
	Spills and other such issues requiring custodial assistance are addressed in a timely manner?				No issues identified relating to spill clean up practices at the time of assessment..	None	
	LOCKER ROOM						
	Locker room and showers cleaned regularly and properly?				Industrial supplies in room.	None	
	THERMAL COMFORT						
	Classroom is free of significant temperature shifts?				Temperature was elevated at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based 2
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)				Humidity was acceptable at the time of assessment.	None	
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)				No gaps in windows or doors identified at the time of assessment.	None	
	Room is usually comfortable? (If no, please explain in the notes below.)				Temperature was elevated at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based 2
	Temperature in my classroom is generally comfortable (72F-76F)?				Temperature was elevated at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based 2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
199	Temp	83.0	RH% 36.4	CO2 27.1	Occupants: 23			
	ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?			This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Physical Plant Operations	3	
	GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?			There does not appear to be a dusting issue within this room.	None			
	Room is free of the use of scented cleaners and air fresheners?			Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	2	
	THERMAL COMFORT							
	Classroom is free of significant temperature shifts?			Portable unable to be adequately cooled by two antiquated, inefficient, noisy A/C units. Students sweat in the afternoon. In the WINTER it takes a long time to heat portable to acceptable temperature!	Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)			Portable unable to be adequately cooled by two antiquated, inefficient, noisy A/C units. Students sweat in the afternoon. In the WINTER it takes a long time to heat portable to acceptable temperature!	Humidity was acceptable at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)			Portable unable to be adequately cooled by two antiquated, inefficient, noisy A/C units. Students sweat in the afternoon. In the WINTER it takes a long time to heat portable to acceptable temperature!	Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2
	Temperature in my classroom is generally comfortable (72F-76F)?			Portable unable to be adequately cooled by two antiquated, inefficient, noisy A/C units. Students sweat in the afternoon. In the WINTER it takes a long time to heat portable to acceptable temperature!	Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
202	Temp	79.3	RH% 50.7	CO2 655	Occupants: 11		
GENERAL CLEANLINESS							
Room is free of pests?					No pests observed at the time of assessment.	None	
Walkthrough							
					Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based 2
202A	Temp	79.3	RH% 50.7	CO2 655	Occupants:		
DRAIN TRAPS IN THE CLASSROOM							
Water poured down floor drains once per week (approx. 1 quart of water).					It appears as though water is poured down the floor drain at least once a week.	None	
EXCESS MOISTURE IN CLASSROOMS							
Area around and under classroom sinks free of leaks?					No leaks or signs of water intrusion identified.	None	
Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?					No leaks or signs of water intrusion identified.	None	
Classroom lavatories/water fountains free of leaks?					No lavatories/water fountains in room.	None	
GENERAL CLEANLINESS							
Air supply/return registers are cleaned regularly and free of dust and debris accumulation?			Room needs to be cleaned more thoroughly and regularly	Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Classroom is dusted/vacuumed thoroughly and regularly?			Room needs to be cleaned more thoroughly and regularly	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Classrooms general appearance is clean and acceptable?			Room needs to be cleaned more thoroughly and regularly	General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Floor is cleaned on a regular basis?			Room needs to be cleaned more thoroughly and regularly	Dust and dirt accumulation on floor.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
Room is free of pests?			Room needs to be cleaned more thoroughly and regularly	Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations	2
Spills and other such issues requiring custodial assistance are addressed in a timely manner?			Room needs to be cleaned more thoroughly and regularly	There appears to be a problem with spill clean up practices. To address all spills in a timely manner, all moisture effected materials must be dried within a 24-hour timeframe.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
202A	Temp	79.3	RH% 50.7	CO2 655	Occupants:		
LOCAL EXHAUST FANS							
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?			It appears that the ventilation system is adequate based on room activities.	None		
LOCKER ROOM							
	Locker room and showers cleaned regularly and properly?			Issues not applicable. Room is not a locker room.	None		
	Soiled clothes and towels are removed regularly?			Appears that clothes and towels are removed regularly.	None		
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?			Temperature was elevated at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based	2
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)			Humidity was acceptable at the time of assessment.	None		
	Room is usually comfortable? (If no, please explain in the notes below.)			Temperature was elevated at the time of assessment.	Facilities serviceperson should monitor this room.	Site Based	2
208	Temp	79.4	RH% 51.6	CO2 738	Occupants:	7	
GENERAL CLEANLINESS							
	Classrooms general appearance is clean and acceptable?		Our day custodian, Ralston, is excellent in his attitude and support. However, the classroom is not adequately cleaned. It has a stale odor, the desk and table tops are never wiped off and the floor is not wet mopped. The bathrooms often do not have so		General cleanliness of the room at the time of assessment was acceptable.	None	
	Floor is cleaned on a regular basis?		Our day custodian, Ralston, is excellent in his attitude and support. However, the classroom is not adequately cleaned. It has a stale odor, the desk and table tops are never wiped off and the floor is not wet mopped. The bathrooms often do not have so		Floor was clean at the time of assessment.	None	
	Food, if any, is stored in tightly sealed containers?		Our day custodian, Ralston, is excellent in his attitude and support. However, the classroom is not adequately cleaned. It has a stale odor, the desk and table tops are never wiped off and the floor is not wet mopped. The bathrooms often do not have so		No unsealed food items were observed at the time of assessment.	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
208	Temp	79.4	RH% 51.6	CO2 738	Occupants: 7			
	Room is free of pests?	Our day custodian, Ralston, is excellent in his attitude and support. However, the classroom is not adequately cleaned. It has a stale odor, the desk and table tops are never wiped off and the floor is not wet mopped. The bathrooms often do not have so			No pests observed at the time of assessment.	None		
220	Temp	75.2	RH% 56.8	CO2 830	Occupants:			
AIR CONDITIONING								
	Room is free of smell of kitchen/food?				No microbial growth identified. No odor identified at the time of assessment.	None		
	Windows/doors are operable and are kept closed?				Windows and doors are operable and are kept closed.	None		
ANIMALS IN THE CLASSROOM								
	Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
EXCESS MOISTURE IN CLASSROOMS								
	Classroom lavatories/water fountains free of leaks?				No lavatories/water fountains in room.	None		
GENERAL CLEANLINESS								
	Room is free of the use of scented cleaners and air fresheners?				No scented cleaners, air fresheners or non-approved chemicals found at the time of assessment.	None		
LOCAL EXHAUST FANS								
	My classroom has sufficient exhaust systems based on the activities/functionality of the room?				Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2
THERMAL COMFORT								
	Classroom is free of significant temperature shifts?				Temperature was acceptable at the time of assessment.	None		
	Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)				Humidity was acceptable at the time of assessment.	None		
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)				No gaps in windows or doors identified at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority	
220	Temp	75.2	RH% 56.8	CO2 830	Occupants: <input type="text"/>			
	Room is usually comfortable? (If no, please explain in the notes below.)				Temperature was acceptable at the time of assessment.	None		
	Temperature in my classroom is generally comfortable (72F-76F)?				Temperature was acceptable at the time of assessment.	None		
220E	Temp	74.5	RH% 62.6	CO2 818	Occupants: <input type="text"/>			
	ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based	3
	GENERAL CLEANLINESS							
	Floor is cleaned on a regular basis?				Floor was clean at the time of assessment.	None		
THERMAL COMFORT								
Classroom is free of significant temperature shifts?				Temperature was acceptable at the time of assessment.	None			
Walkthrough								
				Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations	2	
220G	Temp	74.2	RH% 59.2	CO2 807	Occupants: <input type="text"/>			
	GENERAL CLEANLINESS							
Room is free of the use of scented cleaners and air fresheners?				Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based	2	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
220M	Temp	73.1	RH% 65.5	CO2 835	Occupants:		
GENERAL CLEANLINESS							
Room is free of the use of scented cleaners and air fresheners?			Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based		2
LOCAL EXHAUST FANS							
Other exhaust fans that may exist in the classroom are functioning properly?			Exhaust fan is functioning properly.	None			
220N	Temp	73.8	RH% 63.2	CO2 822	Occupants:		
EXCESS MOISTURE IN CLASSROOMS							
Indoor surfaces of exterior walls free of continuous condensation?			No condensation.	None			
GENERAL CLEANLINESS							
Food, if any, is stored in tightly sealed containers?			No unsealed food items were observed at the time of assessment.	None			
THERMAL COMFORT							
Classroom is free of significant temperature shifts?			Very cold	Temperature was acceptable at the time of assessment.	None		
Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)			Very cold	Humidity was slightly elevated at the time of assessment - 10% greater than outdoors.	Physical Plant Operations to evaluate HVAC system for proper operation and repair as appropriate to lower humidity level.	Physical Plant Operations	2
Room is usually comfortable? (If no, please explain in the notes below.)			Very cold	Temperature was acceptable at the time of assessment.	None		
Temperature in my classroom is generally comfortable (72F-76F)?			Very cold	Temperature was acceptable at the time of assessment.	None		
220P	Temp	73.4	RH% 68.7	CO2 780	Occupants:		
THERMAL COMFORT							
Classroom is free of significant temperature shifts?			The room temperature is either too cold, or too warm.	Temperature was acceptable at the time of assessment.	None		
Room is usually comfortable? (If no, please explain in the notes below.)			The room temperature is either too cold, or too warm.	Temperature was acceptable at the time of assessment.	None		

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

277C

Temp RH% CO2 Occupants:

ANIMALS IN THE CLASSROOM

Activities and/or room conditions are modified to address student allergies?

This is a general issue requiring approved communication among all stakeholders.

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

You are informed about the potential allergies of your students?

This is a general issue requiring approved communication among all stakeholders.

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Site Based

3

EXCESS MOISTURE IN CLASSROOMS

Ceiling tiles or walls free of leaks and/or discoloration (discoloration may indicate periodic leaks)?

Stained ceiling tiles.

Facilities serviceperson to replace stained ceiling tiles.

Site Based

2

Indoor surfaces of exterior walls free of continuous condensation?

Condensation on windows at the time of assessment. Temperature was not within acceptable range and leaks were identified.

Physical Plant Operations to evaluate and repair as appropriate.

Physical Plant Operations

2

GENERAL CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

No dust observed on supply/return registers at the time of assessment.

None

Room is free of pests?

No pests observed at the time of assessment.

None

Room is free of the use of scented cleaners and air fresheners?

No scented cleaners, air fresheners or non-approved chemicals found at the time of assessment.

None

Spills and other such issues requiring custodial assistance are addressed in a timely manner?

No issues identified relating to spill clean up practices at the time of assessment..

None

278

Temp RH% CO2 Occupants:

AIR CONDITIONING

Room is free of smell of mold or mildew?

Odor detected at the time of assessment.

Physical Plant Operations to evaluate cause of odor.

Physical Plant Operations

1

EXCESS MOISTURE IN CLASSROOMS

Indoor surfaces of exterior walls free of continuous condensation?

Condensation on windows at the time of assessment. Temperature was not within acceptable range and leaks were identified.

Physical Plant Operations to evaluate and repair as appropriate.

Physical Plant Operations

1

Windows, windowsills and window frames free of continuous condensation?

Condensation on walls at the time of assessment.

Physical Plant Operations to evaluate and repair as appropriate.

Physical Plant Operations

1

GENERAL CLEANLINESS

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
278	Temp	77.2	RH% 52.3	CO2 489	Occupants: 25		
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				No dust observed on supply/return registers at the time of assessment.	None	
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	
	Floor is cleaned on a regular basis?				Dust and dirt accumulation on floor. Floor needs wax.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	Room is free of pests?				No pests observed at the time of assessment.	None	
	Room is free of the use of scented cleaners and air fresheners?				No scented cleaners, air fresheners or non-approved chemicals found at the time of assessment.	None	
THERMAL COMFORT							
	Classroom is free of significant temperature shifts?				Temperature was elevated at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.	Site Based 2
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)				Gaps in windows or doors identified at the time of assessment.	Physical Plant Operations to evaluate and repair as appropriate.	Physical Plant Operations 2
503C	Temp	80.0	RH% 47.8	CO2 2026	Occupants: 18		
AIR CONDITIONING							
	Room is free of smell of mold or mildew?				No odor detected at the time of assessment.	None	
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
	You are informed about the potential allergies of your students?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
EXCESS MOISTURE IN CLASSROOMS							
	Area around and under classroom sinks free of leaks?				No leaks or signs of water intrusion identified.	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
-----------	----------------------	--	--	----------	----------------	-------------	----------

503C

Temp RH% CO2

Occupants:

Indoor surfaces of exterior walls free of continuous condensation?

No condensation at the time of assessment. None

Windows, windowsills and window frames free of continuous condensation?

No condensation on windows at the time of assessment. None

GENERAL CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

No dust observed on supply/return registers at the time of assessment. None

Classroom is dusted/vacuumed thoroughly and regularly?

There does not appear to be a dusting issue within this room. None

Classrooms general appearance is clean and acceptable?

General cleanliness of the room at the time of assessment was acceptable. None

Room is free of the use of scented cleaners and air fresheners?

No scented cleaners, air fresheners or non-approved chemicals found at the time of assessment. None

THERMAL COMFORT

Classroom is free of significant temperature shifts?

Temperature was elevated at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve. Site Based

2

Humidity is generally acceptable? (Typically too high if higher than 60% relative humidity [RH] or too low if lower than 30% RH.)

Humidity was acceptable at the time of assessment. None

Room is free of the introduction of outdoor air? (Gaps in window/door frames.)

No gaps in windows or doors identified at the time of assessment. None

504C

Temp RH% CO2

Occupants:

GENERAL CLEANLINESS

Air supply/return registers are cleaned regularly and free of dust and debris accumulation?

No dust observed on supply/return registers at the time of assessment. None

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority
617C	Temp	86.5	RH% 49.6	CO2 1416	Occupants:	10	
GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?	I enjoy teaching in a portable/learning cottage however, there is an ant problem. I have had the custodian bomb it from time to time but I feel it needs to be tented. There have been many times I would be typing on my laptop and ants would cross or wal			There does not appear to be a dusting issue within this room.	None	
	Room is free of pests?	I enjoy teaching in a portable/learning cottage however, there is an ant problem. I have had the custodian bomb it from time to time but I feel it needs to be tented. There have been many times I would be typing on my laptop and ants would cross or wal			Pests observed at the time of assessment.	Physical Plant Operations to initiate work order to evaluate pest issue within location and take appropriate action.	Physical Plant Operations 2
	Room is free of the use of scented cleaners and air fresheners?	I enjoy teaching in a portable/learning cottage however, there is an ant problem. I have had the custodian bomb it from time to time but I feel it needs to be tented. There have been many times I would be typing on my laptop and ants would cross or wal			Non-approved chemicals, scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals, scented cleaners or air fresheners from the room.	Site Based 2
THERMAL COMFORT							
	Room is free of the introduction of outdoor air? (Gaps in window/door frames.)				No gaps in windows or doors identified at the time of assessment.	None	
646C	Temp	81.1	RH% 40.3	CO2 815	Occupants:	22	
ANIMALS IN THE CLASSROOM							
	Activities and/or room conditions are modified to address student allergies?				This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.	Site Based 3
GENERAL CLEANLINESS							
	Classroom is dusted/vacuumed thoroughly and regularly?				There does not appear to be a dusting issue within this room.	None	
	Floor is cleaned on a regular basis?				Dust and dirt accumulation on floor. Floor needs wax.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based 2
	Room is free of the use of scented cleaners and air fresheners?				No scented cleaners, air fresheners or non-approved chemicals found at the time of assessment.	None	
	Trash is removed daily and trash bags are changed as appropriate?				No issues identified regarding trash removal practices.	None	

FISH/Room	Participant Comments			Response	Recommendation	Responsible	Priority				
927C	Temp	85.3	RH%	48.5	CO2	2099	Occupants:				
	Air supply/return registers are cleaned regularly and free of dust and debris accumulation?				Dust observed on supply/return registers at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2			
	Classroom is dusted/vacuumed thoroughly and regularly?				Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.	Site Based	2			
	Room is free of pests?				No pests observed at the time of assessment.	None					
	Room is free of the use of scented cleaners and air fresheners?				No scented cleaners, air fresheners or non-approved chemicals found at the time of assessment.	None					