

Report: Site

**SEMINOLE MIDDLE**

Walkthrough Date: 05/16/2006 Temp RH CO2

Outdoor Parameters: 85.7 51.0 515

Room	Priority	Responsible	Answer	Recommendation
004	Inside Parameters:	Temp	RH	CO2
		76.8	52.4	931

2 Site No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles. Facilities serviceperson to replace ceiling tiles.

Room	Priority	Responsible	Answer	Recommendation
101A	Inside Parameters:	Temp	RH	CO2
		73.6	68.8	671

2 Site Dust observed on supply register at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

1 Site This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

2 Site No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles. Facilities serviceperson to replace ceiling tiles.

Room	Priority	Responsible	Answer	Recommendation
104D	Inside Parameters:	Temp	RH	CO2
		74.9	56.2	885

2 Site Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.

2 Site Dust and dirt accumulation on floor. Facilities serviceperson to thoroughly clean and sanitize.

Room	Priority	Responsible	Answer	Recommendation
107	Inside Parameters:	Temp	RH	CO2
		73	60.5	944

2 Site Dust observed on supply register at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

1	Site	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
1	Site	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
2	Site	No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.	Facilities serviceperson to replace ceiling tiles.
1	Site	Microbial growth in cabinets. Remove books and clean.	Clean with Wexcide disinfectant solution.

Room	Priority	Responsible	Answer	Recommendation
112	Inside Parameters:	Temp 72.7	RH 63.5	CO2 776

2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
---	------	--------------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------------------

Room	Priority	Responsible	Answer	Recommendation
112A	Inside Parameters:	Temp 72.4	RH 63	CO2 749

2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
---	------	--------------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------------------

Room	Priority	Responsible	Answer	Recommendation
112B	Inside Parameters:	Temp 73	RH 62.5	CO2 746

2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
---	------	--------------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------------------

2	Site	Dust observed on supply register at the time of assessment. [Heavy]	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
---	------	---------------------------------------------------------------------	------------------------------------------------------------------------------------------------------

Room	Priority	Responsible	Answer	Recommendation
117	Inside Parameters:	Temp 75.1	RH 48.9	CO2 1156

2	Site	Excessive dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
---	------	-----------------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------------------

2	Site	Dust observed on supply register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
1	Site	Non-approved chemicals scented cleaners or air fresheners found at the time of assessment.	Facilities serviceperson to remove all non-approved chemicals scented cleaners or air fresheners from the room.
2	Site	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize.
1	Site	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Room	Priority	Responsible	Answer	Recommendation
118	Inside Parameters:	Temp	RH	CO2
		75	60	1206

2	Site	Dust observed on return register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
2	Site	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize.
1	Site	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
1	Site	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
2	Site	No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles. [Bowed]	Facilities serviceperson to replace ceiling tiles. Bowed ceiling tiles.

Room	Priority	Responsible	Answer	Recommendation
119	Inside Parameters:	Temp	RH	CO2
		70.0	50.7	830

2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment. Two stained ceiling tiles.	Site based administration should address general cleanliness with facility serviceperson staff. Replace stained tiles.
2	Site	Dust observed on supply register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Room	Priority	Responsible	Answer	Recommendation
120	Inside Parameters:	Temp	RH	CO2
		68.6	67.3	933

1	Site	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
3	Site	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
2	Site	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.
2	Site	Temperature was low at the time of assessment.	Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
120A	Inside Parameters:	Temp 69.2	RH 68.6	CO2 1043
2	Site		Dust observed on supply register at the time of assessment. Replace bowed ceiling tiles.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
1	Site		This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Room	Priority	Responsible	Answer	Recommendation
121	Inside Parameters:	Temp 73.6	RH 59.5	CO2 1217
1	Site		No exhaust in room. Air fresheners any many cleaning chemicals in closet.	Sources of allergens, remove immediately.

Room	Priority	Responsible	Answer	Recommendation
122	Inside Parameters:	Temp 71.8	RH 62.4	CO2 1029
1	Site		Stained ceiling tiles. All environmental surfaces dirty. 122A-Keep food in air tight containers, remove unauthorized chemicals.	Clean all surfaces. 122A-Remove unauthorized chemical & put food in containers.

3 Site This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Room	Priority	Responsible	Answer	Recommendation
123	Inside Parameters:	Temp 70.5	RH 68.5	CO2 861

3 Site This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

2 Site Temperature was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
124	Inside Parameters:	Temp 68.6	RH 72.9	CO2 881

2 Site Dust observed on supply register at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

Room	Priority	Responsible	Answer	Recommendation
125	Inside Parameters:	Temp 68.8	RH 71.1	CO2 758

2 Site Temperature was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
127	Inside Parameters:	Temp 68.2	RH 73	CO2 873

2 Site Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.

2 Site Dust and dirt accumulation on floor. Facilities serviceperson to thoroughly clean and sanitize.

Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

2 Site Temperature was low at the time of assessment.

Room	Priority	Responsible	Answer	Recommendation
128	Inside Parameters:	Temp 70.3	RH 68.5	CO2 859

Facilities serviceperson to thoroughly clean and sanitize.

Facilities serviceperson to replace ceiling tiles.

Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

2 Site Dust and dirt accumulation on floor.  
2 Site No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.  
2 Site Temperature was low at the time of assessment.

Room	Priority	Responsible	Answer	Recommendation
131	Inside Parameters:	Temp 67.2	RH 75.4	CO2 800

Site based administration should address general cleanliness with facility serviceperson staff.

Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner. Replace dirt impacted ceiling tiles.

Facilities serviceperson to thoroughly clean and sanitize.

Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

2 Site Excessive dust accumulation was observed on environmental surfaces at the time of assessment.  
2 Site Dust observed on supply register at the time of assessment.  
2 Site Dust and dirt accumulation on floor.  
2 Site Temperature was low at the time of assessment.

Room	Priority	Responsible	Answer	Recommendation
132	Inside Parameters:	Temp 68.9	RH 72.7	CO2 790

Site based administration should address general cleanliness with facility serviceperson staff.

This is a general issue requiring approved communication Site based administration is encouraged to communicate all

3 Site among all stakeholders.

known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

2 Site Temperature was low at the time of assessment.

Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
133	Inside Parameters:	Temp	RH	CO2
		70.4	71.9	982

2 Site Temperature was low at the time of assessment. Duct tape on floor, ceiling tiles misaligned, surfaces dirty. Dust accumulated on ceiling tiles at AC Supply registers.

Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
134	Inside Parameters:	Temp	RH	CO2
		70.9	72	1066

1 Site This is a general issue requiring approved communication among all stakeholders.

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

2 Site Temperature was low at the time of assessment.

Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
136	Inside Parameters:	Temp	RH	CO2
		70.6	73.1	1018

2 Site Excessive dust accumulation was observed on environmental surfaces at the time of assessment.

Site based administration should address general cleanliness with facility serviceperson staff.

2 Site Dust observed on supply register at the time of assessment.

Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.

3 Site This is a general issue requiring approved communication among all stakeholders.

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Room	Priority	Responsible	Answer	Recommendation

Room	Priority	Responsible	Answer	Recommendation
140	Inside Parameters:	Temp	RH	CO2
		68.3	73.7	947

2	Site	General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.
2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
2	Site	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize.
3	Site	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Room	Priority	Responsible	Answer	Recommendation
146	Inside Parameters:	Temp	RH	CO2
		72.2	57.2	896

2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
---	------	--------------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------------------

Room	Priority	Responsible	Answer	Recommendation
147	Inside Parameters:	Temp	RH	CO2
		73.1	52.8	804

2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
3	Site	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Room	Priority	Responsible	Answer	Recommendation
151	Inside Parameters:	Temp	RH	CO2
		71.8	60.8	777

2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
3	Site	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order

to modify classroom activities/conditions when necessary.

Facilities serviceperson to replace ceiling tiles.

Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Site based facilities serviceperson should monitor this room.

Room	Priority	Responsible	Answer	Recommendation
154	Inside Parameters:	Temp	RH	CO2
		73.6	50.6	764

2 Site No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles. Facilities serviceperson to replace ceiling tiles.

Room	Priority	Responsible	Answer	Recommendation
156	Inside Parameters:	Temp	RH	CO2
		72.6	49.6	738

2 Site No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles. Facilities serviceperson to replace ceiling tiles.

Room	Priority	Responsible	Answer	Recommendation
174	Inside Parameters:	Temp	RH	CO2
		69.1	64.5	960

2 Site General cleanliness of the room at the time of assessment was not acceptable. Site based administration should address general cleanliness with facility serviceperson staff.

2 Site Excessive dust accumulation was observed on environmental surfaces due to clutter at the time of assessment. Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts

3 Site There appears to be an issue regarding daily trash removal practices. Site based administration should address general cleanliness with facility serviceperson staff.

2 Site Dust observed on supply register at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with

District approved germicidal cleaner.  
 Facilities serviceperson to thoroughly clean and sanitize.  
 Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.  
 Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.  
 Facilities serviceperson to replace ceiling tiles.

2 Site Dust and dirt accumulation on floor.  
 3 Site This is a general issue requiring approved communication among all stakeholders.  
 3 Site This is a general issue requiring approved communication among all stakeholders.  
 2 Site No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.

Room	Priority	Responsible	Answer	Recommendation
175	Inside Parameters:	Temp 69.8	RH 62.7	CO2 763

2 Site General cleanliness of the room at the time of assessment was not acceptable. Site based administration should address general cleanliness with facility serviceperson staff.  
 2 Site Excessive dust accumulation was observed on environmental surfaces due to clutter at the time of assessment. Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts  
 2 Site Dust and dirt accumulation on floor. Facilities serviceperson to thoroughly clean and sanitize.  
 1 Site This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.  
 2 Site No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles. Facilities serviceperson to replace ceiling tiles.

Room	Priority	Responsible	Answer	Recommendation
175A	Inside Parameters:	Temp 68.7	RH 65.8	CO2 772

2 Site General cleanliness of the room at the time of assessment was not acceptable. Site based administration should address general cleanliness with facility serviceperson staff.  
 2 Site Excessive dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.  
 3 Site There appears to be an issue regarding daily trash removal practices. Site based administration should address general cleanliness with facility serviceperson staff.  
 2 Site Dust and dirt accumulation on floor. Facilities serviceperson to thoroughly clean and sanitize.

- 3 Site This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
- 2 Site It appears as though sink is not utilized regularly. Sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors. Site based administration should address maintenance of sinks toilets and drains with facility serviceperson staff.

Room	Priority	Responsible	Answer	Recommendation
175B	Inside Parameters:	Temp	RH	CO2
		71.5	61.6	810

- 2 Site Dust and dirt accumulation on floor. Closet with lots of clutter. Facilities serviceperson to thoroughly clean and sanitize.

Room	Priority	Responsible	Answer	Recommendation
176	Inside Parameters:	Temp	RH	CO2
		69.7	62.5	684

- 2 Site Slight dust accumulation was observed on environmental surfaces at the time of assessment. Site based administration should address general cleanliness with facility serviceperson staff.
- 3 Site This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
- 3 Site This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
- 2 Site Temperature was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
177	Inside Parameters:	Temp	RH	CO2
		70.4	61.7	663

- 2 Site Excessive dust accumulation was observed on environmental surfaces due to clutter at the time of assessment. Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts
- 2 Site Dust observed on supply register at the time of assessment. Facilities serviceperson to thoroughly clean and sanitize with

District approved germicidal cleaner.

Facilities serviceperson to thoroughly clean and sanitize.

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Facilities serviceperson to replace ceiling tiles.

- 2 Site Dust and dirt accumulation on floor.
- 3 Site This is a general issue requiring approved communication among all stakeholders.
- 2 Site No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.

Room	Priority	Responsible	Answer	Recommendation
177A	Inside Parameters:	Temp	RH	CO2
		75.3	55.5	747

2 Site Dust and dirt accumulation on floor.

Facilities serviceperson to thoroughly clean and sanitize.

2 Site Supply vents closed at the time of assessment.

Facilities serviceperson to open supply vents.

Room	Priority	Responsible	Answer	Recommendation
179E	Inside Parameters:	Temp	RH	CO2
		72.3	59.4	711

2 Site Excessive dust accumulation was observed on environmental surfaces due to clutter at the time of assessment.

Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts

3 Site This is a general issue requiring approved communication among all stakeholders.

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

2 Site No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.

Facilities serviceperson to replace ceiling tiles.

Room	Priority	Responsible	Answer	Recommendation
210A	Inside Parameters:	Temp	RH	CO2
		74.2	41.2	930

3 Site This is a general issue requiring approved communication among all stakeholders.

Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

2 Site No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles.

Facilities serviceperson to replace ceiling tiles.

2 Site Slight dust accumulation was observed on environmental surfaces at the time of assessment.

Site based administration should address general cleanliness with facility serviceperson staff.

Room	Priority	Responsible	Answer	Recommendation
210B	Inside Parameters:	Temp	RH	CO2
		72.2	47.6	940

2 Site Slight dust accumulation was observed on environmental surfaces due to clutter at the time of assessment. Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts

Room	Priority	Responsible	Answer	Recommendation
210C	Inside Parameters:	Temp	RH	CO2
		70.6	49	891

2 Site Slight dust accumulation was observed on environmental surfaces due to clutter at the time of assessment. Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts

2 Site Temperature was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
210D	Inside Parameters:	Temp	RH	CO2
		67.9	52.7	893

2 Site Slight dust accumulation was observed on environmental surfaces due to clutter at the time of assessment. Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts

2 Site Temperature was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

2 Site Temperature was low at the time of assessment. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
210E	Inside Parameters:	Temp	RH	CO2

		69.3	49.8	906
2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.		Site based administration should address general cleanliness with facility serviceperson staff.
2	Site	Temperature was low at the time of assessment.		Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.
2	Site	Temperature was low at the time of assessment.		Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
210G	Inside Parameters:	Temp	RH	CO2
		70.1	48.5	910
2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.		Site based administration should address general cleanliness with facility serviceperson staff.
3	Site	This is a general issue requiring approved communication among all stakeholders.		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
2	Site	Temperature was low at the time of assessment.		Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.
2	Site	Temperature was low at the time of assessment.		Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

Room	Priority	Responsible	Answer	Recommendation
210H	Inside Parameters:	Temp	RH	CO2
		71.3	45.8	956
2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.		Site based administration should address general cleanliness with facility serviceperson staff.
2	Site	Dust and dirt accumulation on floor.		Facilities serviceperson to thoroughly clean and sanitize.
2	Site	Temperature was low at the time of assessment.		Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition

and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve. Site based administration to encourage facility serviceperson staff to adjust the thermostat. Continue to monitor condition and initiate a work order for Physical Plant Operations to evaluate the HVAC system if temperature does not improve.

2 Site Temperature was low at the time of assessment.

Room	Priority	Responsible	Answer	Recommendation
220	Inside Parameters:	Temp	RH	CO2
		73.1	57.6	1577

2 Site It appears as though sink is not utilized regularly. Sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors. Site based administration should address maintenance of sinks toilets and drains with facility serviceperson staff.

Room	Priority	Responsible	Answer	Recommendation
223	Inside Parameters:	Temp	RH	CO2
		71.4	44.8	1621

2 Site It appears as though sink is not utilized regularly. Sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors. Site based administration should address maintenance of sinks toilets and drains with facility serviceperson staff.

2 Site No leaks identified. Signs of previous water intrusion as evidenced by stained ceiling tiles. Facilities serviceperson to replace ceiling tiles.

Room	Priority	Responsible	Answer	Recommendation
224	Inside Parameters:	Temp	RH	CO2
		71.1	63.8	1488

3 Site This is a general issue requiring approved communication among all stakeholders. Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

2 Site It appears as though sink is not utilized regularly. Sewer gas odor detected. By running water regularly it eliminates the potential for sewer gas odors. Site based administration should address maintenance of sinks toilets and drains with facility serviceperson staff.

Room	Priority	Responsible	Answer	Recommendation
226	Inside Parameters:	Temp	RH	CO2

		70.9	62.9	1539
--	--	------	------	------

2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
2	Site	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize.

Room	Priority	Responsible	Answer	Recommendation
413P	Inside Parameters:	Temp	RH	CO2
		69.3	68.3	2554

2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment. Filters clogged.	Site based administration should address general cleanliness with facility serviceperson staff.
3	Site	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Room	Priority	Responsible	Answer	Recommendation
478C	Inside Parameters:	Temp	RH	CO2
		69	53.4	2221

2	Site	Excessive dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
2	Site	Dust observed on supply register at the time of assessment.	Facilities serviceperson to thoroughly clean and sanitize with District approved germicidal cleaner.
2	Site	Dust and dirt accumulation on floor.	Facilities serviceperson to thoroughly clean and sanitize.
3	Site	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
3	Site	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Room	Priority	Responsible	Answer	Recommendation
486C	Inside Parameters:	Temp	RH	CO2
		72.8	65.5	3112

2	Site	Excessive dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
2	Site	Dust observed on supply register at the time of assessment. Filter were clogged, only 1 unit running, 1 unit missing	Facilities serviceperson to thoroughly clean and sanitize with

2	Site	filter. Dust and dirt accumulation on floor.	District approved germicidal cleaner. Facilities serviceperson to thoroughly clean and sanitize.
3	Site	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Room	Priority	Responsible	Answer	Recommendation
70C	Inside Parameters:	Temp 74.5	RH 52.4	CO2 3003

3	Site	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
---	------	----------------------------------------------------------------------------------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Room	Priority	Responsible	Answer	Recommendation
852	Inside Parameters:	Temp 65.7	RH 53.2	CO2 1960

2	Site	Excessive dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.
3	Site	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
3	Site	This is a general issue requiring approved communication among all stakeholders.	Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Room	Priority	Responsible	Answer	Recommendation
860	Inside Parameters:	Temp 74.3	RH 76	CO2 1389

2	Site	General cleanliness of the room at the time of assessment was not acceptable.	Site based administration should address general cleanliness with facility serviceperson staff.
2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.	Site based administration should address general cleanliness with facility serviceperson staff.

Room	Priority	Responsible	Answer	Recommendation
861	Inside Parameters:	Temp	RH	CO2

		71.8	64.1	575
2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.		Site based administration should address general cleanliness with facility serviceperson staff.
2	Site	Dust and dirt accumulation on floor.		Facilities serviceperson to thoroughly clean and sanitize.
3	Site	This is a general issue requiring approved communication among all stakeholders.		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.
3	Site	This is a general issue requiring approved communication among all stakeholders.		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Room	Priority	Responsible	Answer	Recommendation
862	Inside Parameters:	Temp	RH	CO2
		70.9	68.9	1140

2	Site	Slight dust accumulation was observed on environmental surfaces due to clutter at the time of assessment.		Site based administration should work with room occupant to encourage occupant to reduce clutter to assist facility serviceperson with their dusting efforts
2	Site	Dust and dirt accumulation on floor.		Facilities serviceperson to thoroughly clean and sanitize.
3	Site	This is a general issue requiring approved communication among all stakeholders.		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.

Room	Priority	Responsible	Answer	Recommendation
863	Inside Parameters:	Temp	RH	CO2
		70.1	67	1299

2	Site	Slight dust accumulation was observed on environmental surfaces at the time of assessment.		Site based administration should address general cleanliness with facility serviceperson staff.
2	Site	Dust and dirt accumulation on floor.		Facilities serviceperson to thoroughly clean and sanitize.
3	Site	This is a general issue requiring approved communication among all stakeholders.		Site based administration is encouraged to communicate all known student allergies to the appropriate personnel in order to modify classroom activities/conditions when necessary.