

Jeffrey S. Moquin, Director
Risk Management Department

Telephone: 754-321-3200
Facsimile: 754-321-3290

September 6, 2006

Signature on File

TO: Ms. Rebecca Dahl, Principal
Sunrise Middle School

FROM: Aston A. Henry, Jr., Supervisor
Risk Management Department

SUBJECT: Indoor Air Quality (IAQ) Assessment
FISH 132 and 138

On September 5, 2006 I conducted an assessment of FISH 132 and 138 at **Sunrise Middle School**. This evaluation included observations of the flooring system, ceiling tiles, false ceiling plenum, environmental surfaces, interior and exterior walls, and the accessible ventilation equipment. Additionally, environmental parameter measurements were taken to include temperature, relative humidity, and carbon dioxide. The detailed findings, along with the recommended corrective action can be found on the attached IAQ Assessment Worksheets.

Generally, the IAQ Assessment did not identify any existing conditions significantly impacting IAQ and thereby presenting immediate health and safety concerns to building occupants. However, due to individual sensitivities and predisposing health factors, it is possible that some building occupants may elicit a health response to agents and / or conditions identified during the evaluation. Therefore, to further improve IAQ, prevent development of future IAQ-related problems, and to reduce the potential for IAQ-related complaints by building occupants, the IAQ Assessment Team recommends appropriate follow up of each item identified and listed in the attached evaluation.

Should any questions arise, or if the current concerns continue after the attached recommendations have been addressed, please feel free to contact me at 754-321-3200.

cc: Dr. Verda Farrow, Area Superintendent
Michaelle Pope, Area Director
Jeffrey S. Moquin, Director, Risk Management
Wayne Thrasher, Project Manager, Facilities and Construction Management
Ralph Eckhardt, Broward Teachers Union
Mark Dorsett, Manager 1, Physical Plant Operations Division, Zone 1
Roy Norton, Manager Custodial/Grounds, Physical Plant Operations Division
Robert Krickovich, Coordinator, LEA, Facilities and Construction Management

AAH/tc
Enc.

IAQ Assessment

Sunrise Middle School

Location Number
 Evaluation Requested
 Evaluation Date

Time of Day

Outdoor Conditions Temperature Relative Humidity Ambient CO2

Fish	Temperature	Range	Relative Humidity	Range	CO2	Range	# Occupants
<input type="text" value="132"/>	<input type="text" value="67.8"/>	<input type="text" value="72 - 78"/>	<input type="text" value="64.7"/>	<input type="text" value="30% - 60%"/>	<input type="text" value="549"/>	<input type="text" value="Max 700 > Ambient"/>	<input type="text" value="4"/>
Noticeable Odor	<input type="text" value="No"/>	Visible water damage / staining?	<input type="text" value="No"/>	Visible microbial growth?	<input type="text" value="No"/>	Amount of material affected	<input type="text" value="None"/>
Ceiling Type	<input type="text" value="2 x 4 Lay In"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		
Wall Type	<input type="text" value="Drywall"/>		<input type="text" value="No"/>	<input type="text" value="Yes"/>	<input type="text" value="Southwest & Southeast wall"/>		
Flooring	<input type="text" value="Tile"/>		<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text" value="None"/>		

	Clean	Minor Dust / Debris	Needs Cleaning	Corrective Action Required
Ceiling	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Walls	<input type="text" value="No"/>	<input type="text" value="Yes"/>	<input type="text" value="Yes"/>	<input type="text" value="Clean with Wexcide disinfectant"/>
Flooring	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
HVAC Supply Grills	<input type="text" value="No"/>	<input type="text" value="Yes"/>	<input type="text" value="Yes"/>	<input type="text" value="Clean with Wexcide disinfectant"/>
HVAC Return Grills	<input type="text" value="No"/>	<input type="text" value="Yes"/>	<input type="text" value="Yes"/>	<input type="text" value="Clean with Wexcide disinfectant"/>
Ceiling at Supply Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Surfaces in Room	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>

Observations

Findings:

- Visible microbial growth on Southwest and Southeast wall of media center
- Dust and debris on HVAC supply and return grills
- Temperature was low and humidity level was slightly elevated at the time of the assessment

Recommendations:

Site Based Maintenance:

- Thoroughly clean walls with Wexcide disinfectant solution
- Clean HVAC supply and return grills with Wexcide disinfectant solution
- Adjust the thermostat to increase the temperature which will also lower the humidity level
- Continue to monitor this location for any signs of microbial growth as well as dust and debris accumulation and clean as appropriate

IAQ Assessment

Sunrise Middle School

Location Number
 Evaluation Requested
 Evaluation Date

Time of Day

Outdoor Conditions Temperature Relative Humidity Ambient CO2

Fish	Temperature	Range	Relative Humidity	Range	CO2	Range	# Occupants
<input type="text" value="138"/>	<input type="text" value="65.7"/>	<input type="text" value="72 - 78"/>	<input type="text" value="64"/>	<input type="text" value="30% - 60%"/>	<input type="text"/>	<input type="text" value="Max 700 > Ambient"/>	<input type="text"/>
Noticeable Odor	<input type="text" value="No"/>	Visible water damage / staining?	<input type="text" value="No"/>	Visible microbial growth?	<input type="text" value="No"/>	Amount of material affected	<input type="text" value="None"/>
Ceiling Type	<input type="text" value="2 x 4 Lay In"/>		<input type="text" value="No"/>		<input type="text" value="No"/>		<input type="text" value="None"/>
Wall Type	<input type="text" value="Drywall"/>		<input type="text" value="No"/>		<input type="text" value="Yes"/>		<input type="text" value="Northwest wall"/>
Flooring	<input type="text" value="Tile"/>		<input type="text" value="No"/>		<input type="text" value="No"/>		<input type="text" value="None"/>

	Clean	Minor Dust / Debris	Needs Cleaning	Corrective Action Required
Ceiling	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Walls	<input type="text" value="No"/>	<input type="text" value="Yes"/>	<input type="text" value="Yes"/>	<input type="text" value="Clean with Wexcide disinfectant"/>
Flooring	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
HVAC Supply Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
HVAC Return Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Ceiling at Supply Grills	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>
Surfaces in Room	<input type="text" value="Yes"/>	<input type="text" value="No"/>	<input type="text" value="No"/>	<input type="text"/>

Observations

Findings:

- Visible microbial growth on Northwest wall
- Temperature was low and humidity level was slightly elevated at the time of the assessment
- Condensation is forming on the outside wall due to low temperature

Recommendations:

Site Based Maintenance:

- Thoroughly clean wall with Wexcide disinfectant solution
- Adjust the thermostat to increase the temperature which will also lower the humidity level and eliminate condensation on wall.
- Continue to monitor this location for any signs of microbial growth as well as dust and debris accumulation and clean as appropriate