

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
<b>101</b>				
<b>102</b>				
<b>104</b>				



<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
Thermal Comfort	Humidity level.	The humidity was 52% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.
Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.
Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.
My room is never at a constant temperature and more often than not the students are complaining that they are too hot - especially towards the end of the day. It also seems to be unusually humid in my classroom.			

117

72.3	51%	880
<i>Temp</i>	<i>RH</i>	<i>Co2</i>

Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Classroom Information		Minor dust and debris was observed on the air supply and return registers at the time of the assessment.	Custodial staff should clean and sanitize the air supply and return registers in this classroom.
General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.

The floors are not washed often enough... the room is rarely dusted (never, as far as I can tell). There is dust all over the shelves/cabinets. The window slats are insect-ridden.

118

72.7	52%	948
<i>Temp</i>	<i>RH</i>	<i>Co2</i>

Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Classroom Information		Dust and debris was observed on the air supply and return registers at the time of the assessment.	Custodial staff should clean and sanitize the air supply and return registers in this classroom.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
121	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
		My classroom is typically much colder than other areas of the school.		
	72 <i>Temp</i>	52% <i>RH</i>	965 <i>Co2</i>	
123	General Cleanliness	Confirm that the classroom is cleaned properly	Dust and debris was observed on the air supply and return registers at the time of the assessment. Also, walls, ceiling tiles, and flooring need to be cleaned.	Custodial staff should clean and sanitize the air supply and return registers in this classroom and clean walls, ceiling tiles and flooring.
	71.8 <i>Temp</i>	52% <i>RH</i>	899 <i>Co2</i>	
133	General Classroom Information		Dust and debris was observed on the air supply and return registers at the time of the assessment. Also, walls, ceiling tiles, and flooring need to be cleaned.	Custodial staff should clean and sanitize the air supply and return registers in this classroom and clean walls, ceiling tiles and flooring.
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
	73.8 <i>Temp</i>	54% <i>RH</i>	1174 <i>Co2</i>	
	Drain Traps	Drain traps, if present, can become a problem when the water in the drain trap evaporates due to infrequent use, allowing sewer gases to enter the room.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Confirm that the classroom is cleaned properly	Tile floor is dirty and has marks.	Clean and sanitize flooring.

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>	
Local Exhaust Fans	Confirm that fume hoods and local exhaust fans are used whenever activities that generate pollutants take place.	There are no fume hoods or local exhaust fans in classroom.	No corrective action recommended at this time.	
Local Exhaust Fans	General items.	There are no fume hoods or local exhaust fans in classroom.	No corrective action recommended at this time.	
Local Exhaust Fans	Confirm that fume hoods and local exhaust fans function properly.	There are no fume hoods or local exhaust fans in classroom.	No corrective action recommended at this time.	
<b>137</b>	73.1	52%	786	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	General Cleanliness	Confirm that the classroom is cleaned properly	Tile floor is slightly dirty.	clean and sanitize flooring.
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
Ventilation	If you have mechanical ventilation, confirm that air is flowing from the room into the air return grille(s).	Return air grill is functioning properly.	No corrective action recommended at this time.	
Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.	
Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.	
Teacher's lunch area in café is always hot. Library is hot, planning area is hot. No air circulation, very stuffy and my allergies are very sensitive to this.				
<b>138</b>	73.3	52%	786	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.	

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
<b>143</b>	71.5 <i>Temp</i>	51% <i>RH</i>	1004 <i>Co2</i>	
	Animals in the Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.
	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
	Thermal Comfort	Humidity level.	The humidity was 51% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
	Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.
	Ventilation	If you have mechanical ventilation, confirm that air is flowing from the room into the air return grille(s).	Return air grill is functioning properly.	No corrective action recommended at this time.
	Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.
	My room is often very hot during the day.			
<b>145</b>	70.2 <i>Temp</i>	54% <i>RH</i>	1306 <i>Co2</i>	
	Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	Three stained ceiling tiles identified on the north wall. Ceiling plenum appears to be dry. A/C supply duct is not insulated. Possible condensation dripping from A/C onto the ceiling tiles.	Maintenance to inspect for roof leak and repair as appropriate and replace ceiling tiles.
	General Classroom Information		Co2 level was slightly elevated at time of assessment.	Maintenance to inspect and repair as appropriate to lower Co2 level.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
<b>148</b>	70.1 <i>Temp</i>	54% <i>RH</i>	1050 <i>Co2</i>	
	General Classroom Information		Dust and cob webs on the walls. Dirty ceiling tiles. Floors slightly dirty.	Custodial staff should thoroughly clean all environmental surfaces within classroom and wax and clean flooring.
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment. Teacher had window open prior to assessment.	Location should monitor situation and consider slightly raising thermostat within this area.
		My room is too cold, the students complain.		
<b>150</b>	70.4 <i>Temp</i>	54% <i>RH</i>	1199 <i>Co2</i>	
	Animals in the Classroom	Take special care with asthmatic or other sensitive students.	No animals in the classroom.	No corrective action recommended at this time.
	Drain Traps	Drain traps, if present, can become a problem when the water in the drain trap evaporates due to infrequent use, allowing sewer gases to enter the room.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	General Cleanliness	Confirm that the classroom is cleaned properly	Dust accumulation was observed on environmental surfaces. Dust and debris on return air register grill.	Custodial staff should thoroughly clean all environmental surfaces within classroom and clean and sanitize return air grill.
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
	Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.
		This year, as well as last year, my room has been unreasonably hot with little or no air circulation on many days. In the last week or two the air conditioning seems to have improved. HOWEVER, I am concerned about the consistency of it, I am worried that it may become hot in here again, as it has been quite often, to the point where the STUDENTS complain they DO NOT FEEL WELL, like headaches, and MY THROAT HURTS so much, that by 5th or 6th hour it is extremely painful to talk. When the air is operating properly we do not suffer these problems. Thank you for your interest!		
<b>152</b>	72.7 <i>Temp</i>	53% <i>RH</i>	1085 <i>Co2</i>	

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
Art Supplies	Follow good safety, handling, and storage practices.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Art Supplies	Minimize exposure to hazardous materials.	No hazardous materials identified.	No corrective action recommended at this time.
Art Supplies	Learn about your supplies.		Site based administration will provide information to site based staff.
Drain Traps	Drain traps, if present, can become a problem when the water in the drain trap evaporates due to infrequent use, allowing sewer gases to enter the room.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Industrial and Vocational Education Supplies	Follow good safety, handling, and storage practices.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Industrial and Vocational Education Supplies	Minimize exposure to hazardous materials.	No hazardous supplied identified.	No corrective action recommended at this time.
Industrial and Vocational Education Supplies	Learn about your supplies.		Site based administration will provide information to site based staff.
Local Exhaust Fans	General items.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Local Exhaust Fans	Confirm that fume hoods and local exhaust fans function properly.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Local Exhaust Fans	Confirm that fume hoods and local exhaust fans are used whenever activities that generate pollutants take place.	Fume hoods and exhaust fans are used.	No corrective action recommended at this time.
<p>The design of the Foods Lab (Room 152) is poorly designed. The garbage disposals are non-operational due to no electric hook-up. Poor plumbing causes backups in sinks and flooding and leaking. There is virtually no storage area in the room, so all supplies are all over the room, in no safe place. The dryer vent is not attached, so no items can be washed or dried in the room. There are a lot of poorly designed details that need to have immediate attention.</p>			
<b>157</b>	64.8	56%	1004
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>
General Cleanliness	Confirm that the classroom is cleaned properly	Dust and debris was observed on the air supply and return registers at the time of the assessment. Dust on countertops.	Custodial staff should clean and sanitize the air supply and return registers in this classroom and dust countertops.
Maintain Student Health Records	Include information about sensitivities to IAQ problems in student health records.		Site based administration will provide information to site based staff.
Thermal Comfort	General items to watch for.	Classroom is too cold.	Check HVAC for proper operation.



	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
<b>201</b>	Ventilation	Determine how your classroom is ventilated.	Air supply ductwork within the false ceiling plenum has a hole.	Maintenance to inspect and repair as appropriate.
		72.9 <i>Temp</i>	54% <i>RH</i>	996 <i>Co2</i>
<b>201A</b>	General Cleanliness	Confirm that the classroom is cleaned properly	Dust and debris was observed on the air supply and return registers at the time of the assessment.	Custodial staff should clean and sanitize the air supply and return registers in this classroom.
		72.9 <i>Temp</i>	54% <i>RH</i>	1035 <i>Co2</i>
<b>201B</b>	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
	Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.
	Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing slightly into the room from the air supply vents.	Check HVAC for proper operation.
	Ventilation	If you have mechanical ventilation, confirm that air is flowing from the room into the air return grille(s).	Return air grill is functioning properly but has minor dust and debris.	Custodial staff should clean and sanitize the return registers in this classroom.
		Since my room was set up as a technology storage room I don't think we receive the air conditioning of a normal classroom.		
	73.3 <i>Temp</i>	54% <i>RH</i>	1032 <i>Co2</i>	
	General Cleanliness	Confirm that the classroom is cleaned properly	Carpeting is dirty.	Clean and sanitize carpeting.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
	Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.
	Ventilation	If you have mechanical ventilation, confirm that air is flowing from the room into the air return grille(s).	Return air grill is functioning properly.	No corrective action recommended at this time.
	Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.
	My room is very warm all the time; I went out and bought some fans just to move the air. Many of my students have allergy problems and sneeze throughout class.			
<b>201F</b>	70.1	53%	1029	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	Local Exhaust Fans	General items.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
	Thermal Comfort	General items to watch for.	Air supply vent has been blocked off with a cardboard folder.	Maintenance needs to inspect HVAC and repair.
	Teacher's bathrooms in the Library need exhaust fans. Odor from bathrooms spreads quickly into my room.			
<b>201J and 201H</b>				
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	General Classroom Information		Exhaust fans are not working.	Maintenance to inspect and repair as appropriate.
<b>210</b>	72.2	50%	936	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	General Classroom Information		Dust accumulation was observed on environmental surfaces. Dust and debris was observed on the air supply and return registers at the time of the assessment.	Custodial staff should thoroughly clean all environmental surfaces within classroom. Clean and sanitize the air supply and return registers in this classroom.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
211	General Cleanliness	Check for pests.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
		My pests are very small ants that have found their way into the local classrooms. Not sure it is an issue, but some of my windows' hurricane vents are seizing up (and it is a new school) - perhaps they need some grease to avoid total seizure in the years to come?		
		72.7 <i>Temp</i>	51% <i>RH</i>	872 <i>Co2</i>
217	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
		72.6 <i>Temp</i>	51% <i>RH</i>	854 <i>Co2</i>
222	General Cleanliness	Confirm that the classroom is cleaned properly	Dust and debris was observed on the air supply and return registers at the time of the assessment.	Custodial staff should clean and sanitize the air supply and return registers in this classroom.
		74.5 <i>Temp</i>	53% <i>RH</i>	1019 <i>Co2</i>
	General Cleanliness	Confirm that the classroom is cleaned properly	General cleanliness appeared adequate on date of assessment.	No corrective action recommended at this time.
	Thermal Comfort	Humidity level.	The humidity was 53% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
	Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Air is flowing into the room from the air supply vents.	No corrective action recommended at this time.

	<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
223	Ventilation	If you have mechanical ventilation, confirm that air is flowing from the room into the air return grille(s).	Dust and debris was observed on the return registers at the time of the assessment.	Custodial staff should clean and sanitize the return registers in this classroom.
	75.1	52%	1130	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
224	General Classroom Information		Dust and debris was observed on the return registers at the time of the assessment.	Custodial staff should clean and sanitize the return registers in this classroom.
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
	74.7	51%	1094	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
225	Health and Hygiene Education	Establish an information and counseling program regarding smoking.		Site based administration will provide information to site based staff.
	Health and Hygiene Education	Inform students and staff about the importance of good hygiene in preventing the spread of airborne contagious diseases.		Site based administration will provide information to site based staff.
	Health and Hygiene Education	Obtain Indoor Air Quality: An introduction for health professionals.		Site based administration will provide information to site based staff.
	Maintain Student Health Records	Track health-related complaints by students and staff.		Site based administration will provide information to site based staff.
	74.5	52%	1094	
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>	
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>	
232	<div style="border: 1px solid black; width: 100%; height: 20px; margin-bottom: 5px;"></div> <div style="display: flex; justify-content: space-around;"> <div style="border: 1px solid black; padding: 2px;">75.4</div> <div style="border: 1px solid black; padding: 2px;">49%</div> <div style="border: 1px solid black; padding: 2px;">873</div> </div> <p style="text-align: center;"><i>Temp</i>      <i>RH</i>      <i>Co2</i></p>			
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
233	<div style="border: 1px solid black; width: 100%; height: 20px; margin-bottom: 5px;"></div> <div style="display: flex; justify-content: space-around;"> <div style="border: 1px solid black; padding: 2px;">74.1</div> <div style="border: 1px solid black; padding: 2px;">47%</div> <div style="border: 1px solid black; padding: 2px;">893</div> </div> <p style="text-align: center;"><i>Temp</i>      <i>RH</i>      <i>Co2</i></p>			
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
248	<div style="border: 1px solid black; width: 100%; height: 20px; margin-bottom: 5px;"></div> <div style="border: 1px solid black; width: 100%; height: 20px; margin-bottom: 5px;"></div> <div style="border: 1px solid black; width: 100%; height: 20px; margin-bottom: 5px;"></div> <div style="display: flex; justify-content: space-around;"> <div style="border: 1px solid black; padding: 2px;">73</div> <div style="border: 1px solid black; padding: 2px;">46%</div> <div style="border: 1px solid black; padding: 2px;">624</div> </div> <p style="text-align: center;"><i>Temp</i>      <i>RH</i>      <i>Co2</i></p>	A/C does not always work. Sometimes it is very hot in here.		
	General Classroom Information		Dust and debris was observed on the return registers at the time of the assessment.	Custodial staff should clean and sanitize the return registers in this classroom.
	Thermal Comfort	General items to watch for.	Temperature was within acceptable range at time of assessment.	No corrective action recommended at this time.
304	<div style="border: 1px solid black; width: 100%; height: 20px; margin-bottom: 5px;"></div> <div style="display: flex; justify-content: space-around;"> <div style="border: 1px solid black; padding: 2px;">76.1</div> <div style="border: 1px solid black; padding: 2px;">52%</div> <div style="border: 1px solid black; padding: 2px;">1900</div> </div> <p style="text-align: center;"><i>Temp</i>      <i>RH</i>      <i>Co2</i></p>			
	Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.

<i>Category</i>	<i>Detail</i>	<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
General Classroom Information		Co2 level was slightly elevated at time of assessment.	Maintenance to inspect and repair as appropriate to lower Co2 level.
Thermal Comfort	Humidity level.	the humidity was 52% at the time of assessment. The desired humidity level is below 60%.	No corrective action recommended at this time.
Ventilation	If you have mechanical ventilation, confirm that air is flowing from the room into the air return grille(s).	Ceilings were too high to determine air flow.	No corrective action recommended at this time.
Ventilation	If you have mechanical ventilation, confirm that air is flowing into the room from the air supply vent(s).	Ceilings were too high to determine air flow.	No corrective action recommended at this time.
Ventilation	Determine how your classroom is ventilated.	Ceilings were too high to determine air flow.	No corrective action recommended at this time.
<div style="border: 1px solid black; width: 100%; height: 20px; margin-bottom: 5px;"></div>			
<b>305</b>	75.6	53%	1800
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>
General Classroom Information		Co2 level was slightly elevated at time of assessment.	Maintenance to inspect and repair as appropriate to lower Co2 level.
<div style="border: 1px solid black; width: 100%; height: 20px; margin-bottom: 5px;"></div>			
<b>306</b>	72.2	54%	1833
	<i>Temp</i>	<i>RH</i>	<i>Co2</i>
Excess Moisture in Classrooms	Check for leaks or signs of moisture from plumbing or roofs.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
Excess Moisture in Classrooms	Condensate (condensed water, or "fog") on cold surfaces.	There were no problems observed at time of assessment.	No corrective action recommended at this time.
General Classroom Information		Co2 level was slightly elevated at time of assessment.	Maintenance to inspect and repair as appropriate to lower Co2 level.
Ventilation	Determine how your classroom is ventilated.	Ventilation is working properly.	No corrective action recommended at this time.
Ventilation	Check for unexplained odors.	No odors were detected at time of assessment.	No corrective action recommended at this time.
<div style="border: 1px solid black; width: 100%; height: 20px; margin-bottom: 5px;"></div>			

	<i>Category</i>	<i>Detail</i>		<i>Assessment Comments</i>	<i>Recommended Corrective Action</i>
<b>317</b>	73.4 <i>Temp</i>	50% <i>RH</i>	532 <i>Co2</i>		
	General Cleanliness	Check for pests.		There were no problems observed at time of assessment.	No corrective action recommended at this time.
		<div style="border: 1px solid black; height: 20px; width: 100%;"></div>			